

Upcoming high-impact outages in the NEM (information as of 28/08/2017 1625 hrs):

| |
|---------------------------------------|
| Newly added outage |
| Update(s) since the last notification |

| Region | NSP | Start | Finish | Network asset | Impact | Recall time | Market notice | Constraint | Outage reason |
|--------|-----------|------------------|------------------|--|--|-------------------------------------|---|----------------|---------------|
| VIC | AusNet | 28/08/2017 10:30 | 28/08/2017 17:30 | Moorabool - Mortlake 500 kV Line | <p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Local regulation raise and lower FCAS will be sourced within South Australia. • When power transfer is from South Australia to Victoria, contingency lower FCAS will be sourced within SA. | Day: 2 hrs Night: Not applicable | Issued on 08/08/2017 Updated on 25/08/2017 | Invoked | Maintenance |
| NSW | Transgrid | 30/08/2017 11:00 | 30/08/2017 13:00 | Armidale - Tamworth (85) 330 kV Line | <p>A credible contingency event during this planned outage could cause:</p> <ul style="list-style-type: none"> • Synchronous separation of the Queensland region from the rest of the NEM | Day: 1 hrs Night: No recall | Not required | Invoked | Maintenance |
| QLD | Powerlink | 04/09/2017 07:00 | 22/09/2017 17:00 | Stanwell - Broadsound (8831) 275 kV Line | <p>This is a high impact outage because the recall time is greater than 30 minutes.</p> <p>A credible contingency event during this planned outage may result in shedding Far North QLD and Lilyvale local load.</p> <p>Following a credible contingency market intervention through issuing of directions may be required. If market intervention is unsuccessful all of North QLD load would be in a credible risk</p> | Day: 6 days Night: 6 days | Not required | Being assessed | Project work |
| VIC | AusNet | 09/09/2017 06:30 | 09/09/2017 14:00 | Ballarat - Waubra - Horsham 220 kV Line | <p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs Night: Not applicable | Not required | Invoked | Maintenance |

Upcoming high-impact outages in the NEM (information as of 28/08/2017 1625 hrs):

| |
|---------------------------------------|
| Newly added outage |
| Update(s) since the last notification |

| Region | NSP | Start | Finish | Network asset | Impact | Recall time | Market notice | Constraint | Outage reason |
|-----------|------------|------------------|------------------|---|--|-------------------------------------|---------------|----------------|---------------|
| VIC | AusNet | 09/09/2017 07:00 | 09/09/2017 17:00 | Hazelwood - Cranbourne 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: <ul style="list-style-type: none"> • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs Night: Not applicable | Not required | Invoked | Maintenance |
| VIC | AusNet | 10/09/2017 07:00 | 10/09/2017 17:00 | | | | | | |
| VIC | AusNet | 13/09/2017 07:30 | 13/09/2017 16:00 | Keilor – Sydenham 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: <ul style="list-style-type: none"> • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs Night: Not applicable | Not required | Invoked | Maintenance |
| VIC | AusNet | 14/09/2017 07:00 | 14/09/2017 16:00 | Keilor – Sydenham 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: <ul style="list-style-type: none"> • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs Night: Not applicable | Not required | Invoked | Maintenance |
| NSW / VIC | Transgrid | 15/09/2017 08:00 | 15/09/2017 10:00 | Buronga Red_Cliffs X1 220kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 1 hrs Night: No recall | Not required | Invoked | Maintenance |
| SA | ElectraNet | 18/09/2017 08:00 | 29/09/2017 15:30 | Tailem Bend - South East No.1 275 kV Line | This outage has been WITHDRAWN. A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: <ul style="list-style-type: none"> • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 80 hrs Night: 88 hrs | To be issued | Being assessed | Maintenance |

Upcoming high-impact outages in the NEM (information as of 28/08/2017 1625 hrs):

| |
|---------------------------------------|
| Newly added outage |
| Update(s) since the last notification |

| Region | NSP | Start | Finish | Network asset | Impact | Recall time | Market notice | Constraint | Outage reason |
|--------|------------|------------------|------------------|---|--|------------------------------|---------------|----------------|---------------|
| QLD | Powerlink | 19/09/2017 08:00 | 22/09/2017 15:00 | Ross No.2 288/138/19 kV Transformer | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 2 hrs Night: 2 hrs | Not required | Not required | Maintenance |
| NSW | Transgrid | 27/09/2017 08:00 | 28/09/2017 17:00 | Buronga–Balranald-Darlington Point (X5) 220 kV line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C During this planned outage power transfer will be restricted <ul style="list-style-type: none"> Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. | Day: 2 hrs Night: 4 hrs | Not required | Being assessed | Maintenance |
| SA | ElectraNet | 04/10/2017 07:30 | 07/10/2017 09:30 | Tailem Bend - South East No.2 275 kV Line | This outage has been WITHDRAWN. A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: <ul style="list-style-type: none"> Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 26 hrs Night: 32 hrs | To be issued | Being assessed | Maintenance |
| SA | ElectraNet | 07/10/2017 09:30 | 08/10/2017 13:30 | Tailem Bend - Tungkillio 275 kV Line | This outage has been WITHDRAWN. A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: <ul style="list-style-type: none"> Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 26 hrs Night: 32 hrs | To be issued | Being assessed | Maintenance |

Upcoming high-impact outages in the NEM (information as of 28/08/2017 1625 hrs):

| |
|---------------------------------------|
| Newly added outage |
| Update(s) since the last notification |

| Region | NSP | Start | Finish | Network asset | Impact | Recall time | Market notice | Constraint | Outage reason |
|--------|-----------|------------------|------------------|---|--|---------------------------------------|---------------|------------|---------------|
| NSW | Transgrid | 10/10/2017 06:00 | 11/10/2017 16:00 | Lower Tumut - Wagga (051) 330 kV Line | <p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer</p> <ul style="list-style-type: none"> • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 8 hrs Night: 8 hrs | Not required | Invoked | Maintenance |
| VIC | AusNet | 11/10/2017 07:00 | 11/10/2017 16:00 | Hazelwood - Cranbourne 500 kV Line | <p>This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW</p> <p>A credible contingency event during this planned outage could:</p> <ul style="list-style-type: none"> • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 1 hrs Night: Not applicable | Not required | Invoked | Maintenance |
| NSW | Transgrid | 12/10/2017 06:00 | 12/10/2017 16:00 | Armidale - Dumaresq (8C) 500 kV Line | <p>A credible contingency event during this planned outage could cause:</p> <ul style="list-style-type: none"> • Synchronous separation of the Queensland region from the rest of the NEM | Day: 2 hrs Night: No recall | Not required | Invoked | Maintenance |
| NSW | Transgrid | 13/10/2017 06:00 | 13/10/2017 16:00 | Armidale - Dumaresq (8C) 500 kV Line | <p>A credible contingency event during this planned outage could cause:</p> <ul style="list-style-type: none"> • Synchronous separation of the Queensland region from the rest of the NEM | Day: 2 hrs Night: No recall | Not required | Invoked | Maintenance |
| NSW | Transgrid | 14/10/2017 05:00 | 14/10/2017 16:00 | Armidale - Dumaresq (8C) 500 kV Line | <p>A credible contingency event during this planned outage could cause:</p> <ul style="list-style-type: none"> • Synchronous separation of the Queensland region from the rest of the NEM | Day: 3 hrs Night: No recall | Not required | Invoked | Maintenance |
| NSW | Transgrid | 15/10/2017 06:00 | 15/10/2017 16:00 | Armidale - Dumaresq (8C) 500 kV Line | <p>A credible contingency event during this planned outage could cause:</p> <ul style="list-style-type: none"> • Synchronous separation of the Queensland region from the rest of the NEM | Day: 3 hrs Night: No recall | Not required | Invoked | Maintenance |
| VIC | AusNet | 15/10/2017 07:30 | 15/10/2017 15:00 | Hazelwood - Loy Yang Power Station No.1 500 kV Line | <p>A credible contingency event during this planned outage could cause:</p> <ul style="list-style-type: none"> • A large reduction in generation in Victoria • Load shedding in Victoria | Day: 30 mins Night: Not applicable | Not required | Invoked | Maintenance |

Upcoming high-impact outages in the NEM (information as of 28/08/2017 1625 hrs):

| |
|---------------------------------------|
| Newly added outage |
| Update(s) since the last notification |

| Region | NSP | Start | Finish | Network asset | Impact | Recall time | Market notice | Constraint | Outage reason |
|--------|------------|------------------|------------------|---|--|---------------------------------------|----------------------|------------|---------------|
| NSW | Transgrid | 16/10/2017 06:00 | 16/10/2017 16:00 | Armidale - Dumaresq (8C) 500 kV Line | A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> Synchronous separation of the Queensland region from the rest of the NEM | Day: 3 hrs Night: No recall | Not required | Invoked | Maintenance |
| SA | ElectraNet | 16/10/2017 08:00 | 27/10/2017 15:30 | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: <ul style="list-style-type: none"> Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 80 hrs Night: 88 hrs | Issued on 28/08/2017 | Invoked | Project work |
| NSW | Transgrid | 17/10/2017 06:00 | 17/10/2017 16:00 | Armidale - Dumaresq (8C) 500 kV Line | A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> Synchronous separation of the Queensland region from the rest of the NEM | Day: 3 hrs Night: No recall | Not required | Invoked | Maintenance |
| NSW | Transgrid | 18/10/2017 06:00 | 18/10/2017 16:00 | Armidale - Dumaresq (8C) 500 kV Line | A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> Synchronous separation of the Queensland region from the rest of the NEM | Day: 3 hrs Night: No recall | Not required | Invoked | Maintenance |
| VIC | AusNet | 28/10/2017 06:00 | 28/10/2017 11:00 | Hazelwood Terminal Station - Loy Yang Power Station 500 kV line | A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> A large reduction in generation in Victoria Load shedding in Victoria | Day: 30 mins Night: Not applicable | Not required | Invoked | Maintenance |

Upcoming high-impact outages in the NEM (information as of 28/08/2017 1625 hrs):

| |
|---------------------------------------|
| Newly added outage |
| Update(s) since the last notification |

| Region | NSP | Start | Finish | Network asset | Impact | Recall time | Market notice | Constraint | Outage reason |
|--------|------------|------------------|------------------|---|--|---------------------------------------|---------------|------------|---------------|
| VIC | AusNet | 28/10/2017 11:00 | 28/10/2017 17:30 | Hazelwood Terminal Station - Loy Yang Power Station 500 kV line | A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> • A large reduction in generation in Victoria • Load shedding in Victoria | Day: 30 mins Night: Not applicable | Not required | Invoked | Maintenance |
| VIC | AusNet | 29/10/2017 06:00 | 29/10/2017 15:30 | Hazelwood Terminal Station - Loy Yang Power Station 500 kV line | A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> • A large reduction in generation in Victoria • Load shedding in Victoria | Day: 30 mins Night: Not applicable | Not required | Invoked | Maintenance |
| SA | ElectraNet | 01/11/2017 08:30 | 06/11/2017 10:30 | Tailem Bend - South East No.2 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: <ul style="list-style-type: none"> • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. <p>During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</p> | Day: 26 hrs Night: 32 hrs | To be issued | Invoked | Project work |
| SA | ElectraNet | 06/11/2017 10:30 | 07/11/2017 14:30 | Tailem Bend - Tungkillio 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: <ul style="list-style-type: none"> • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. <p>During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</p> | Day: 26 hrs Night: 32 hrs | To be issued | Invoked | Project work |

Upcoming high-impact outages in the NEM (information as of 28/08/2017 1625 hrs):

| |
|---------------------------------------|
| Newly added outage |
| Update(s) since the last notification |

| Region | NSP | Start | Finish | Network asset | Impact | Recall time | Market notice | Constraint | Outage reason |
|----------|-------------|------------------|------------------|---------------------------------------|---|---------------------------------------|---------------|----------------|---------------|
| NSW | Transgrid | 14/11/2017 07:00 | 20/11/2017 16:00 | Jindera - Wagga (62) 330 kV Line | <p>This outage has been WITHDRAWN.</p> <p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer</p> <ul style="list-style-type: none"> • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs Night: 2 hrs | Not required | Being assessed | Maintenance |
| TAS | TasNetworks | 14/11/2017 08:00 | 14/11/2017 14:00 | Sheffield - Farrell No.1 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 1 hrs Night: Not applicable | Not required | Being assessed | Maintenance |
| TAS | TasNetworks | 01/12/2017 07:00 | 01/12/2017 15:00 | Sheffield - Farrell No.1 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 1.5 hrs Night: Not applicable | Not required | Being assessed | Maintenance |
| VIC / SA | ElectraNet | 17/06/2018 08:00 | 17/06/2018 17:00 | Heywood - South East No.1 275 kV Line | <p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Local regulation raise and lower FCAS will be sourced within South Australia. • When power transfer is from South Australia to Victoria, contingency lower FCAS will be sourced within SA. | Day: 1.5 hrs Night: Not applicable | To be issued | Being assessed | Maintenance |

Upcoming high-impact outages in the NEM (information as of 28/08/2017 1625 hrs):

| |
|---------------------------------------|
| Newly added outage |
| Update(s) since the last notification |

| Region | NSP | Start | Finish | Network asset | Impact | Recall time | Market notice | Constraint | Outage reason |
|----------|-------------|------------------|------------------|---------------------------------------|--|---------------------------------------|---------------|----------------|---------------|
| VIC / SA | ElectraNet | 18/06/2018 08:00 | 18/06/2018 17:00 | Heywood - South East No.1 275 kV Line | <p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Local regulation raise and lower FCAS will be sourced within South Australia. • When power transfer is from South Australia to Victoria, contingency lower FCAS will be sourced within SA. | Day: 1.5 hrs Night: Not applicable | To be issued | Being assessed | Maintenance |
| VIC / SA | ElectraNet | 19/06/2018 08:00 | 19/06/2018 17:00 | Heywood - South East No.2 275 kV Line | <p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Local regulation raise and lower FCAS will be sourced within South Australia. • When power transfer is from South Australia to Victoria, contingency lower FCAS will be sourced within SA. | Day: 1.5 hrs Night: Not applicable | To be issued | Being assessed | Maintenance |
| VIC / SA | ElectraNet | 20/06/2018 08:00 | 20/06/2018 17:00 | Heywood - South East No.2 275 kV Line | <p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Local regulation raise and lower FCAS will be sourced within South Australia. • When power transfer is from South Australia to Victoria, contingency lower FCAS will be sourced within SA. | Day: 1.5 hrs Night: Not applicable | To be issued | Being assessed | Maintenance |
| TAS | TasNetworks | 02/10/2018 08:00 | 02/10/2018 16:00 | Gordon - Chapel St No.1 220 kV Line | <p>A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.</p> | Day: 2.5 hrs Night: Not applicable | Not required | Invoked | Maintenance |

Upcoming high-impact outages in the NEM (information as of 28/08/2017 1625 hrs):

| |
|---------------------------------------|
| Newly added outage |
| Update(s) since the last notification |

| Region | NSP | Start | Finish | Network asset | Impact | Recall time | Market notice | Constraint | Outage reason |
|--------|-------------|------------------|------------------|--------------------------------------|--|---------------------------------------|---------------|----------------|---------------|
| TAS | TasNetworks | 05/10/2018 08:00 | 05/10/2018 16:00 | Gordon - Chapel St No.1 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 2.5 hrs Night: Not applicable | Not required | Invoked | Maintenance |
| TAS | TasNetworks | 09/10/2018 07:00 | 09/10/2018 15:00 | Gordon - Chapel St No.2 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 2.5 hrs Night: Not applicable | Not required | Invoked | Maintenance |
| TAS | TasNetworks | 12/10/2018 07:00 | 12/10/2018 15:00 | Gordon - Chapel St No.2 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 2.5 hrs Night: Not applicable | Not required | Invoked | Maintenance |
| TAS | TasNetworks | 05/12/2018 07:00 | 05/12/2018 16:00 | Sheffield - Farrell No.2 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 1.5 hrs Night: Not applicable | Not required | Being assessed | Maintenance |
| TAS | TasNetworks | 06/12/2018 07:00 | 06/12/2018 15:00 | Sheffield - Farrell No.1 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 1 hrs Night: Not applicable | Not required | Being assessed | Maintenance |

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.