

Upcoming High-Impact Outages (HIOs) in the NEM
- Information Current as of: 21 June 2021 - 1056 hrs -

Legend

| | |
|--|---------------------------------------|
| | Newly Added Outage |
| | Update(s) since the last notification |
| | Withdrawn since the last notification |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----------|-----------------------------|-----------------------------|--|--|-------------------------|---|------------|-------------|------------------|----------------|----------------------------|
| VIC | AusNet | 21/06/2021 07:12 Monday | 21/06/2021 17:00 Monday | Heywood - Mortlake 500 kV Line | <p><<NEW since the last notification>> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage:</p> <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | In Progress - PTP MN: 86491 - Issued on: Thu 03/06/2021 | ✓ | ✓ | ✓ | | Maintenance 9.8 Hours |
| NSW | Transgrid | 21/06/2021 07:30 Monday | 21/06/2021 17:00 Monday | Muswellbrook - Tamworth (88) 330 kV Line | <p>A credible contingency event during this planned outage could cause:</p> <ul style="list-style-type: none"> • Synchronous separation of the Queensland region from the rest of the NEM | Day: 3 hrs Night: NA | In Progress - PTP | ✓ | | | ✓ | Commissioning 9.5 Hours |
| VIC | AusNet | 22/06/2021 07:00 Tuesday | 22/06/2021 17:00 Tuesday | Heywood - Mortlake 500 kV Line | <p><<NEW since the last notification>> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage:</p> <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - MTLTP MN: 86491 - Issued on: Thu 03/06/2021 | ✓ | ✓ | ✓ | | Maintenance 10 Hours |
| NSW | Transgrid | 22/06/2021 07:30 Tuesday | 22/06/2021 17:00 Tuesday | Muswellbrook - Tamworth (88) 330 kV Line | <p>A credible contingency event during this planned outage could cause:</p> <ul style="list-style-type: none"> • Synchronous separation of the Queensland region from the rest of the NEM | Day: 3 hrs Night: NA | Planned - STLTP | ✓ | | | ✓ | Commissioning 9.5 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----------|-------------------------------|-------------------------------|--|--|-------------------------|---|------------|--------------|------------------|----------------|----------------------------|
| VIC | AusNet | 23/06/2021 07:00 Wednesday | 23/06/2021 17:00 Wednesday | Heywood - Mortlake 500 kV Line | <<NEW since the last notification>> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - MTLTP MN: 86491 - Issued on: Thu 03/06/2021 | ✓ | ✓ | ✓ | | Maintenance 10 Hours |
| NSW | Transgrid | 23/06/2021 07:30 Wednesday | 23/06/2021 17:00 Wednesday | Muswellbrook - Tamworth (88) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 3 hrs Night: NA | Planned - MTLTP | ✓ | | | ✓ | Commissioning 9.5 Hours |
| VIC | AusNet | 24/06/2021 07:00 Thursday | 24/06/2021 17:00 Thursday | Heywood - Mortlake 500 kV Line | <<NEW since the last notification>> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - MTLTP MN: 86491 - Issued on: Thu 03/06/2021 | ✓ | ✓ | ✓ | | Maintenance 10 Hours |
| NSW | Transgrid | 24/06/2021 07:30 Thursday | 24/06/2021 17:00 Thursday | Muswellbrook - Tamworth (88) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 3 hrs Night: NA | Planned - MTLTP | ✓ | | | ✓ | Commissioning 9.5 Hours |
| VIC | AusNet | 25/06/2021 07:00 Friday | 25/06/2021 17:00 Friday | Heywood - Mortlake 500 kV Line | <<NEW since the last notification>> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - MTLTP MN: 86491 - Issued on: Thu 03/06/2021 | ✓ | ✓ | ✓ | | Maintenance 10 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-------------|-------------------------------|-------------------------------|--|---|----------------------------|--------------------------|------------|--------------|------------------|----------------|----------------------------|
| NSW | Transgrid | 25/06/2021 07:30 Friday | 25/06/2021 17:00 Friday | Muswellbrook - Tamworth (88) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 3 hrs Night: NA | Planned - MTLTP | | ✓ | | ✓ | Commissioning 9.5 Hours |
| NSW | Transgrid | 26/06/2021 07:30 Saturday | 26/06/2021 17:00 Saturday | Muswellbrook - Tamworth (88) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 3 hrs Night: NA | Planned - MTLTP | | ✓ | | ✓ | Commissioning 9.5 Hours |
| NSW | Transgrid | 27/06/2021 07:00 Sunday | 27/06/2021 17:00 Sunday | Armidale - Tamworth (86) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 2 hrs Night: NA | Planned - MTLTP | | ✓ | ✓ | ✓ | Maintenance 10 Hours |
| NSW | Transgrid | 28/06/2021 07:00 Monday | 28/06/2021 17:00 Monday | Tamworth Liddell PS (84) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs Night: 4 hrs | Planned - MTLTP | | ✓ | ✓ | ✓ | Commissioning 10 Hours |
| NSW | Transgrid | 29/06/2021 07:00 Tuesday | 29/06/2021 17:00 Tuesday | Tamworth Liddell PS (84) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs Night: 4 hrs | Planned - MTLTP | | ✓ | ✓ | ✓ | Commissioning 10 Hours |
| NSW | Transgrid | 30/06/2021 07:00 Wednesday | 30/06/2021 17:00 Wednesday | Tamworth Liddell PS (84) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs Night: 4 hrs | Planned - MTLTP | | ✓ | ✓ | ✓ | Commissioning 10 Hours |
| TAS | TasNetworks | 30/06/2021 09:30 Wednesday | 30/06/2021 15:30 Wednesday | Gordon - Chapel St No.1 220 kV Line | <<NEW since the last notification>> A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 1.5 hrs Night: NA | Planned - MTLTP | | | | ✓ | Maintenance 6 Hours |
| NSW | Transgrid | 01/07/2021 07:00 Thursday | 01/07/2021 17:00 Thursday | Tamworth Liddell PS (84) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs Night: 4 hrs | Planned - MTLTP | | ✓ | ✓ | ✓ | Commissioning 10 Hours |
| NSW | Transgrid | 02/07/2021 07:00 Friday | 02/07/2021 17:00 Friday | Tamworth Liddell PS (84) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs Night: 4 hrs | Planned - MTLTP | | ✓ | ✓ | ✓ | Commissioning 10 Hours |
| NSW | Transgrid | 03/07/2021 07:00 Saturday | 03/07/2021 17:00 Saturday | Tamworth Liddell PS (84) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs Night: 4 hrs | Planned - MTLTP | | ✓ | ✓ | ✓ | Commissioning 10 Hours |
| NSW | Transgrid | 04/07/2021 07:30 Sunday | 04/07/2021 17:00 Sunday | Muswellbrook - Tamworth (88) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 3 hrs Night: NA | Planned - MTLTP | | ✓ | | ✓ | Commissioning 9.5 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----------|-------------------------------|-------------------------------|---|---|-------------------------|--------------------------|------------|--------------|------------------|----------------|-------------------------|
| VIC | AusNet | 06/07/2021 07:00 Tuesday | 06/07/2021 17:00 Tuesday | Red Cliffs-Wemen 220 kv ine | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - MTLTP | | | | | Maintenance 10 Hours |
| NSW | Transgrid | 06/07/2021 08:00 Tuesday | 06/07/2021 16:00 Tuesday | Wagga - Darlington Point (63) 330 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer •Between Victoria and New South Wales. •Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 1 hr Night: NA | Planned - SUBMIT | ✓ | ✓ | ✓ | | Maintenance 8 Hours |
| VIC | AusNet | 07/07/2021 07:00 Wednesday | 07/07/2021 17:00 Wednesday | Bendigo - Kerang 220 kV Line | <<This outage has been WITHDRAWN!>> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Withdrawn | | | | | Maintenance 10 Hours |
| VIC | AusNet | 07/07/2021 07:00 Wednesday | 07/07/2021 17:00 Wednesday | Bendigo - Kerang 220 kV Line | <<This outage has been WITHDRAWN!>> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Withdrawn | | | | | Maintenance 10 Hours |
| VIC | AusNet | 07/07/2021 07:00 Wednesday | 07/07/2021 17:00 Wednesday | Red Cliffs-Wemen 220 kv ine | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 08/07/2021 07:00 Thursday | 08/07/2021 17:00 Thursday | Bendigo - Kerang 220 kV Line | <<This outage has been WITHDRAWN!>> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Withdrawn | | | | | Maintenance 10 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----------|------------------------------|------------------------------|--|---|-------------------------|--------------------------|------------|--------------|------------------|----------------|----------------------------|
| VIC | AusNet | 08/07/2021 07:00 Thursday | 08/07/2021 17:00 Thursday | Red Cliffs-Wemen 220 kV ine | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 09/07/2021 07:00 Friday | 09/07/2021 17:00 Friday | Red Cliffs-Wemen 220 kV ine | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 10/07/2021 07:00 Saturday | 10/07/2021 17:00 Saturday | Red Cliffs-Wemen 220 kV ine | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| NSW | Transgrid | 10/07/2021 07:30 Saturday | 10/07/2021 17:00 Saturday | Muswellbrook - Tamworth (88) 330 kV Line | A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> • Synchronous separation of the Queensland region from the rest of the NEM | Day: 3 hrs Night: NA | Planned - MTLTP | | ✓ | | ✓ | Commissioning 9.5 Hours |
| VIC | AusNet | 11/07/2021 07:00 Sunday | 11/07/2021 17:00 Sunday | Red Cliffs-Wemen 220 kV ine | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 12/07/2021 07:00 Monday | 12/07/2021 19:00 Monday | Heywood - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| NSW | Transgrid | 12/07/2021 07:30 Monday | 12/07/2021 17:00 Monday | Armidale - Tamworth (86) 330 kV Line | A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> • Synchronous separation of the Queensland region from the rest of the NEM | Day: 2 hrs Night: NA | Planned - MTLTP | | | | | Maintenance 9.5 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|------------|-----------------------------|-----------------------------|---------------------------------------|---|--------------------------------|---|------------|--------------|------------------|----------------|--------------------------|
| VIC | AusNet | 12/07/2021 08:00 Monday | 12/07/2021 16:00 Monday | Hazelwood A1 500/220 kV Transformer | <<NEW since the last notification>> This is a high impact outage only if Hazelwood A3 transformer is not switched to No.2 220 kV bus Risk of large reduction in generation in Victoria and interconnector capacity between Victoria - South Australia following a credible contingency | Day: 30 mins Night: NA | Planned - SUBMIT | | | | | Maintenance 8 Hours |
| VIC | AusNet | 13/07/2021 07:00 Tuesday | 13/07/2021 19:00 Tuesday | Heywood - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| NSW | Transgrid | 13/07/2021 07:30 Tuesday | 13/07/2021 17:00 Tuesday | Armidale - Tamworth (86) 330 kV Line | <<NEW since the last notification>> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 2 hrs Night: NA | Planned - MTLTP | | | | | Maintenance 9.5 Hours |
| VIC | AusNet | 13/07/2021 08:00 Tuesday | 13/07/2021 12:00 Tuesday | Hazelwood A1 500/220 kV Transformer | <<NEW since the last notification>> This is a high impact outage only if Hazelwood A3 transformer is not switched to No.2 220 kV bus Risk of large reduction in generation in Victoria and interconnector capacity between Victoria - South Australia following a credible contingency | Day: 30 mins Night: NA | Planned - SUBMIT | | | | | Maintenance 4 Hours |
| SA | ElectraNet | 13/07/2021 08:15 Tuesday | 20/07/2021 08:15 Tuesday | Heywood - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 159 hrs Night: 159 hrs | Planned - MTLTP MN: 86982 - Issued on: Tue 15/06/2021 | | | | ✓ | Commissioning 7 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----------|-------------------------------|-------------------------------|--------------------------------------|--|-------------------------|--------------------------|------------|--------------|------------------|----------------|--------------------------|
| VIC | AusNet | 14/07/2021 07:00 Wednesday | 14/07/2021 19:00 Wednesday | Heywood - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| NSW | Transgrid | 14/07/2021 07:30 Wednesday | 14/07/2021 17:00 Wednesday | Armidale - Tamworth (86) 330 kV Line | <<NEW since the last notification>> A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> Synchronous separation of the Queensland region from the rest of the NEM | Day: 2 hrs Night: NA | Planned - SUBMIT | | ✓ | | ✓ | Maintenance 9.5 Hours |
| VIC | AusNet | 14/07/2021 08:00 Wednesday | 14/07/2021 16:00 Wednesday | Rowville - South Morang 500 kV Line | <<NEW since the last notification>> This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: <ul style="list-style-type: none"> Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 1 hr Night: NA | Planned - SUBMIT | | | | | Maintenance 8 Hours |
| VIC | AusNet | 15/07/2021 07:00 Thursday | 15/07/2021 17:00 Thursday | Kerang-Wemen 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| NSW | Transgrid | 15/07/2021 07:30 Thursday | 15/07/2021 17:00 Thursday | Armidale - Tamworth (86) 330 kV Line | <<NEW since the last notification>> A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> Synchronous separation of the Queensland region from the rest of the NEM | Day: 2 hrs Night: NA | Planned - SUBMIT | | ✓ | | ✓ | Maintenance 9.5 Hours |
| VIC | AusNet | 16/07/2021 07:00 Friday | 16/07/2021 17:00 Friday | Kerang-Wemen 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| NSW | Transgrid | 16/07/2021 07:30 Friday | 16/07/2021 17:00 Friday | Armidale - Tamworth (86) 330 kV Line | <<NEW since the last notification>> A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> Synchronous separation of the Queensland region from the rest of the NEM | Day: 2 hrs Night: NA | Planned - SUBMIT | | ✓ | | ✓ | Maintenance 9.5 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----------|------------------------------|-------------------------------|--|--|----------------------------|--------------------------|------------|--------------|------------------|----------------|---------------------------|
| VIC | AusNet | 17/07/2021 07:00 Saturday | 17/07/2021 17:00 Saturday | Kerang-Wemen 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| NSW | Transgrid | 17/07/2021 07:30 Saturday | 17/07/2021 17:00 Saturday | Armidale - Tamworth (86) 330 kV Line | <<NEW since the last notification>> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 2 hrs Night: NA | Planned - SUBMIT | | ✓ | | ✓ | Maintenance 9.5 Hours |
| VIC | AusNet | 18/07/2021 07:00 Sunday | 18/07/2021 17:00 Sunday | Bendigo - Kerang 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - RESUBMIT | | | | | Maintenance 10 Hours |
| NSW | Transgrid | 18/07/2021 07:30 Sunday | 18/07/2021 17:00 Sunday | Armidale - Tamworth (86) 330 kV Line | <<NEW since the last notification>> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 2 hrs Night: NA | Planned - SUBMIT | | ✓ | | ✓ | Maintenance 9.5 Hours |
| NSW | Transgrid | 19/07/2021 06:30 Monday | 21/07/2021 17:00 Wednesday | Liddell to Muswellbrook (83) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs Night: 4 hrs | Planned - MTLTP | | ✓ | | ✓ | Commissioning 2.4 Days |
| VIC | AusNet | 19/07/2021 07:00 Monday | 19/07/2021 17:00 Monday | Bendigo - Kerang 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - RESUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 20/07/2021 07:00 Tuesday | 20/07/2021 17:00 Tuesday | Bendigo - Kerang 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - RESUBMIT | | | | | Maintenance 10 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|------------|-------------------------------|-------------------------------|---------------------------------------|---|--------------------------------|---|------------|--------------|------------------|----------------|---------------------------|
| SA | ElectraNet | 20/07/2021 08:15 Tuesday | 22/07/2021 17:30 Thursday | Heywood - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 159 hrs Night: 159 hrs | Planned - MTLTP MN: 87531 - Issued on: Mon 21/06/2021 | | | | ✓ | Commissioning 2.4 Days |
| VIC | AusNet | 21/07/2021 07:00 Wednesday | 21/07/2021 17:00 Wednesday | Heywood No.2 500 kV Bus | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 22/07/2021 07:00 Thursday | 22/07/2021 17:00 Thursday | Heywood No.2 500 kV Bus | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 23/07/2021 07:00 Friday | 23/07/2021 17:00 Friday | Heywood No.2 500 kV Bus | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNSP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----------|-------------------------------|-------------------------------|--|---|----------------------------|--------------------------|------------|-------------|------------------|----------------|---------------------------|
| NSW | Transgrid | 24/07/2021 06:00 Saturday | 25/07/2021 17:00 Sunday | Liddell to Muswellbrook (83) 330 kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs Night: 4 hrs | Planned - MTLTP | | ✓ | | ✓ | Commissioning 1.5 Days |
| VIC | AusNet | 24/07/2021 07:00 Saturday | 24/07/2021 17:00 Saturday | Kerang-Wemen 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - RESUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 25/07/2021 07:00 Sunday | 25/07/2021 17:00 Sunday | Kerang-Wemen 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - RESUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 26/07/2021 07:00 Monday | 26/07/2021 17:00 Monday | Red Cliffs-Wemen 220 kV ine | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 27/07/2021 07:00 Tuesday | 27/07/2021 17:00 Tuesday | Red Cliffs-Wemen 220 kV ine | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 28/07/2021 07:00 Wednesday | 28/07/2021 19:00 Wednesday | Heywood - Tarrone 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|--------|------------------------------|-------------------------------|-------------------------------|---|------------------------------|--------------------------|------------|--------------|------------------|----------------|-------------------------|
| VIC | AusNet | 29/07/2021 07:00 Thursday | 29/07/2021 19:00 Thursday | Heywood - Tarrone 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| VIC | AusNet | 30/07/2021 07:00 Friday | 30/07/2021 19:00 Friday | Heywood - Tarrone 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| VIC | AusNet | 31/07/2021 07:00 Saturday | 31/07/2021 19:00 Saturday | Heywood - Tarrone 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| VIC | AusNet | 02/08/2021 07:00 Monday | 04/08/2021 17:00 Wednesday | Heywood No.1 500 kV Bus | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 24 hrs Night: 24 hrs | Planned - SUBMIT | | | | | Maintenance 2.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----------|------------------------------|------------------------------|---|--|-----------------------------|--------------------------|------------|--------------|------------------|----------------|---------------------------|
| VIC | AusNet | 06/08/2021 07:00 Friday | 06/08/2021 17:00 Friday | Bendigo - Kerang 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 07/08/2021 07:00 Saturday | 07/08/2021 17:00 Saturday | Bendigo - Kerang 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 08/08/2021 07:00 Sunday | 08/08/2021 17:00 Sunday | Bendigo - Kerang 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| QLD | Powerlink | 09/08/2021 07:00 Monday | 13/08/2021 17:00 Friday | Stanwell - Broadsound (856) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may result in shedding Far North QLD load and Lilyvale local load. Following a credible contingency market intervention through issuing of directions may be required. If market intervention is unsuccessful all of North QLD load would be in a credible risk | Day: 8 hrs Night: 12 hrs | Planned - SUBMIT | | | | | Commissioning 4.4 Days |
| VIC | AusNet | 09/08/2021 07:00 Monday | 09/08/2021 17:00 Monday | Bendigo - Kerang 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 10/08/2021 07:00 Tuesday | 10/08/2021 17:00 Tuesday | Bendigo - Kerang 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----------|-------------------------------|-------------------------------|-----------------------------------|--|------------------------------|--------------------------|------------|--------------|------------------|----------------|-------------------------|
| NSW | Transgrid | 11/08/2021 07:00 Wednesday | 11/08/2021 17:00 Wednesday | Buronga-Balranald (X3) 220kV line | <p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>During this planned outage power transfer will be restricted</p> <ul style="list-style-type: none"> • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - RESUBMIT | | | ✓ | ✓ | Maintenance 10 Hours |
| VIC | AusNet | 11/08/2021 07:00 Wednesday | 11/08/2021 17:00 Wednesday | Bendigo - Kerang 220 kV Line | <p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 12/08/2021 07:00 Thursday | 12/08/2021 17:00 Thursday | Bendigo - Kerang 220 kV Line | <p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 13/08/2021 07:00 Friday | 13/08/2021 17:00 Friday | Bendigo - Kerang 220 kV Line | <p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 14/08/2021 07:00 Saturday | 14/08/2021 17:00 Saturday | Bendigo - Kerang 220 kV Line | <p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 16/08/2021 07:00 Monday | 17/08/2021 17:00 Tuesday | Heywood No.2 500 kV Bus | <p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 24 hrs Night: 24 hrs | Planned - SUBMIT | | | | | Maintenance 1.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----------|------------------------------|------------------------------|--------------------------------------|---|-------------------------|--------------------------|------------|--------------|------------------|----------------|-------------------------|
| VIC | AusNet | 20/08/2021 07:00 Friday | 20/08/2021 19:00 Friday | Heywood - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| VIC | AusNet | 21/08/2021 07:00 Saturday | 21/08/2021 19:00 Saturday | Heywood - Tarrone 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 1 hr Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| VIC | AusNet | 23/08/2021 07:00 Monday | 23/08/2021 17:00 Monday | Kerang-Wemen 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. | Day: NA Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 24/08/2021 07:00 Tuesday | 24/08/2021 17:00 Tuesday | Bendigo - Kerang 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. | Day: NA Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| QLD | Powerlink | 26/08/2021 09:00 Thursday | 26/08/2021 12:00 Thursday | Nebo - Strathmore (8845) 275 kV Line | <<NEW since the last notification>> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 3 Hours |
| QLD | Powerlink | 26/08/2021 13:00 Thursday | 26/08/2021 17:00 Thursday | Nebo - Strathmore (8845) 275 kV Line | <<NEW since the last notification>> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 4 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----------|-------------------------------|-------------------------------|---|---|------------------------------|--------------------------|------------|--------------|------------------|----------------|---------------------------|
| QLD | Powerlink | 28/08/2021 07:00 Saturday | 28/08/2021 18:00 Saturday | Haughton River - Strathmore (879) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 4 hrs Night: 8 hrs | Planned - SUBMIT | | | | | Maintenance 11 Hours |
| NSW | Transgrid | 30/08/2021 08:00 Monday | 03/09/2021 17:00 Friday | Lower Tumut - Wagga (051) 330 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 12 hrs Night: 12 hrs | Planned - SUBMIT | | | | | Commissioning 4.4 Days |
| QLD | Powerlink | 01/09/2021 08:30 Wednesday | 01/09/2021 12:00 Wednesday | Ross No.4 288/138/19 kV Transformer | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 1 hr Night: NA | Planned - SUBMIT | | | | | Maintenance 3.5 Hours |
| VIC | AusNet | 04/09/2021 07:00 Saturday | 04/09/2021 19:00 Saturday | Heywood - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| QLD | Powerlink | 06/09/2021 07:00 Monday | 10/09/2021 17:00 Friday | Stanwell - Broadsound (856) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may result in shedding Far North QLD load and Lilyvale local load. Following a credible contingency market intervention through issuing of directions may be required. If market intervention is unsuccessful all of North QLD load would be in a credible risk | Day: 8 hrs Night: 12 hrs | Planned - SUBMIT | | | | | Commissioning 4.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----------|-------------------------------|-------------------------------|-------------------------------------|---|----------------------------|--------------------------|------------|--------------|------------------|----------------|-------------------------|
| QLD | Powerlink | 06/09/2021 08:30 Monday | 10/09/2021 16:00 Friday | Ross No.3 288/138/19 kV Transformer | <<NEW since the last notification>> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 4 hrs Night: 6 hrs | Planned - SUBMIT | | | | | Maintenance 4.3 Days |
| VIC | AusNet | 21/09/2021 07:00 Tuesday | 21/09/2021 19:00 Tuesday | Heywood - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| VIC | AusNet | 22/09/2021 07:00 Wednesday | 22/09/2021 19:00 Wednesday | Heywood - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| VIC | AusNet | 23/09/2021 07:00 Thursday | 23/09/2021 19:00 Thursday | Heywood - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----------|-------------------------------|-------------------------------|--------------------------------------|---|-------------------------|--------------------------|------------|--------------|------------------|----------------|----------------------------|
| VIC | AusNet | 29/09/2021 07:00 Wednesday | 29/09/2021 19:00 Wednesday | Heywood - Tarrone 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| QLD | Powerlink | 18/10/2021 07:00 Monday | 30/10/2021 17:00 Saturday | Nebo - Broadsound (8847) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: NA Night: NA | Planned - SUBMIT | | | | | Commissioning 12.4 Days |
| VIC | AusNet | 19/10/2021 06:00 Tuesday | 19/10/2021 16:00 Tuesday | Keilor – Sydenham 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: <ul style="list-style-type: none"> Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 3 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 10 Hours |
| VIC | AusNet | 04/11/2021 06:00 Thursday | 04/11/2021 18:00 Thursday | Heywood - Tarrone 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| VIC | AusNet | 05/11/2021 06:00 Friday | 05/11/2021 18:00 Friday | Heywood - Tarrone 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-------------|-------------------------------|-------------------------------|---------------------------------------|---|--------------------------|--------------------------|------------|--------------|------------------|----------------|---------------------------|
| VIC | AusNet | 06/11/2021 06:00 Saturday | 06/11/2021 18:00 Saturday | Heywood - Tarrone 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 12 Hours |
| QLD | Powerlink | 08/11/2021 14:00 Monday | 08/11/2021 15:00 Monday | Ross No.2 288/138/19 kV Transformer | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 5 mins Night: NA | Planned - SUBMIT | | | | | Maintenance 60 Minutes |
| QLD | Powerlink | 09/11/2021 08:00 Tuesday | 09/11/2021 08:30 Tuesday | Ross No.3 288/138/19 kV Transformer | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 5 mins Night: NA | Planned - SUBMIT | | | | | Maintenance 30 Minutes |
| QLD | Powerlink | 10/11/2021 10:00 Wednesday | 10/11/2021 10:30 Wednesday | Ross No.4 288/138/19 kV Transformer | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 5 mins Night: NA | Planned - SUBMIT | | | | | Maintenance 30 Minutes |
| TAS | TasNetworks | 06/12/2021 07:00 Monday | 06/12/2021 15:00 Monday | Gordon - Chapel St No.1 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | ✓ | | Maintenance 8 Hours |
| QLD | Powerlink | 06/12/2021 07:00 Monday | 06/12/2021 16:00 Monday | Bouldercombe - Nebo (821) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Commissioning 9 Hours |
| TAS | TasNetworks | 07/12/2021 07:00 Tuesday | 07/12/2021 15:00 Tuesday | Gordon - Chapel St No.1 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | ✓ | | Maintenance 8 Hours |
| QLD | Powerlink | 07/12/2021 07:00 Tuesday | 07/12/2021 16:00 Tuesday | Bouldercombe - Nebo (821) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Commissioning 9 Hours |
| TAS | TasNetworks | 20/12/2021 07:00 Monday | 20/12/2021 15:00 Monday | Gordon - Chapel St No.2 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | ✓ | | Maintenance 8 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-------------|-------------------------------|-------------------------------|--|--|---------------------------|--------------------------|------------|--------------|------------------|----------------|--------------------------|
| TAS | TasNetworks | 21/12/2021 07:00 Tuesday | 21/12/2021 15:00 Tuesday | Gordon - Chapel St No.2 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | ✓ | | Maintenance 8 Hours |
| TAS | TasNetworks | 15/02/2022 08:00 Tuesday | 15/02/2022 14:00 Tuesday | Sheffield - Farrell No.1 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 1.5 hrs Night: NA | Planned - SUBMIT | | | ✓ | | Maintenance 6 Hours |
| TAS | TasNetworks | 16/02/2022 08:00 Wednesday | 16/02/2022 14:30 Wednesday | Sheffield - Farrell No.2 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 2 hrs Night: NA | Planned - SUBMIT | | | ✓ | | Maintenance 6.5 Hours |
| TAS | TasNetworks | 24/02/2022 07:00 Thursday | 24/02/2022 15:00 Thursday | Gordon - Chapel St No.1 220 kV Line | <<NEW since the last notification>> A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 1 hr Night: NA | Planned - SUBMIT | | | ✓ | | Commissioning 8 Hours |
| VIC | AusNet | 01/03/2022 06:00 Tuesday | 01/03/2022 15:00 Tuesday | Red Cliffs-Wemen 220 kV ine | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 9 Hours |
| VIC | AusNet | 01/03/2022 06:00 Tuesday | 01/03/2022 15:00 Tuesday | Buronga - Redcliffs (OX1) 220 kV Line. | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 9 Hours |
| VIC | AusNet | 02/03/2022 06:00 Wednesday | 02/03/2022 15:00 Wednesday | Red Cliffs-Wemen 220 kV ine | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 9 Hours |
| VIC | AusNet | 03/03/2022 06:00 Thursday | 03/03/2022 15:00 Thursday | Red Cliffs-Wemen 220 kV ine | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 9 Hours |
| VIC | AusNet | 09/03/2022 06:00 Wednesday | 09/03/2022 15:00 Wednesday | Buronga - Redcliffs (OX1) 220 kV Line. | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 9 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|--------|-------------------------------|-------------------------------|--|--|-------------------------|--------------------------|------------|--------------|------------------|----------------|------------------------|
| VIC | AusNet | 10/03/2022 06:00 Thursday | 10/03/2022 15:00 Thursday | Buronga - Redcliffs (OX1) 220 kV Line. | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 9 Hours |
| VIC | AusNet | 16/03/2022 06:00 Wednesday | 16/03/2022 13:00 Wednesday | Buronga - Redcliffs (OX1) 220 kV Line. | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 7 Hours |
| VIC | AusNet | 20/04/2022 07:00 Wednesday | 20/04/2022 16:00 Wednesday | Buronga - Redcliffs (OX1) 220 kV Line. | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 9 Hours |
| VIC | AusNet | 10/05/2022 07:00 Tuesday | 10/05/2022 16:00 Tuesday | Buronga - Redcliffs (OX1) 220 kV Line. | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 9 Hours |
| VIC | AusNet | 11/05/2022 07:00 Wednesday | 11/05/2022 16:00 Wednesday | Buronga - Redcliffs (OX1) 220 kV Line. | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 9 Hours |
| VIC | AusNet | 12/05/2022 07:00 Thursday | 12/05/2022 16:00 Thursday | Buronga - Redcliffs (OX1) 220 kV Line. | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 9 Hours |
| VIC | AusNet | 13/05/2022 07:00 Friday | 13/05/2022 16:00 Friday | Buronga - Redcliffs (OX1) 220 kV Line. | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 9 Hours |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|------------|-----------------------------|-------------------------------|---|--|--------------------------------|--------------------------|------------|--------------|------------------|----------------|----------------------------|
| VIC | AusNet | 17/05/2022 07:00 Tuesday | 17/05/2022 16:00 Tuesday | Buronga - Redcliffs (OX1) 220 kV Line. | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 9 Hours |
| QLD | Powerlink | 24/05/2022 07:00 Tuesday | 03/06/2022 17:00 Friday | Bouldercombe - Broadsound (820) 275 kV Line | <<NEW since the last notification>> This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 120 hrs Night: 120 hrs | Planned - SUBMIT | | | | | Commissioning 10.4 Days |
| VIC | AusNet | 31/05/2022 07:00 Tuesday | 31/05/2022 16:00 Tuesday | Buronga - Redcliffs (OX1) 220 kV Line. | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs Night: NA | Planned - SUBMIT | | | | | Maintenance 9 Hours |
| SA | ElectraNet | 06/06/2022 12:30 Monday | 08/06/2022 17:30 Wednesday | Tailem Bend - South East No.2 275 kV Line | <<NEW since the last notification>> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: <ul style="list-style-type: none"> • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. <p>During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</p> | Day: 159 hrs Night: 159 hrs | Planned - SUBMIT | | | | | Commissioning 2.2 Days |
| SA | ElectraNet | 20/06/2022 08:15 Monday | 25/06/2022 08:15 Saturday | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: <ul style="list-style-type: none"> • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. <p>During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</p> | Day: 159 hrs Night: 159 hrs | Planned - SUBMIT | | | | | Commissioning 5 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|------------|------------------------------|-------------------------------|---|---|--------------------------------|--------------------------|------------|--------------|------------------|----------------|----------------------------|
| SA | ElectraNet | 25/06/2022 08:15 Saturday | 27/06/2022 12:30 Monday | Tailem Bend - South East No.1 275 kV Line | <p>A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:</p> <ul style="list-style-type: none"> • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. <p>During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</p> | Day: 159 hrs Night: 159 hrs | Planned - SUBMIT | | | | | Commissioning 2.2 Days |
| SA | ElectraNet | 27/06/2022 12:30 Monday | 29/06/2022 17:30 Wednesday | Tailem Bend - South East No.1 275 kV Line | <p>A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:</p> <ul style="list-style-type: none"> • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. <p>During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</p> | Day: 159 hrs Night: 159 hrs | Planned - SUBMIT | | | | | Commissioning 2.2 Days |
| QLD | Powerlink | 02/08/2022 07:00 Tuesday | 22/08/2022 17:00 Monday | Nebo - Strathmore (8845) 275 kV Line | <p>This is a high impact outage because the recall time is greater than 30 minutes.</p> <p>A credible contingency event during this planned outage may require market intervention through issuing of directions.</p> | Day: NA Night: NA | Planned - SUBMIT | | | | | Commissioning 20.4 Days |
| QLD | Powerlink | 29/08/2022 07:00 Monday | 16/09/2022 17:00 Friday | Nebo - Strathmore (878) 275 kV Line | <p>This is a high impact outage because the recall time is greater than 30 minutes.</p> <p>A credible contingency event during this planned outage may require market intervention through issuing of directions.</p> | Day: NA Night: NA | Planned - SUBMIT | | | | | Commissioning 18.4 Days |
| QLD | Powerlink | 13/09/2022 07:00 Tuesday | 23/09/2022 17:00 Friday | Bouldercombe - Broadsound (820) 275 kV Line | <p><<NEW since the last notification>></p> <p>This is a high impact outage because the recall time is greater than 30 minutes.</p> <p>A credible contingency event during this planned outage may require market intervention through issuing of directions.</p> | Day: 120 hrs Night: 120 hrs | Planned - SUBMIT | | | | | Commissioning 10.4 Days |
| QLD | Powerlink | 17/10/2022 07:00 Monday | 03/11/2022 17:00 Thursday | Nebo - Strathmore (8845) 275 kV Line | <p>This is a high impact outage because the recall time is greater than 30 minutes.</p> <p>A credible contingency event during this planned outage may require market intervention through issuing of directions.</p> | Day: 24 hrs Night: 48 hrs | Planned - SUBMIT | | | | | Commissioning 17.4 Days |

| Region | NSP | Start | Finish | Network Asset | Impact | Recall | Status and Market Notice | Unplanned? | DNISP Aware? | Generator Aware? | Inter-Regional | Reason and Duration |
|--------|-----|-------|--------|---------------|--------|--------|--------------------------|------------|--------------|------------------|----------------|---------------------|
|--------|-----|-------|--------|---------------|--------|--------|--------------------------|------------|--------------|------------------|----------------|---------------------|

The following fields of data are submitted by NSPs to AEMO.

- ✓ **Unplanned** - Outage is forced outage, trip or submitted with short notice.
- ✓ **DNISP(s) Aware** - The TNSP that submitted the outage confirms they have notified DNISP(s) that are impacted by this outage and made aware of the risks of next contingency.
- ✓ **Generator(s) Aware** - The TNSP that submitted the outage confirms they have notified generator(s) that are directly impacted by this outage and made aware of potential risks of next credible contingency.
- ✓ **Inter-Regional** - The TNSP that submitted the outage confirms they have notified other TNSP(s) that may be impacted by this outage, often in the neighbouring region.

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies. AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- * make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- * are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.