| | NSW Transgrid 21/05/2024 07:00 | | Finish Network Asset | | Impact | Legend Withdrawn / Newly Adde Re Update(s) sin Withdrawn s | | | st no | otifica | notification oct Region, ation ason and ation |
|-----|--------------------------------|-------------------------------|------------------------------|--|---|---|--------------------|---|-------|-------------|--|
| NSW | Transgrid | 21/05/2024 07:00 Tuesday | 25/05/2024 17:00 Saturday | Liddell to Muswellbrook (83) 330 kV Line | < <this been="" has="" outage="" withdrawn!="">> A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM</this> | Day: 4 hrs- Night: 4 hrs | Withdrawn | | | | NSW / QLD Commissioning 4.4 Days |
| QLD | Powerlink | 22/05/2024 07:00 Wednesday | 23/05/2024 16:00 Thursday | Strathmore - Ross (8857) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - MTLTP | × | | | QLD Commissioning 1.4 Days |
| TAS | TasNetworks | 28/05/2024 08:00 Tuesday | 31/05/2024 14:00 Friday | Sheffield - Farrell No.2 220 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.</new> | Day: 24 hrs- Night: 24 hrs | Planned - RESUBMIT | | X | | TAS Commissioning 3.3 Days |
| TAS | TasNetworks | 01/06/2024 08:00 Saturday | 01/06/2024 14:30 Saturday | Sheffield - Farrell No.2 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 2 hrs- Night: NA | Planned - MTLTP | | X | | Commissioning 6.5 Hours |
| NSW | Transgrid | 03/06/2024 07:00 Monday | 03/06/2024 18:00 Monday | Tamworth No.3 330 kV Bus | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 8 hrs- Night: 8 hrs | Planned - MTLTP | Þ | | \boxtimes | NSW / QLD Commissioning 11 Hours |
| VIC | AusNet | 04/06/2024 06:00 Tuesday | 04/06/2024 18:00 Tuesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 4 hrs- Night: NA | Planned - RESUBMIT | | | X | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 04/06/2024 06:00 Tuesday | 04/06/2024 18:00 Tuesday | Heywood - Mortlake 500 kV Line | < <this been="" has="" outage="" withdrawn!="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</this> | Day: 2 hrs- Night: NA | Withdrawn | | | | VIC / SA Maintenance 12 Hours |

| | | | Finish | Network Asset | Impact | Legen Re | Nd Withdrawn / UT Newly Added C Update(s) since Withdrawn since | utage the la | st no | tifica | act Region, Ition ason and |
|-----|-----------|-------------------------------|-------------------------------|--|---|-----------------------------|--|-----------------|-------------|-------------|-------------------------------------|
| VIC | AusNet | 05/06/2024 06:00 Wednesday | 05/06/2024 18:00 Wednesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | × | \boxtimes | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 05/06/2024 07:00 Wednesday | 05/06/2024 16:00 Wednesday | Hazelwood - Rowville 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | | VIC Maintenance 9 Hours |
| QLD | Powerlink | 05/06/2024 10:00 Wednesday | 07/06/2024 16:00 Friday | Bouldercombe - Broadsound (820) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 2 hrs- Night: 3 hrs | Planned - SUBMIT | | | | QLD Commissioning 2.3 Days |
| VIC | AusNet | 06/06/2024 06:00 Thursday | 06/06/2024 18:00 Thursday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | \boxtimes | X | VIC / SA Maintenance 12 Hours |

| | | | Finish Network Asset | | Impact | | d Withdrawn / UT Newly Added O Update(s) since Withdrawn sinc | utage the las | st no | tificat | ict Region, tion ason and |
|-----|-------------|------------------------------|------------------------------|-------------------------------------|---|------------------------------|--|------------------|-------|---------|-------------------------------------|
| SA | ElectraNet | 06/06/2024 07:30 Thursday | 09/06/2024 17:30 Sunday | | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | X | SA Maintenance 3.4 Days |
| TAS | TasNetworks | 06/06/2024 10:30 Thursday | 06/06/2024 15:00 Thursday | Gordon - Chanel St No 1 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 2 hrs- Night: NA | Planned - MTLTP | | X | | Maintenance 4.5 Hours |
| VIC | AusNet | 07/06/2024 06:00 Friday | 07/06/2024 18:00 Friday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | × | × | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 08/06/2024 06:00 Saturday | 08/06/2024 18:00 Saturday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | X | X | VIC / SA Maintenance 12 Hours |

| | | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / U Newly Added C Update(s) since Withdrawn sinc | outage the la | st no | otifica | act Region, ation ason and |
|-----|-----------|-----------------------------|------------------------------|-------------------------------------|---|-----------------------------|---|------------------|-------|---------|--|
| VIC | AusNet | 09/06/2024 06:00 Sunday | 09/06/2024 18:00 Sunday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | X | X | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 10/06/2024 06:00 Monday | 10/06/2024 18:00 Monday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | X | X | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 10/06/2024 07:00 Monday | 10/06/2024 17:00 Monday | Moorabool–Sydenham No.2 500 kV Line | < <this been="" has="" outage="" withdrawn!="">> A credible contingency event during this planned outage may require market intervention through issuing of directions</this> | Day: 1 hr- Night: NA | Withdrawn | | | | VIC Maintenance 10 Hours |
| VIC | AusNet | 11/06/2024 06:00 Tuesday | 11/06/2024 18:00 Tuesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | × | X | VIC / SA Maintenance 12 Hours |
| NSW | Transgrid | 11/06/2024 07:00 Tuesday | 13/06/2024 18:00 Thursday | Tamworth No.3 330 kV Bus | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM | Day: 8 hrs- Night: 8 hrs | Planned - MTLTP | | | | NSW / QLD Commissioning 2.5 Days |

| | | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / UT Newly Added C Update(s) since Withdrawn since | Outage the l | e ast no | otifica | act Region, Ition ason and |
|-----|------------|-------------------------------|-------------------------------|---|--|------------------------------|---|-----------------|-------------|---------|-------------------------------------|
| SA | ElectraNet | 11/06/2024 07:30 Tuesday | 17/06/2024 07:30 Monday | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - MTLTP | | | X | SA Maintenance 6 Days |
| VIC | AusNet | 12/06/2024 06:00 Wednesday | 12/06/2024 18:00 Wednesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | X | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 12/06/2024 07:00 Wednesday | 12/06/2024 18:00 Wednesday | Jindera - Wodonga (060) 330 kV Line | < <this been="" has="" outage="" withdrawn!="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</this> | Day: 4 hrs- Night: NA | Withdrawn | | | | NSW/ VIC Maintenance 11 Hours |
| VIC | AusNet | 13/06/2024 06:00 Thursday | 13/06/2024 18:00 Thursday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | X | | VIC / SA Maintenance 12 Hours |

| C | | | Finish | Network Asset | Impact | Leger Re | d Withdrawn / U Newly Added C Update(s) since Withdrawn since |)utage the la | st no | otifica | ict Region, ition ason and |
|-----|--------|------------------------------|------------------------------|-------------------------------------|--|--------------------------|--|------------------|-------|---------|-------------------------------------|
| VIC | AusNet | 13/06/2024 07:00 Thursday | 13/06/2024 17:00 Thursday | Jindera - Wodonga (060) 330 kV Line | < <this been="" has="" outage="" withdrawn!="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</this> | Day: 4 hrs- Night: NA | Withdrawn | | | | NSW/ VIC Maintenance 10 Hours |
| VIC | AusNet | 14/06/2024 06:00 Friday | 14/06/2024 18:00 Friday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | X | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 14/06/2024 07:00 Friday | 14/06/2024 17:00 Friday | Jindera - Wodonga (060) 330 kV Line | < <this been="" has="" outage="" withdrawn!="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</this> | Day: 4 hrs- Night: NA | Withdrawn | | | | NSW/ VIC Maintenance 10 Hours |
| VIC | AusNet | 15/06/2024 06:00 Saturday | 15/06/2024 18:00 Saturday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | X | | VIC / SA Maintenance 12 Hours |

| | | | Finish | Network Asset | Impact | Leger Re | nd Withdrawn / U Newly Added O Update(s) since Withdrawn since | Outage the la | ast no | otifica | ict Region, tion ason and |
|-----|--------|------------------------------|------------------------------|-------------------------------------|--|--------------------------|---|------------------|--------|---------|-------------------------------------|
| VIC | AusNet | 15/06/2024 06:00 Saturday | 15/06/2024 18:00 Saturday | Jindera - Wodonga (060) 330 kV Line | < <this been="" has="" outage="" withdrawn!="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</this> | Day: 4 hrs- Night: NA | Withdrawn | | | | NSW/ VIC Maintenance 12 Hours |
| VIC | AusNet | 16/06/2024 06:00 Sunday | 16/06/2024 18:00 Sunday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | X | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 16/06/2024 06:00 Sunday | 16/06/2024 18:00 Sunday | Jindera - Wodonga (060) 330 kV Line | < <this been="" has="" outage="" withdrawn!="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</this> | Day: 4 hrs- Night: NA | Withdrawn | | | | NSW/ VIC Maintenance 12 Hours |
| VIC | AusNet | 17/06/2024 06:00 Monday | 17/06/2024 18:00 Monday | Moorabool - Mortlake 500 kV Line | < <this been="" has="" outage="" withdrawn!="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</this> | Day: 4 hrs- Night: NA | Withdrawn | | × | X | VIC / SA Maintenance 12 Hours |

| | ALISTRALIAN ENERGY MARKET OPERATOR | | | Finish Network Asset Impact < < < < | | Legend Withdrawn / UTP since the last notification Newly Added Outage ct Region Re Update(s) since the last notification Withdrawn since the last notification Uration | | | | | | |
|----|------------------------------------|------------|-----------------------------|---|--|--|------------------------------|------------------|--|---|-------------|-------------------------------------|
| VI | С | AusNet | 18/06/2024 06:00 Tuesday | 18/06/2024 18:00 Tuesday | Moorabool - Mortlake 500 kV Line | < <this been="" has="" outage="" withdrawn!="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</this> | Day: 4 hrs- Night: NA | Withdrawn | | X | \boxtimes | VIC / SA Maintenance 12 Hours |
| VI | с | AusNet | 18/06/2024 07:00 Tuesday | 18/06/2024 17:00 Tuesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 10 Hours |
| SA | Å | ElectraNet | 18/06/2024 07:30 Tuesday | 24/06/2024 17:30 Monday | Tailem Bend - Tungkillo No.2 275 kV Line | < <new last="" notification="" since="" the="">> A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).</new> | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | \boxtimes | SA Maintenance 6.4 Days |

| | | AUST | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / UT Newly Added C Update(s) since Withdrawn sinc | utage the la | ist no | otifica notifca | ict Region, ition ason and |
|---|----|------------|-------------------------------|-------------------------------|--|---|-------------------------------|--|-----------------|--------|--------------------|-------------------------------------|
| S | 5A | ElectraNet | 18/06/2024 09:00 Tuesday | 20/06/2024 16:30 Thursday | Tailem Bend - Tungkillo No.2 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 48 hrs- Night: 48 hrs | Planned - SUBMIT | | | | SA Maintenance 2.3 Days |
| v | ЛС | AusNet | 19/06/2024 06:00 Wednesday | 19/06/2024 18:00 Wednesday | Moorabool - Mortlake 500 kV Line | < <this been="" has="" outage="" withdrawn!="">> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.</this> | Day: 4 hrs- Night: NA | Withdrawn | | | | VIC / SA Maintenance 12 Hours |
| v | ИC | AusNet | 19/06/2024 07:30 Wednesday | 19/06/2024 16:30 Wednesday | Jindera - Wodonga (060) 330 kV Line | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</new> | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | | NSW/ VIC Maintenance 9 Hours |
| V | лс | AusNet | 20/06/2024 07:30 Thursday | 20/06/2024 16:30 Thursday | Jindera - Wodonga (060) 330 kV Line | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</new> | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | | NSW/ VIC Maintenance 9 Hours |

| | | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / UT Newly Added O Update(s) since Withdrawn sinc | utage the last i e the last | notific | ation ason and |
|-----|------------|------------------------------|------------------------------|--|---|-------------------------------|--|-----------------------------------|---------|-------------------------------------|
| SA | ElectraNet | 20/06/2024 16:30 Thursday | 22/06/2024 16:30 Saturday | Tailem Bend - Tungkillo No.2 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 48 hrs- Night: 48 hrs | Planned - SUBMIT | | | SA Maintenance 2 Days |
| VIC | AusNet | 21/06/2024 07:30 Friday | 21/06/2024 16:30 Friday | Jindera - Wodonga (060) 330 kV Line | < <new last="" notification="" since="" the="">> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.</new> | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | NSW/ VIC Maintenance 9 Hours |
| VIC | AusNet | 25/06/2024 07:00 Tuesday | 25/06/2024 18:00 Tuesday | Jindera - Wodonga (060) 330 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | NSW/ VIC Maintenance 11 Hours |
| QLD | Powerlink | 25/06/2024 08:00 Tuesday | 27/06/2024 16:00 Thursday | Nebo - Strathmore (822) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 2 hrs- Night: 6 hrs | Planned - RESUBMIT | | | QLD Commissioning 2.3 Days |

| 6 | | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / U Newly Added C Update(s) since Withdrawn since | utage the las | st not | ificat | ict Region, |
|-----|------------|-------------------------------|-------------------------------|---|--|-------------------------------|--|------------------|--------|--------|-------------------------------------|
| VIC | AusNet | 26/06/2024 07:00 Wednesday | 26/06/2024 17:00 Wednesday | Jindera - Wodonga (060) 330 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | | NSW/ VIC Maintenance 10 Hours |
| VIC | AusNet | 27/06/2024 07:00 Thursday | 27/06/2024 17:00 Thursday | Jindera - Wodonga (060) 330 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | | NSW/ VIC Maintenance 10 Hours |
| SA | ElectraNet | 29/06/2024 08:30 Saturday | 29/06/2024 17:30 Saturday | Tailem Bend - Tungkillo No.2 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 48 hrs- Night: 48 hrs | Planned - SUBMIT | | | | SA Maintenance 9 Hours |
| SA | ElectraNet | 30/06/2024 07:30 Sunday | 05/07/2024 17:30 Friday | Tailem Bend - South East No.2 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | × | SA Maintenance 5.4 Days |

| | | | Finish | Network Asset | Impact | Re Update(s) Withdraw | | | / UTP since the last notification ed Outage ct Region, ince the last notification ason and since the last notification uration | | | | |
|-----|--------|-------------------------------|-------------------------------|---------------------------------------|---|--------------------------|------------------|--|---|-------------------------------------|--|--|--|
| VIC | AusNet | 01/07/2024 06:00 Monday | 01/07/2024 21:00 Monday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 15 Hours | | | |
| VIC | AusNet | 02/07/2024 06:00 Tuesday | 02/07/2024 18:00 Tuesday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 12 Hours | | | |
| VIC | AusNet | 02/07/2024 06:00 Tuesday | 02/07/2024 18:00 Tuesday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 12 Hours | | | |
| VIC | AusNet | 03/07/2024 07:00 Wednesday | 03/07/2024 17:00 Wednesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 10 Hours | | | |

| | AUST | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / UT Newly Added O Update(s) since Withdrawn sinc | utage the la | st no | tifica otifca | ict Region, tion ason and |
|-----|------------|------------------------------|-------------------------------|---------------------------------------|---|------------------------------|--|-----------------|-------|------------------|-------------------------------------|
| VIC | AusNet | 05/07/2024 06:00 Friday | 05/07/2024 21:00 Friday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 15 Hours |
| VIC | AusNet | 05/07/2024 07:00 Friday | 05/07/2024 16:00 Friday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | | VIC Maintenance 9 Hours |
| SA | ElectraNet | 06/07/2024 07:30 Saturday | 07/07/2024 19:30 Sunday | Heywood - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | \boxtimes | VIC / SA Maintenance 1.5 Days |
| SA | ElectraNet | 08/07/2024 07:30 Monday | 10/07/2024 17:30 Wednesday | Heywood - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | VIC / SA Maintenance 2.4 Days |
| VIC | ΤΟΑ | 09/07/2024 06:00 Tuesday | 09/07/2024 18:00 Tuesday | Ararat - Crowlands 220kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 1 hr- Night: NA | Planned - SUBMIT | | X | X | VIC Maintenance 12 Hours |

| | | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / UT Newly Added O Update(s) since Withdrawn sinc | utage the la | st no | tifica otifca | ict Region, tion ason and |
|-----|-----------|-------------------------------|-------------------------------|--|---|----------------------------|--|-----------------|-------|------------------|-------------------------------------|
| VIC | AusNet | 09/07/2024 07:00 Tuesday | 09/07/2024 17:00 Tuesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 10 Hours |
| VIC | AusNet | 10/07/2024 06:00 Wednesday | 10/07/2024 18:00 Wednesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 10/07/2024 06:00 Wednesday | 10/07/2024 18:00 Wednesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | ТОА | 10/07/2024 06:00 Wednesday | 10/07/2024 18:00 Wednesday | Ararat - Waubra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: NA-Night: NA | Planned - SUBMIT | | × | \boxtimes | Commissioning 12 Hours |
| QLD | Powerlink | 10/07/2024 09:00 Wednesday | 10/07/2024 17:00 Wednesday | Bouldercombe - Broadsound (820) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 30 mins- Night: NA | Planned - SUBMIT | | | | QLD Maintenance 8 Hours |

| | | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / U Newly Added C Update(s) since Withdrawn since | utage the l | e ast n | otifica notifc | act Region, |
|-----|------------|------------------------------|------------------------------|--|---|------------------------------|--|----------------|------------|-------------------|-------------------------------------|
| QLD | Powerlink | 11/07/2024 07:00 Thursday | 11/07/2024 15:00 Thursday | Bouldercombe - Broadsound (820) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 30 mins- Night: NA | Planned - SUBMIT | | | | QLD Maintenance 8 Hours |
| VIC | AusNet | 18/07/2024 06:00 Thursday | 18/07/2024 18:00 Thursday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 19/07/2024 06:00 Friday | 19/07/2024 18:00 Friday | Moorabool - Haunted Gully 500 kV line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | | VIC / SA Maintenance 12 Hours |
| SA | ElectraNet | 25/07/2024 07:30 Thursday | 03/08/2024 17:30 Saturday | Tailem Bend - Tungkillo No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | × | SA Maintenance 9.4 Days |

| | | | Finish | Network Asset | Impact | Legen Re | Newly Added O | utage the las | t notif | ict Region, fication ason and |
|-----|------------|-------------------------------|------------------------------|---------------------------------------|---|------------------------------|------------------|------------------|---------|-------------------------------------|
| SA | ElectraNet | 26/07/2024 07:45 Friday | 27/07/2024 17:30 Saturday | Heywood - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 5 hrs- Night: 12 hrs | Planned - SUBMIT | | | VIC / SA Maintenance 1.4 Days |
| VIC | AusNet | 29/07/2024 06:00 Monday | 29/07/2024 18:00 Monday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 30/07/2024 06:00 Tuesday | 30/07/2024 18:00 Tuesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 12 Hours |
| SA | ElectraNet | 31/07/2024 07:45 Wednesday | 01/08/2024 17:30 Thursday | Heywood - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 5 hrs- Night: 12 hrs | Planned - SUBMIT | | | VIC / SA Maintenance 1.4 Days |

| | | | Finish | Network Asset | Impact | Re | Newly Added O | utage the last not | ict Region, tification ason and otifcation |
|-----|------------|------------------------------|-------------------------------|--|---|------------------------------|------------------|-----------------------|--|
| VIC | AusNet | 03/08/2024 06:00 Saturday | 03/08/2024 18:00 Saturday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC Commissioning 12 Hours |
| SA | ElectraNet | 03/08/2024 07:45 Saturday | 04/08/2024 17:30 Sunday | Heywood - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 5 hrs- Night: 12 hrs | Planned - SUBMIT | | VIC / SA Maintenance 1.4 Days |
| VIC | AusNet | 05/08/2024 06:00 Monday | 05/08/2024 18:00 Monday | Kerang-Wemen 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 5 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours |
| VIC | AusNet | 05/08/2024 06:00 Monday | 07/08/2024 18:00 Wednesday | Kerang-Wemen 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. | Day: 5 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 2.5 Days |
| SA | ElectraNet | 05/08/2024 07:30 Monday | 11/08/2024 17:30 Sunday | Tailem Bend - Tungkillo No.2 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | SA Maintenance 6.4 Days |

| | | | Finish | Network Asset | Impact | Re | Newly Added O | utage the la | ist noti | ict Region, fication ason and |
|-----|-----------|-------------------------------|-------------------------------|------------------------------------|--|---------------------------|------------------|-----------------|----------|----------------------------------|
| VIC | AusNet | 06/08/2024 06:00 Tuesday | 06/08/2024 18:00 Tuesday | Kerang-Wemen 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 5 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 12 Hours |
| QLD | Powerlink | 06/08/2024 12:05 Tuesday | 06/08/2024 15:00 Tuesday | Haughton River No. 2 275kV BUS | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 1 hr- Night: NA | Planned - SUBMIT | | X | QLD Maintenance 2.9 Hours |
| VIC | AusNet | 07/08/2024 06:00 Wednesday | 07/08/2024 18:00 Wednesday | Kerang-Wemen 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. | Day: 5 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 12 Hours |
| VIC | AusNet | 19/08/2024 07:00 Monday | 19/08/2024 17:00 Monday | Kiamal SF - MurraWarra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours |
| VIC | AusNet | 19/08/2024 07:00 Monday | 19/08/2024 17:00 Monday | Kiamal SF - MurraWarra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours |
| VIC | AusNet | 20/08/2024 06:00 Tuesday | 20/08/2024 18:00 Tuesday | Kerang-Wemen 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 12 Hours |
| VIC | AusNet | 21/08/2024 07:00 Wednesday | 21/08/2024 17:00 Wednesday | Horsham - MurraWarra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours |

| | | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / UT Newly Added O Update(s) since Withdrawn sinc | utage the last notifi | act Region, cation ason and |
|-----|--------|-------------------------------|-------------------------------|-------------------------------------|--|---------------------------|--|--------------------------|-------------------------------------|
| VIC | AusNet | 21/08/2024 07:00 Wednesday | 21/08/2024 17:00 Wednesday | Horsham - MurraWarra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours |
| VIC | AusNet | 22/08/2024 07:00 Thursday | 22/08/2024 18:00 Thursday | Moorabool–Sydenham No.1 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 60 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 11 Hours |
| VIC | AusNet | 23/08/2024 07:00 Friday | 23/08/2024 18:00 Friday | Moorabool–Sydenham No.1 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 60 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 11 Hours |
| VIC | AusNet | 24/08/2024 07:00 Saturday | 24/08/2024 17:00 Saturday | Haunted Gully - Tarrone 500 Kv line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC / SA Maintenance 10 Hours |
| VIC | AusNet | 25/08/2024 06:00 Sunday | 25/08/2024 18:00 Sunday | Haunted Gully - Tarrone 500 Kv line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC / SA Maintenance 12 Hours |
| VIC | AusNet | 25/08/2024 07:00 Sunday | 25/08/2024 19:00 Sunday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours |

| | | | Finish | Network Asset | Impact | Legen Re | Newly Added O | utage the last no | ict Region, tification ason and otifcation ^{uration} |
|-----|-----------|-----------------------------|------------------------------|--------------------------------------|---|---------------------------|------------------|----------------------|---|
| VIC | AusNet | 26/08/2024 07:00 Monday | 26/08/2024 17:00 Monday | Haunted Gully - Tarrone 500 Kv line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC / SA Maintenance 10 Hours |
| VIC | AusNet | 26/08/2024 07:00 Monday | 26/08/2024 19:00 Monday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours |
| VIC | AusNet | 27/08/2024 07:00 Tuesday | 27/08/2024 17:00 Tuesday | Haunted Gully - Tarrone 500 Kv line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC / SA Maintenance 10 Hours |
| VIC | AusNet | 27/08/2024 07:00 Tuesday | 27/08/2024 19:00 Tuesday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours |
| QLD | Powerlink | 27/08/2024 08:00 Tuesday | 31/08/2024 16:00 Saturday | Strathmore - Ross (8857) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 48 hrs- Night: NA | Planned - SUBMIT | | QLD Commissioning 4.3 Days |

| | | | Finish | Network Asset | Impact | Leger Re | Newly Added O | utage the last no | |
|-----|--------|-------------------------------|-------------------------------|-------------------------------------|---|--------------------------|------------------|----------------------|-------------------------------------|
| VIC | AusNet | 28/08/2024 07:00 Wednesday | 28/08/2024 17:00 Wednesday | Haunted Gully - Tarrone 500 Kv line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC / SA Maintenance 10 Hours |
| VIC | AusNet | 28/08/2024 07:00 Wednesday | 28/08/2024 19:00 Wednesday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours |
| VIC | AusNet | 29/08/2024 07:00 Thursday | 29/08/2024 17:00 Thursday | Haunted Gully - Tarrone 500 Kv line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC / SA Maintenance 10 Hours |
| VIC | AusNet | 29/08/2024 07:00 Thursday | 29/08/2024 19:00 Thursday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours |
| VIC | AusNet | 30/08/2024 07:00 Friday | 30/08/2024 17:00 Friday | Haunted Gully - Tarrone 500 Kv line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC / SA Maintenance 10 Hours |

| | AUST | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / UT Newly Added O Update(s) since Withdrawn sinc | utage the last r e the last | otifica | ict Region, ition ason and ation ^{uration} |
|-----|--------|------------------------------|------------------------------|-------------------------------------|---|---------------------------|--|-----------------------------------|---------|---|
| VIC | AusNet | 31/08/2024 07:00 Saturday | 31/08/2024 18:00 Saturday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 11 Hours |
| VIC | AusNet | 31/08/2024 07:00 Saturday | 31/08/2024 17:00 Saturday | Haunted Gully - Tarrone 500 Kv line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 10 Hours |
| VIC | AusNet | 01/09/2024 07:00 Sunday | 01/09/2024 18:00 Sunday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 11 Hours |
| VIC | AusNet | 01/09/2024 07:00 Sunday | 01/09/2024 17:00 Sunday | Haunted Gully - Tarrone 500 Kv line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 10 Hours |
| VIC | AusNet | 02/09/2024 07:00 Monday | 02/09/2024 17:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours |
| VIC | AusNet | 02/09/2024 07:00 Monday | 02/09/2024 17:00 Monday | Haunted Gully - Tarrone 500 Kv line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 10 Hours |

| 6 | | | Finish | Network Asset | Impact | Leger Re | nd Withdrawn / UT Newly Added O Update(s) since Withdrawn sinc | utage the la | ist no | otifica notifc | act Region, ation ason and |
|-----|-----------|------------------------------|------------------------------|--|---|---------------------------|---|-----------------|--------|-------------------|--|
| VIC | AusNet | 03/09/2024 07:00 Tuesday | 03/09/2024 19:00 Tuesday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - SUBMIT | | | | VIC Maintenance 12 Hours |
| VIC | AusNet | 03/09/2024 07:00 Tuesday | 03/09/2024 19:00 Tuesday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - SUBMIT | | | | VIC Maintenance 12 Hours |
| QLD | Powerlink | 05/09/2024 07:30 Thursday | 05/09/2024 17:00 Thursday | Nebo - Strathmore (8845) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | | QLD Maintenance 9.5 Hours |
| NSW | Transgrid | 09/09/2024 05:30 Monday | 09/09/2024 22:00 Monday | Balranald - Darlington Point (X5) 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C During this planned outage power transfer will be restricted Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. | Day: 12 hrs- Night: NA | Planned - SUBMIT | | X | | NSW / VIC Commissioning 16.5 Hours |
| VIC | AusNet | 09/09/2024 07:00 Monday | 09/09/2024 17:00 Monday | Hazelwood - South Morang No.2 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs- Night: NA | Planned - RESUBMIT | | | | VIC Maintenance 10 Hours |
| VIC | AusNet | 09/09/2024 07:00 Monday | 09/09/2024 17:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | | VIC Maintenance 10 Hours |
| VIC | AusNet | 10/09/2024 07:00 Tuesday | 12/09/2024 18:00 Thursday | South Morang - Sydenham No.1 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | | VIC Maintenance 2.5 Days |

| | | | Finish | Network Asset | Impact | Leger Re | Newly Added O | utage the las | st notif | ict Region, fication ason and |
|-----|-------------|-------------------------------|-------------------------------|--|---|---------------------------|--------------------|------------------|-------------|----------------------------------|
| VIC | AusNet | 10/09/2024 07:00 Tuesday | 10/09/2024 17:00 Tuesday | Hazelwood - South Morang No.2 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours |
| VIC | AusNet | 11/09/2024 07:30 Wednesday | 11/09/2024 17:00 Wednesday | Hazelwood - South Morang No.1 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 9.5 Hours |
| VIC | AusNet | 12/09/2024 07:30 Thursday | 12/09/2024 17:00 Thursday | Hazelwood - South Morang No.1 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 9.5 Hours |
| VIC | AusNet | 16/09/2024 07:00 Monday | 16/09/2024 17:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours |
| TAS | TasNetworks | 17/09/2024 14:00 Tuesday | 17/09/2024 16:30 Tuesday | Gordon - Chapel St No.1 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 1 hr- Night: NA | Planned - RESUBMIT | | \boxtimes | TAS Maintenance 2.5 Hours |
| VIC | AusNet | 23/09/2024 07:00 Monday | 23/09/2024 17:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours |
| VIC | AusNet | 24/09/2024 07:00 Tuesday | 26/09/2024 18:00 Thursday | South Morang - Sydenham No.2 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 24 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 2.5 Days |

| | | | Finish | Network Asset | Impact | Leger Re | utage | | |
|-----|-----------|------------------------------|------------------------------|---|--|----------------------------|--------------------|--|---|
| NSW | Transgrid | 30/09/2024 05:30 Monday | 30/09/2024 22:00 Monday | Jindera - Wagga (62) 330 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 12 hrs- Night: NA | Planned - SUBMIT | | NSW/ VIC Commissioning 16.5 Hours |
| VIC | AusNet | 30/09/2024 07:00 Monday | 30/09/2024 17:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours |
| VIC | AusNet | 07/10/2024 06:00 Monday | 07/10/2024 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours |
| VIC | AusNet | 12/10/2024 06:00 Saturday | 12/10/2024 16:00 Saturday | Ararat - Crowlands 220kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - RESUBMIT | | VIC Maintenance 10 Hours |
| VIC | AusNet | 14/10/2024 06:00 Monday | 14/10/2024 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours |
| VIC | AusNet | 15/10/2024 06:00 Tuesday | 20/10/2024 17:00 Sunday | South Morang - Sydenham No.1 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 120 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 5.5 Days |
| VIC | AusNet | 21/10/2024 06:00 Monday | 21/10/2024 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours |
| VIC | AusNet | 25/10/2024 06:00 Friday | 25/10/2024 18:00 Friday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours |

| | | | | | | Legend Withdrawn / UTP since the last notification Newly Added Outage ict Reg Re Update(s) since the last notification Withdrawn since the last notification uration Utter G | | | | | |
|-----|-------------|-------------------------------|-------------------------------|--|--|--|--------------------|-------------|-----------------------------------|--|--|
| VIC | AusNet | 26/10/2024 06:00 Saturday | 26/10/2024 18:00 Saturday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours | | |
| VIC | AusNet | 27/10/2024 06:00 Sunday | 27/10/2024 18:00 Sunday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours | | |
| TAS | TasNetworks | 28/10/2024 05:00 Monday | 01/11/2024 20:00 Friday | George Town - George Town Converter Station 220 kV Line | Tasmania will be separated from the NEM | Day: 4 hrs- Night: 6 hrs | Planned - SUBMIT | \boxtimes | TAS Maintenance 4.6 Days | | |
| VIC | AusNet | 28/10/2024 06:00 Monday | 28/10/2024 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 28/10/2024 06:00 Monday | 28/10/2024 18:00 Monday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours | | |
| VIC | AusNet | 29/10/2024 06:00 Tuesday | 29/10/2024 18:00 Tuesday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours | | |
| TAS | TasNetworks | 30/10/2024 13:00 Wednesday | 30/10/2024 15:30 Wednesday | Gordon - Chapel St No.2 220 kV Line | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania. | Day: 1 hr- Night: NA | Planned - RESUBMIT | | TAS Commissioning 2.5 Hours | | |
| VIC | AusNet | 31/10/2024 05:00 Thursday | 31/10/2024 17:00 Thursday | Kerang-Wemen 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours | | |
| VIC | AusNet | 01/11/2024 06:00 Friday | 01/11/2024 16:00 Friday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 04/11/2024 06:00 Monday | 04/11/2024 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |

| | | | Finish Network Asset | | Impact | Newly Added Outage | | | | last notification ason and | | |
|-----|-----------|------------------------------|-------------------------------|--------------------------------------|--|-------------------------------|--------------------|---|---|----------------------------------|--|--|
| VIC | AusNet | 09/11/2024 06:00 Saturday | 09/11/2024 16:00 Saturday | Kiamal SF - MurraWarra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 11/11/2024 06:00 Monday | 11/11/2024 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 12/11/2024 06:00 Tuesday | 12/11/2024 16:00 Tuesday | Ararat - Crowlands 220kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 18/11/2024 06:00 Monday | 18/11/2024 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 25/11/2024 06:00 Monday | 25/11/2024 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | | |
| QLD | Powerlink | 25/11/2024 08:00 Monday | 29/11/2024 17:00 Friday | Nebo - Strathmore (822) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 48 hrs- Night: 48 hrs | Planned - SUBMIT | X | | QLD Maintenance 4.4 Days | | |
| VIC | AusNet | 02/12/2024 06:00 Monday | 02/12/2024 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 09/12/2024 06:00 Monday | 09/12/2024 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 09/12/2024 06:00 Monday | 09/12/2024 16:00 Monday | Kiamal SF - MurraWarra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | | |
| QLD | Powerlink | 09/12/2024 08:00 Monday | 11/12/2024 17:00 Wednesday | Strathmore - Ross (8857) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 6 hrs- Night: 8 hrs | Planned - RESUBMIT | | × | QLD Commissioning 2.4 Days | | |

| | | | Finish | Network Asset | Impact | Legend Withdrawn / UTP since the last notification Newly Added Outage ict Re Re Update(s) since the last notification ason a Withdrawn since the last notification | | | | | |
|-----|--------|------------------------------|------------------------------|-------------------------------------|--|---|------------------|--|--------------------------------|--|--|
| VIC | AusNet | 31/12/2024 06:00 Tuesday | 31/12/2024 17:00 Tuesday | Kiamal SF - MurraWarra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 11 Hours | | |
| VIC | AusNet | 04/01/2025 06:00 Saturday | 04/01/2025 16:00 Saturday | Bulgana - Horsham 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 04/01/2025 06:00 Saturday | 04/01/2025 16:00 Saturday | Crowland - Bulgana 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 13/01/2025 06:00 Monday | 13/01/2025 18:00 Monday | Moorabool–Sydenham No.1 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours | | |
| VIC | AusNet | 14/01/2025 06:00 Tuesday | 14/01/2025 18:00 Tuesday | Moorabool–Sydenham No.1 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours | | |
| VIC | AusNet | 20/01/2025 06:00 Monday | 20/01/2025 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 27/01/2025 06:00 Monday | 27/01/2025 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 03/02/2025 06:00 Monday | 03/02/2025 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 03/02/2025 06:00 Monday | 03/02/2025 18:00 Monday | Moorabool–Sydenham No.1 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours | | |
| VIC | AusNet | 04/02/2025 06:00 Tuesday | 04/02/2025 16:00 Tuesday | Bulgana - Horsham 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |

| 6 | | | Finish | Network Asset | Impact | Legend Withdrawn / UTP since the last notification Newly Added Outage ict Region Re Update(s) since the last notification ason and Withdrawn since the last notification uration | | | | | |
|-----|-----------|------------------------------|------------------------------|-------------------------------------|--|---|------------------|--|---------------------------------|--|--|
| VIC | AusNet | 04/02/2025 06:00 Tuesday | 04/02/2025 16:00 Tuesday | Crowland - Bulgana 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 04/02/2025 06:00 Tuesday | 04/02/2025 16:00 Tuesday | Bulgana - Horsham 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 10/02/2025 06:00 Monday | 10/02/2025 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 17/02/2025 06:00 Monday | 17/02/2025 16:00 Monday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 21/02/2025 06:00 Friday | 21/02/2025 18:00 Friday | Moorabool–Sydenham No.1 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours | | |
| VIC | AusNet | 22/02/2025 06:00 Saturday | 22/02/2025 18:00 Saturday | Moorabool–Sydenham No.1 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours | | |
| VIC | AusNet | 23/02/2025 06:00 Sunday | 23/03/2025 18:00 Sunday | Moorabool–Sydenham No.1 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 28.5 Days | | |
| VIC | AusNet | 24/02/2025 06:00 Monday | 24/02/2025 16:00 Monday | Moorabool–Sydenham No.1 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 03/03/2025 06:00 Monday | 03/03/2025 16:00 Monday | Moorabool–Sydenham No.1 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| QLD | Powerlink | 03/03/2025 08:00 Monday | 07/03/2025 17:00 Friday | Nebo - Strathmore (822) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 48 hrs- Night: 48 hrs | Planned - SUBMIT | | QLD Maintenance 4.4 Days | | |
| VIC | AusNet | 04/03/2025 06:00 Tuesday | 04/03/2025 16:00 Tuesday | Kiamal SF - MurraWarra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |

| | | | Finish | Network Asset | Impact | Legend Withdrawn / UTP since the last notification Newly Added Outage ct Reg Re Update(s) since the last notification Withdrawn since the last notification uration | | | | | |
|-----|-----------|-----------------------------|-------------------------------|-------------------------------------|---|---|------------------|--|-------------------------------------|--|--|
| VIC | AusNet | 04/03/2025 06:00 Tuesday | 04/03/2025 16:00 Tuesday | Horsham - MurraWarra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 07/03/2025 05:00 Friday | 13/03/2025 17:00 Thursday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC / SA Maintenance 6.5 Days | | |
| QLD | Powerlink | 07/03/2025 17:01 Friday | 19/08/2025 07:59 Tuesday | Nebo - Strathmore (822) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 0 mins- Night: NA | Planned - SUBMIT | | QLD Maintenance 164.6 Days | | |
| VIC | AusNet | 10/03/2025 06:00 Monday | 10/03/2025 16:00 Monday | Moorabool–Sydenham No.1 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 4 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 17/03/2025 06:00 Monday | 19/03/2025 16:00 Wednesday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC / SA Maintenance 2.4 Days | | |
| VIC | AusNet | 28/03/2025 06:00 Friday | 28/03/2025 18:00 Friday | Kiamal SF-Red Cliffs 220 kV LINE | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 3 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 12 Hours | | |

| | ALISTRALIAN ENERGY MARKET OPERATOR | | Finish Network Asset | | Impact | Legen Re | Newly Added O Update(s) since | P since the last notification utage ict Region, the last notification ason and the last notification the last notification | | |
|-----|------------------------------------|-------------------------------|-------------------------------|-------------------------------------|---|---------------------------|----------------------------------|--|-------------------------------------|--|
| VIC | AusNet | 02/04/2025 06:00 Wednesday | 02/04/2025 16:00 Wednesday | Haunted Gully - Tarrone 500 Kv line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC / SA Maintenance 10 Hours | |
| VIC | AusNet | 02/04/2025 06:00 Wednesday | 02/04/2025 16:00 Wednesday | Haunted Gully - Tarrone 500 Kv line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC / SA Maintenance 10 Hours | |
| VIC | AusNet | 04/04/2025 06:00 Friday | 04/04/2025 16:00 Friday | Kiamal SF - MurraWarra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | |
| VIC | AusNet | 04/04/2025 06:00 Friday | 04/04/2025 16:00 Friday | Horsham - MurraWarra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 10 Hours | |
| VIC | AusNet | 04/04/2025 06:00 Friday | 04/04/2025 16:00 Friday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | VIC / SA Maintenance 10 Hours | |

| | AEMO AUSTRALIAN ENERGY MARKET OPERATOR | | Finish | Network Asset | Network Asset Impact | | Legend Withdrawn / UTP since the last notification | | | | | |
|-----|---|-------------------------------|-------------------------------|---|---|----------------------------|--|--|--|------------------------------------|--|--|
| VIC | AusNet | 04/04/2025 06:00 Friday | 04/04/2025 16:00 Friday | Horsham - MurraWarra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | | |
| VIC | AusNet | 05/04/2025 06:00 Saturday | 10/04/2025 18:00 Thursday | South Morang - Sydenham No.2 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 120 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 5.5 Days | | |
| VIC | AusNet | 06/04/2025 12:00 Sunday | 06/04/2025 17:00 Sunday | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC / SA Maintenance 5 Hours | | |
| VIC | AusNet | 10/04/2025 07:00 Thursday | 10/04/2025 17:00 Thursday | Rowville - South Morang 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | | |
| QLD | Powerlink | 23/04/2025 08:00 Wednesday | 09/05/2025 17:00 Friday | Strathmore - Ross (8858) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 72 hrs- Night: NA | Planned - SUBMIT | | | QLD Commissioning 16.4 Days | | |
| VIC | AusNet | 07/05/2025 07:00 Wednesday | 07/05/2025 17:00 Wednesday | Dederang - Wodonga 330 kV Line | This is a high-impact outage if the forecast temperature at Red Cliffs is greater than 30 deg. C. This line outage offloads X5 220 kV line. Possible load shedding and risk of large reduction in generation in NSW and interconnector capacity between NSW - Victoria following a credible contingency | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | | |

| | | | Finish Network Asset I | | Impact | Legen Re | Newly Added C Update(s) since | Idrawn / UTP since the last notification Ily Added Outage ate(s) since the last notification Idrawn since the last notification Idrawn since the last notification | | | |
|-----|--------|-------------------------------|-------------------------------|---|---|----------------------------|----------------------------------|--|--|--------------------------------|--|
| VIC | AusNet | 08/05/2025 07:00 Thursday | 08/05/2025 17:00 Thursday | Dederang - Wodonga 330 kV Line | This is a high-impact outage if the forecast temperature at Red Cliffs is greater than 30 deg. C. This line outage offloads X5 220 kV line. Possible load shedding and risk of large reduction in generation in NSW and interconnector capacity between NSW - Victoria following a credible contingency | Day: 2 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | |
| VIC | AusNet | 20/05/2025 07:00 Tuesday | 20/05/2025 17:00 Tuesday | Ballarat - Waubra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | |
| VIC | AusNet | 21/05/2025 07:00 Wednesday | 21/05/2025 17:00 Wednesday | Ballarat - Waubra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | |
| VIC | AusNet | 21/05/2025 07:00 Wednesday | 21/05/2025 17:00 Wednesday | Ballarat - Waubra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | |
| VIC | AusNet | 21/05/2025 07:00 Wednesday | 21/05/2025 17:00 Wednesday | Ballarat - Waubra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 10 Hours | |
| VIC | AusNet | 22/05/2025 07:00 Thursday | 22/05/2025 15:00 Thursday | Ballarat - Waubra 220 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 60 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 8 Hours | |
| VIC | AusNet | 24/06/2025 07:00 Tuesday | 29/06/2025 17:00 Sunday | South Morang - Sydenham No.1 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 120 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 5.4 Days | |

| | AUST | | Finish | Network Asset | Impact | Legen Re | Newly Added C | utage the last e the las | notifi | ication ason and |
|-----|------------|-----------------------------|----------------------------|---|---|------------------------------|------------------|--------------------------------|--------|--------------------------------|
| SA | ElectraNet | 30/06/2025 07:30 Monday | 06/07/2025 17:30 Sunday | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 07/07/2025 07:30 Monday | 13/07/2025 17:30 Sunday | Tailem Bend (6595) 275 kV Circuit Breaker | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | Maintenance 6.4 Days |
| SA | ElectraNet | 14/07/2025 07:30 Monday | 20/07/2025 19:30 Sunday | Heywood - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | Đ | Maintenance 6.5 Days |
| VIC | AusNet | 15/07/2025 07:00 Tuesday | 20/07/2025 17:00 Sunday | Moorabool–Sydenham No.1 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 120 hrs- Night: NA | Planned - SUBMIT | | | VIC Maintenance 5.4 Days |

| | | | Finish Network Asset I | | Impact | Re Update(s) since the I | | | ince the last notification age ict Region, e last notification ason and he last notification ເຮັ | | |
|-----|------------|----------------------------|-------------------------------|---|---|------------------------------|------------------|--|--|-------------|--------------------------------|
| SA | ElectraNet | 21/07/2025 07:30 Monday | 27/07/2025 17:30 Sunday | Heywood - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | \boxtimes | Maintenance 6.4 Days |
| SA | ElectraNet | 28/07/2025 07:30 Monday | 03/08/2025 17:30 Sunday | Tailem Bend - Tungkillo No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 04/08/2025 07:30 Monday | 10/08/2025 17:30 Sunday | Tailem Bend - Tungkillo No.2 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| VIC | AusNet | 08/08/2025 07:00 Friday | 13/08/2025 17:00 Wednesday | South Morang - Sydenham No.2 500 kV Line | This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 120 hrs- Night: NA | Planned - SUBMIT | | | | VIC Maintenance 5.4 Days |

| | | | Finish | Network Asset | Impact | | | Legend Withdrawn / UTP since the last noti Newly Added Outage Re Update(s) since the last notificatio Withdrawn since the last notificatio | | | | |
|-----|------------|------------------------------|-------------------------------|---|---|-------------------------------|------------------|---|-----------------------------------|--|--|--|
| QLD | Powerlink | 19/08/2025 08:00 Tuesday | 24/11/2025 07:59 Monday | Nebo - Strathmore (822) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 0 mins- Night: NA | Planned - SUBMIT | | QLD Maintenance 97 Days | | | |
| VIC | AusNet | 01/09/2025 07:00 Monday | 06/09/2025 17:00 Saturday | Moorabool–Sydenham No.2 500 kV Line | A credible contingency event during this planned outage may require market intervention through issuing of directions | Day: 120 hrs- Night: NA | Planned - SUBMIT | | VIC Maintenance 5.4 Days | | | |
| QLD | Powerlink | 02/09/2025 08:00 Tuesday | 15/09/2025 17:00 Monday | Strathmore - Ross (8858) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: NA-Night: NA | Planned - SUBMIT | | QLD Commissioning 13.4 Days | | | |
| QLD | Powerlink | 03/11/2025 07:00 Monday | 07/11/2025 15:00 Friday | Nebo - Broadsound (8846) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 8 hrs- Night: 8 hrs | Planned - SUBMIT | | QLD Commissioning 4.3 Days | | | |
| QLD | Powerlink | 24/11/2025 08:00 Monday | 28/11/2025 17:00 Friday | Nebo - Strathmore (822) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 48 hrs- Night: 48 hrs | Planned - SUBMIT | | QLD Maintenance 4.4 Days | | | |
| QLD | Powerlink | 25/12/2025 08:00 Thursday | 07/01/2026 17:00 Wednesday | Strathmore - Ross (8858) 275 kV Line | This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 72 hrs- Night: NA | Planned - SUBMIT | | QLD Commissioning 13.4 Days | | | |
| SA | ElectraNet | 29/06/2026 07:30 Monday | 05/07/2026 17:30 Sunday | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | Maintenance 6.4 Days | | | |

| | AUST | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / U Newly Added C Update(s) since Withdrawn since | Outage the la | st no | tifica otifca | tion ason and |
|----|------------|----------------------------|----------------------------|---|---|------------------------------|--|------------------|-------|------------------|-------------------------------|
| SA | ElectraNet | 06/07/2026 07:30 Monday | 12/07/2026 17:30 Sunday | Tailem Bend - South East No.2 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 13/07/2026 07:30 Monday | 19/07/2026 19:30 Sunday | Heywood - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.5 Days |
| SA | ElectraNet | 20/07/2026 07:30 Monday | 26/07/2026 17:30 Sunday | Heywood - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | X | Maintenance 6.4 Days |
| SA | ElectraNet | 27/07/2026 07:30 Monday | 02/08/2026 17:30 Sunday | Tailem Bend (6536) 275 kV Circuit Breaker | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |

| | | | Finish | Network Asset | Impact | Legen Re | Newly Added C | utage the last n | |
|----|------------|----------------------------|----------------------------|---|---|------------------------------|------------------|---------------------|-------------------------------|
| SA | ElectraNet | 03/08/2026 07:30 Monday | 09/08/2026 17:30 Sunday | Tailem Bend - Tungkillo No.2 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 28/06/2027 07:30 Monday | 04/07/2027 17:30 Sunday | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | Maintenance 6.4 Days |
| SA | ElectraNet | 05/07/2027 07:30 Monday | 11/07/2027 17:30 Sunday | Tailem Bend (6595) 275 kV Circuit Breaker | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | Maintenance 6.4 Days |

| | | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / U Newly Added C Update(s) since Withdrawn since | utag the l | e last no | tifica | ict Region, tion ason and |
|----|------------|----------------------------|----------------------------|--|---|------------------------------|--|---------------|--------------|--------|-------------------------------------|
| SA | ElectraNet | 12/07/2027 07:30 Monday | 18/07/2027 19:30 Sunday | Heywood - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.5 Days |
| SA | ElectraNet | 19/07/2027 07:30 Monday | 25/07/2027 17:30 Sunday | Heywood - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | VIC / SA Maintenance 6.4 Days |
| SA | ElectraNet | 26/07/2027 07:30 Monday | 01/08/2027 17:30 Sunday | Tailem Bend - Tungkillo No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 02/08/2027 07:30 Monday | 08/08/2027 17:30 Sunday | Tailem Bend - Tungkillo No.2 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |

| (| 6 | | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / UT Newly Added O Update(s) since Withdrawn sinc | utage the last e the las | notifi | act Region, cation ason and |
|---|----|------------|----------------------------|----------------------------|---|---|------------------------------|--|--------------------------------|--------|-------------------------------------|
| | SA | ElectraNet | 26/06/2028 07:30 Monday | 02/07/2028 17:30 Sunday | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | SA Maintenance 6.4 Days |
| | SA | ElectraNet | 03/07/2028 07:30 Monday | 09/07/2028 17:30 Sunday | Tailem Bend (6595) 275 kV Circuit Breaker | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | SA Maintenance 6.4 Days |
| | SA | ElectraNet | 10/07/2028 07:30 Monday | 16/07/2028 19:30 Sunday | Heywood - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | × | Maintenance 6.5 Days |
| | SA | ElectraNet | 17/07/2028 07:30 Monday | 23/07/2028 17:30 Sunday | Heywood - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | × | VIC / SA Maintenance 6.4 Days |

| | | | Finish | Network Asset | Impact | Legen Re | Newly Added C | utage the last no | |
|----|------------|----------------------------|----------------------------|---|---|------------------------------|------------------|----------------------|-------------------------------|
| SA | ElectraNet | 24/07/2028 07:30 Monday | 30/07/2028 17:30 Sunday | Tailem Bend - Tungkillo No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 31/07/2028 07:30 Monday | 06/08/2028 17:30 Sunday | Tailem Bend (6595) 275 kV Circuit Breaker | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 02/07/2029 07:30 Monday | 08/07/2029 17:30 Sunday | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | Maintenance 6.4 Days |

| | | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / U Newly Added C Update(s) since Withdrawn since | Outage the la | st no | tifica otifca | tion ason and |
|----|------------|----------------------------|----------------------------|---|---|------------------------------|--|------------------|-------|------------------|-------------------------------|
| SA | ElectraNet | 09/07/2029 07:30 Monday | 15/07/2029 17:30 Sunday | Tailem Bend - South East No.2 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |
| SA | ElectraNet | 16/07/2029 07:30 Monday | 22/07/2029 19:30 Sunday | Heywood - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.5 Days |
| SA | ElectraNet | 23/07/2029 07:30 Monday | 29/07/2029 17:30 Sunday | Heywood - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |
| SA | ElectraNet | 30/07/2029 07:30 Monday | 05/08/2029 17:30 Sunday | Tailem Bend - Tungkillo No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | SA Maintenance 6.4 Days |

| | | | Finish | Network Asset | Impact | Legen Re | Newly Added C | utage the last r e the last | e last notification ict Region, notification ason and notification 5 |
|----|------------|----------------------------|----------------------------|---|---|------------------------------|------------------|-----------------------------------|--|
| SA | ElectraNet | 06/08/2029 07:30 Monday | 12/08/2029 17:30 Sunday | Tailem Bend (6595) 275 kV Circuit Breaker | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | Maintenance 6.4 Days |
| SA | ElectraNet | 01/07/2030 07:30 Monday | 07/07/2030 17:30 Sunday | Tailem Bend - South East No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | Maintenance 6.4 Days |
| SA | ElectraNet | 08/07/2030 07:30 Monday | 14/07/2030 17:30 Sunday | Tailem Bend - South East No.2 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | Maintenance 6.4 Days |

| | | | Finish | Network Asset | Impact | Legen Re | d Withdrawn / UT Newly Added C Update(s) since Withdrawn sinc | utago the l | e ast no | tifica otifca | ict Region, tion ason and |
|----|------------|----------------------------|----------------------------|---|---|------------------------------|--|----------------|-------------|------------------|-------------------------------------|
| SA | ElectraNet | 15/07/2030 07:30 Monday | 21/07/2030 19:30 Sunday | Heywood - South East No.1 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | VIC / SA Maintenance 6.5 Days |
| SA | ElectraNet | 22/07/2030 07:30 Monday | 28/07/2030 17:30 Sunday | Heywood - South East No.2 275 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | \boxtimes | Maintenance 6.4 Days |
| SA | ElectraNet | 29/07/2030 07:30 Monday | 04/08/2030 17:30 Sunday | Tailem Bend - Tungkillo No.1 275 kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |
| SA | ElectraNet | 05/08/2030 07:30 Monday | 11/08/2030 17:30 Sunday | Tailem Bend (6595) 275 kV Circuit Breaker | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 6 hrs- Night: 12 hrs | Planned - SUBMIT | | | | Maintenance 6.4 Days |



| | | | | | Legend | Withdrawn / UTP since the last notific | ation | |
|----------|--------|---------------|--------|----|--------|--|------------|--|
| | | | | | | Newly Added Outage | ct Region, | |
| | Finish | Network Asset | Impact | Re | | Update(s) since the last notification | ason and | |
| OPERATOR | | | | | | Withdrawn since the last notifcation | uration | |
| | | | | | | | | |



| | | | | | Legend | Withdrawn / UTP since the last notific | ation | |
|----------|--------|---------------|--------|----|--------|--|------------|--|
| | | | | | | Newly Added Outage | ct Region, | |
| | Finish | Network Asset | Impact | Re | | Update(s) since the last notification | ason and | |
| OPERATOR | | | | | | Withdrawn since the last notifcation | uration | |
| | | | | | | | | |



| | | | | | Legend | Withdrawn / UTP since the last notific | ation | |
|----------|--------|---------------|--------|----|--------|--|-------------|---|
| | | | | | | Newly Added Outage | ict Region, | 1 |
| | Finish | Network Asset | Impact | Re | | Update(s) since the last notification | ason and | |
| OPERATOR | | | | | | Withdrawn since the last notifcation | uration | 1 |
| | | | | | | | | 1 |



| | | | | | Legend | Withdrawn / UTP since the last notific | ation | |
|----------|--------|---------------|--------|----|--------|--|------------|--|
| | | | | | | Newly Added Outage | ct Region, | |
| | Finish | Network Asset | Impact | Re | | Update(s) since the last notification | ason and | |
| OPERATOR | | | | | | Withdrawn since the last notifcation | uration | |
| | | | | | | | | |



| | | | | | Legend | Withdrawn / UTP since the last notific | ation | |
|----------|--------|---------------|--------|----|--------|--|------------|--|
| | | | | | | Newly Added Outage | ct Region, | |
| | Finish | Network Asset | Impact | Re | | Update(s) since the last notification | ason and | |
| OPERATOR | | | | | | Withdrawn since the last notifcation | uration | |
| | | | | | | | 1 | |



| | | | | | Legend | Withdrawn / UTP since the last notific | ation | |
|----------|--------|---------------|--------|----|--------|--|------------|--|
| | | | | | | Newly Added Outage | ct Region, | |
| | Finish | Network Asset | Impact | Re | | Update(s) since the last notification | ason and | |
| OPERATOR | | | | | | Withdrawn since the last notifcation | uration | |
| | | | | | | | 1 | |



| | | | | | Legend | Withdrawn / UTP since the last notific | ation | 1 |
|--|--------|---------------|--------|----|--------|--|-------------|---|
| | | | | | | Newly Added Outage | ict Region, | 1 |
| | Finish | Network Asset | Impact | Re | | Update(s) since the last notification | ason and | |
| | | | | | | Withdrawn since the last notifcation | uration | |
| | | | | | | Ğ | | 1 |



| | | | | | Legend | ation | | |
|----------|--------|---------------|--------|----|--------|---------------------------------------|-------------|---|
| | | | | | | Newly Added Outage | ict Region, | 1 |
| | Finish | Network Asset | Impact | Re | | Update(s) since the last notification | ason and | |
| OPERATOR | | | | | | Withdrawn since the last notifcation | uration | 1 |
| | | | | | | | | 1 |