

Newly added outage

Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
QLD	Powerlink	26/06/2017 07:30	11/07/2017 18:00	Ross No.2 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 8 hrs Night: 8 hrs	Not required	Not required	Maintenance
VIC	AusNet	17/07/2017 07:30	17/07/2017 16:00	Moorabool–Sydenham No.1 500 kV Line	This outage has been WITHDRAWN. This is a high-impact outage only if the Emergency Moorabool Transformer Trip (EMTT) scheme remains activated. A credible contingency event during this planned outage could cause:  • A large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 4 hrs Night: Not applicable	Not required	Invoked	Maintenance
VIC	AusNet	18/07/2017 08:30	18/07/2017 15:00	Hazelwood - Rowville 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW  A credible contingency event during this planned outage could cause:  • A large reduction in generation in Victoria  • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 1.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
VIC	AusNet	20/07/2017 07:30	20/07/2017 16:00	Keilor - South Morang 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could cause:  • A large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Invoked	Maintenance
VIC	AusNet	29/07/2017 07:30	29/07/2017 17:00	Hazelwood - Cranbourne 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could cause:  • A large reduction in generation in Victoria  • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: No recall	Not required	Invoked	Maintenance
VIC	AusNet	30/07/2017 07:30	30/07/2017 17:00						maintenance



Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	14/08/2017 07:00	14/08/2017 17:00	Hazelwood - South Morang No.1	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW  A credible contingency event during this planned outage could cause a large reduction in generation in Victoria.	Day: 2 hrs Night: No recall	Not required	Invoked	Maintenance
NSW / VIC	Transgrid	15/09/2017 08:00	15/09/2017 10:00	Buronga Red_Cliffs X1 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 1 hrs Night: No recall	Not required	Being assessed	Maintenance
SA	ElectraNet	18/09/2017 08:00	29/09/2017 15:30		A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 80 hrs Night: 88 hrs	To be issued	Being assessed	Maintenance
SA	ElectraNet	04/10/2017 07:30	07/10/2017 09:30		A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  • Initiate the orderly separation of SA from the rest of the NEM.  • Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 26 hrs Night: 32 hrs	To be issued	Being assessed	Maintenance



Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
SA	ElectraNet	07/10/2017 09:30	08/10/2017 13:30		A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  • Initiate the orderly separation of SA from the rest of the NEM.  • Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 26 hrs Night: 32 hrs	To be issued	Being assessed	Maintenance
VIC	AusNet	15/10/2017 06:30	15/10/2017 10:00	Hazelwood - Loy Yang Power Station No.1 500 kV Line	A credible contingency event during this planned outage could cause:  • A large reduction in generation in Victoria  • Load shedding in Victoria	Day: 30 mins Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	14/11/2017 08:00	14/11/2017 14:00	Sheffield - Farrell No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance
TAS	TasNetworks	01/12/2017 07:00	01/12/2017 15:00	Sheffield - Farrell No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1.5 hrs Night: Not applicable	Not required	Being assessed	Maintenance
TAS	TasNetworks	02/10/2018 08:00	02/10/2018 16:00	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	05/10/2018 08:00	05/10/2018 16:00	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance



Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
TAS	TasNetworks	09/10/2018 07:00	09/10/2018 15:00	l ·	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	12/10/2018 07:00	12/10/2018 15:00	'	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	05/12/2018 07:00	05/12/2018 16:00	I Sheffield - Farrell No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1.5 hrs Night: Not applicable	Not required	Being assessed	Maintenance
TAS	TasNetworks	06/12/2018 07:00	06/12/2018 15:00	I Sheffield - Farrell No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance

#### Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

 $AEMO\ has\ made\ every\ effort\ to\ ensure\ the\ quality\ of\ the\ information\ in\ this\ document\ but\ cannot\ guarantee\ its\ accuracy\ or\ completeness.$ 

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.