

Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
QLD	Powerlink	16/12/2017 06:30	16/12/2017 17:00	Broadsound - Nebo (834) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Invoked	Maintenance
NSW	Transgrid	06/01/2018 07:00	06/01/2018 11:00	Wagga - Darlington Point (63) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer •Between Victoria and New South Wales. •Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 1 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	23/04/2018 07:00	23/04/2018 17:00	Jindera - Wagga (62) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 3 hrs Night: 2 hrs	Not required	Being assessed	Maintenance
<u>nsw</u>	Transgrid	24/04/2018 07:00	24/04/2018 17:00	Jindera - Wagga (62) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 3 hrs Night: 2 hrs	Not required	Being assessed	Maintenance



Newly added outage

Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	26/04/2018 07:00	26/04/2018 17:00	Jindera - Wagga (62) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink • Credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 3 hrs Night: 2 hrs	Not required	Being assessed	Maintenance
NSW	Transgrid	27/04/2018 07:00	27/04/2018 17:00	Jindera - Wagga (62) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 3 hrs Night: 2 hrs	Not required	Being assessed	Maintenance
VIC / SA	ElectraNet	17/06/2018 08:00	17/06/2018 17:00	Heywood - South East No.1 275 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Local regulation raise and lower FCAS will be sourced within South Australia. • When power transfer is from South Australia to Victoria, contingency lower FCAS will be sourced within SA.	Day: 1.5 hrs Night: Not applicable	To be issued	Being assessed	Maintenance



Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC / SA	ElectraNet	18/06/2018 08:00	18/06/2018 17:00		A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Local regulation raise and lower FCAS will be sourced within South Australia. • When power transfer is from South Australia to Victoria, contingency lower FCAS will be sourced within SA.	Day: 1.5 hrs Night: Not applicable	To be issued	Being assessed	Maintenance
VIC / SA	ElectraNet	19/06/2018 08:00	19/06/2018 17:00		A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Local regulation raise and lower FCAS will be sourced within South Australia. • When power transfer is from South Australia to Victoria, contingency lower FCAS will be sourced within SA.	Day: 1.5 hrs Night: Not applicable	To be issued	Being assessed	Maintenance
VIC / SA	ElectraNet	20/06/2018 08:00	20/06/2018 17:00	Heywood - South East No.2 275 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Local regulation raise and lower FCAS will be sourced within South Australia. • When power transfer is from South Australia to Victoria, contingency lower FCAS will be sourced within SA.	Day: 1.5 hrs Night: Not applicable	To be issued	Being assessed	Maintenance
TAS	TasNetworks	02/10/2018 08:00	02/10/2018 16:00	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance



Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
<u>TAS</u>	TasNetworks	05/10/2018 08:00	05/10/2018 16:00	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	09/10/2018 07:00	09/10/2018 15:00	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	12/10/2018 07:00	12/10/2018 15:00	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	05/12/2018 07:00	05/12/2018 16:00	Sheffield - Farrell No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1.5 hrs Night: Not applicable	Not required	Being assessed	Maintenance
TAS	TasNetworks	06/12/2018 07:00	06/12/2018 15:00	Sheffield - Farrell No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice,

and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.