

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
QLD	Powerlink	01/05/2018 08:00	15/05/2018 07:29	Ross No.2 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 6 mins Night: Not applicable	Not required	Not required	Maintenance
QLD	Powerlink	15/05/2018 07:30	18/05/2018 15:00	Ross No.2 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. Market intervention	Day: 4 hrs Night: 6 hrs	Not required	Being assessed	Maintenance
NSW	Transgrid	16/05/2018 07:00	17/05/2018 17:00	Armidale - Tamworth (85) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 2 hrs Night: 2 hrs	Not required	Being assessed	Maintenance
VIC	AusNet	22/05/2018 07:30	22/05/2018 15:30	Hazahugad - Pouvilla 500 MV Lina	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:	Day: 2 hrs	Not required	Invoked	Maintenance
VIC	AusNet	23/05/2018 07:30	23/05/2018 15:30	Hazelwood - Rowville 500 kV Line	Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Night: No recall	Not required	Invoked	
NSW	Transgrid	23/05/2018 08:00	23/05/2018 14:00	Armidale - Dumaresq (8C or 8E) 330 kV line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 2 hrs Night: No recall	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	25/05/2018 08:00	25/05/2018 10:30	Hazelwood - Cranbourne 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Invoked	Maintenance
QLD	Powerlink	29/05/2018 08:00	08/06/2018 14:00	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 2 hrs Night: 3 hrs	Not required	Being assessed	Maintenance
SA	ElectraNet	31/05/2018 08:30	01/06/2018 17:30	Tailem Bend - Tungkillo 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 14 hrs Night: 18 hrs	Issued on 01/05/2018	Invoked	Maintenance
SA	ElectraNet	04/06/2018 08:00	07/06/2018 08:30	Tailem Bend - South East No.1 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 80 hrs Night: 88 hrs	Issued on 04/05/2018	Being assessed	Project work
NSW	Transgrid	07/06/2018 07:00	07/06/2018 18:00	Armidale - Tamworth (85) 330 kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could cause: Synchronous separation of the Queensland region from the rest of the NEM	Day: 11 hrs Night: No recall	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
SA	ElectraNet	07/06/2018 08:30	14/06/2018 08:30	Tailem Bend - South East No.1 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 80 hrs Night: 88 hrs	Issued on 04/05/2018	Being assessed	Project work
NSW	Transgrid	08/06/2018 07:00	08/06/2018 18:00	Armidale - Tamworth (85) 330 kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could cause: Synchronous separation of the Queensland region from the rest of the NEM	Day: 11 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	13/06/2018 07:00	13/06/2018 18:00	Armidale - Tamworth (85) 330 KV	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 11 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	14/06/2018 07:00	14/06/2018 18:00	Armidale - Tamworth (85) 330 KV	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 11 hrs Night: No recall	Not required	Being assessed	Maintenance
SA	ElectraNet	14/06/2018 08:30	14/06/2018 10:30	Tailem Bend - South East No.1 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
SA	ElectraNet	14/06/2018 10:30	14/06/2018 12:30	Tailem Bend - South East No.1 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Being assessed	Project work
SA	ElectraNet	14/06/2018 12:30	14/06/2018 13:30	Tailem Bend - South East No.1 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Being assessed	Project work
SA	ElectraNet	14/06/2018 13:30	14/06/2018 14:00	Tailem Bend - South East No.1 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
SA	ElectraNet	14/06/2018 14:00	14/06/2018 14:30	Tailem Bend - South East No.1 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Being assessed	Project work
SA	ElectraNet	14/06/2018 14:30	14/06/2018 15:00	Tailem Bend - South East No.1 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Being assessed	Project work
SA	ElectraNet	14/06/2018 15:00	14/06/2018 15:30	Tailem Bend - South East No.1 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
SA	ElectraNet	14/06/2018 15:30	14/06/2018 17:30	Tailem Bend - South East No.1 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Being assessed	Project work
SA	ElectraNet	14/06/2018 17:30	15/06/2018 17:30	Tailem Bend - South East No.1 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Being assessed	Project work
NSW	Transgrid	15/06/2018 07:00	15/06/2018 18:00	Armidale - Tamworth (85) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 11 hrs Night: No recall	Not required	Being assessed	Maintenance
VIC / SA	ElectraNet	18/06/2018 08:00	18/06/2018 17:00	Heywood - South East No.1 275 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Local regulation raise and lower FCAS will be sourced within South Australia. • When power transfer is from South Australia to Victoria, contingency lower FCAS will be sourced within SA.	Day: 1.5 hrs Night: Not applicable	To be issued	Invoked	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC / SA	ElectraNet	19/06/2018 08:00	19/06/2018 17:00	Heywood - South East No.2 275 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Local regulation raise and lower FCAS will be sourced within South Australia. • When power transfer is from South Australia to Victoria, contingency lower FCAS will be sourced within SA.	Day: 1.5 hrs Night: Not applicable	To be issued	Invoked	Maintenance
SA	ElectraNet	21/06/2018 08:30	27/06/2018 17:30	Tailem Bend - South East No.2 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 26 hrs Night: 32 hrs	To be issued	Invoked	Project work
SA	ElectraNet	28/06/2018 08:00	01/07/2018 17:30	Cherry Gardens - Tailem Bend 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 18 hrs Night: 24 hrs	To be issued	Invoked	Project work
TAS	TasNetworks	02/10/2018 08:00	02/10/2018 16:00		A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance



Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
TAS	TasNetworks	05/10/2018 08:00	05/10/2018 16:00	· -	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	09/10/2018 07:00	09/10/2018 15:00	*	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	12/10/2018 07:00	12/10/2018 15:00	· '	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	05/12/2018 07:00	05/12/2018 16:00		A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1.5 hrs Night: Not applicable	Not required	Being assessed	Maintenance
TAS	TasNetworks	06/12/2018 07:00	06/12/2018 15:00	i Spettield - Farrell No 1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice,

and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.