

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
SA	ElectraNet	07/06/2018 08:30	14/06/2018 08:30	Tailem Bend - South East No.1 275 kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 80 hrs Night: Not applicable	Issued on 04/05/2018	Invoked	Project work
NSW	Transgrid	13/06/2018 07:00	13/06/2018 18:00	Armidale - Tamworth (85) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 11 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	14/06/2018 07:00	14/06/2018 18:00	Armidale - Tamworth (85) 330 kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 11 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	14/06/2018 07:00	14/06/2018 18:00	Armidale - Tamworth (85) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 11 hrs Night: No recall	Not required	Being assessed	Maintenance



Pogion	NSP	Ctart	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
Region SA	ElectraNet	Start 14/06/2018 08:30	14/06/2018 10:30		This outage has been WITHDRAWN. A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	issued on 04/05/2018	Invoked	Project work
SA	ElectraNet	14/06/2018 10:30	14/06/2018 12:30	Tailem Bend - South East No.1 275 kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Invoked	Project work
SA	ElectraNet	14/06/2018 12:30	14/06/2018 13:30	Tailem Bend - South East No.1 275 kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 KV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Invoked	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
SA	ElectraNet	14/06/2018 13:30	14/06/2018 14:00	Tailem Bend - South East No.1 275 kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Invoked	Project work
SA	ElectraNet	14/06/2018 14:00	14/06/2018 14:30	Tailem Bend - South East No.1 275 kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Invoked	Project work
SA	ElectraNet	14/06/2018 15:00	14/06/2018 15:30	Tailem Bend - South East No.1 275 kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Invoked	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
SA	ElectraNet	14/06/2018 15:30	14/06/2018 16:30		This outage has been WITHDRAWN. A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this	Day: Not applicable Night: Not applicable	Issued on 04/05/2018	Invoked	Project work
NSW	Transgrid	15/06/2018 07:00	15/06/2018 18:00	Armidale - Tamworth (85) 330 kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could cause: Synchronous separation of the Queensland region from the rest of the NEM	Day: 11 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	15/06/2018 07:00	15/06/2018 18:00	Armidale - Tamworth (85) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 11 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	16/06/2018 06:00	16/06/2018 17:00	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: 1 hrs	Not required	Being assessed	Maintenance
NSW	Transgrid	18/06/2018 06:00	18/06/2018 17:00	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: 1 hrs	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
QLD	Powerlink	18/06/2018 08:00	22/06/2018 14:00	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 2 hrs Night: 3 hrs	Not required	Being assessed	Maintenance
NSW	Transgrid	19/06/2018 06:00	19/06/2018 17:00	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: 1 hrs	Not required	Being assessed	Maintenance
NSW	Transgrid	20/06/2018 06:00	20/06/2018 17:00	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: 1 hrs	Not required	Being assessed	Maintenance
QLD	Powerlink	24/06/2018 08:00	20/07/2018 20:00	Stanwell - Broadsound (856) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may result in shedding Far North QLD load and Lilyvale local load. Following a credible contingency market intervention through issuing of directions may be required. If market intervention is unsuccessful all of North QLD load would be in a credible risk	Day: Not applicable Night: Not applicable	Not required	Being assessed	Maintenance
SA	ElectraNet	09/07/2018 08:30	10/07/2018 17:30	Tailem Bend - Tungkillo 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 14 hrs Night: 18 hrs	To be issued	Invoked	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market netice	Constraint	Outage reason
Region	NOF	Start	Fillişli	Network asset	ппрасс	Recall tille	IVIAI KEL HOLICE	Constraint	Outage reason
SA	ElectraNet	11/07/2018 08:00	14/07/2018 17:30	Cherry Gardens - Tailem Bend 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 18 hrs Night: 24 hrs	Issued on 08/06/2018	Invoked	Project work
TAS	TasNetworks	02/10/2018 08:00	02/10/2018 16:00	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	05/10/2018 08:00	05/10/2018 16:00	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	09/10/2018 07:00	09/10/2018 15:00	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	12/10/2018 07:00	12/10/2018 15:00	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	05/12/2018 07:00	05/12/2018 16:00	Sheffield - Farrell No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1.5 hrs Night: Not applicable	Not required	Being assessed	Maintenance
TAS	TasNetworks	06/12/2018 07:00	06/12/2018 15:00	Sheffield - Farrell No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance



	Newly added outage
	Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice Const	raint Outage reason

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice,

and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.