

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
TAS	TasNetworks	05/08/2018 08:30	06/08/2018 16:30	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: 2 hrs	Not required	Invoked	Maintenance
VIC	AusNet	06/08/2018 06:30	06/08/2018 17:00	Ararat - Horsham 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
QLD	Powerlink	06/08/2018 08:00	17/08/2018 17:00	Nebo - Broadsound (8847) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: No recall Night: No recall	Not required	Invoked	Maintenance
SA	ElectraNet	06/08/2018 08:30	12/08/2018 10:30	Tailem Bend - South East No.2 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 26 hrs Night: 32 hrs	Issued on 09/07/2018	Invoked	Project work
QLD	Powerlink	07/08/2018 08:00	07/08/2018 15:00	Nebo - Strathmore (8845) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 1.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
VIC	AusNet	08/08/2018 06:30	08/08/2018 17:00	Ararat - Horsham 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
SA	ElectraNet	12/08/2018 10:30	12/08/2018 13:30		A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 26 hrs Night: 32 hrs	Issued on 09/07/2018	Invoked	Project work
SA	ElectraNet	12/08/2018 13:30	12/08/2018 17:30		A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 26 hrs Night: 32 hrs	Issued on 09/07/2018	Invoked	Project work
NSW / VIC	AusNet	13/08/2018 07:00	13/08/2018 17:00	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 2 hrs Night: No recall	Not required	Invoked	Maintenance
NSW / VIC	Transgrid	13/08/2018 07:00	13/08/2018 17:00	Buronga Red_Cliffs X1 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 2 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW / VIC	AusNet	14/08/2018 07:00	14/08/2018 17:00	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 2 hrs Night: No recall	Not required	Invoked	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW / VIC	Transgrid	14/08/2018 07:00	14/08/2018 17:00		This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 2 hrs Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	14/08/2018 07:00	17/08/2018 16:00		This outage has been WITHDRAWN. This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 4 hrs Night: 5 hrs	Not required	Being assessed	Maintenance
VIC	AusNet	15/08/2018 05:30	15/08/2018 20:30	Ararat - Horsham 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 6 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	16/08/2018 05:30	16/08/2018 20:30		Load shedding in the Victorian outer grid Market intervention through issuing of directions.				Mameriance
VIC	AusNet	17/08/2018 05:30	17/08/2018 20:30			Day: 6 hrs Night: Not applicable	Not required	Being assessed	_
VIC	AusNet	18/08/2018 05:30	18/08/2018 20:30		This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.				Maintenance
VIC	AusNet	19/08/2018 05:30	19/08/2018 20:30		market mententum undugm issuing of uncedions.				
VIC	AusNet	20/08/2018 06:30	20/08/2018 18:30	Ararat - Horsham 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason		
QLD	Powerlink	20/08/2018 07:00	23/08/2018 17:00	Strathmore - Ross (879) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 2 hrs Night: 2 hrs	Not required	Being assessed	Maintenance		
VIC	AusNet	21/08/2018 06:30	21/08/2018 18:30	Ararat - Horsham 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance		
VIC	AusNet	23/08/2018 05:30	23/08/2018 18:30	Ararat - Horsham 220 kV Line							
VIC	AusNet	24/08/2018 05:30	24/08/2018 18:30		Ararat - Horsham 220 kV Line	This is a high-impact outage only if the forecast temperature at Red					
VIC	AusNet	25/08/2018 05:30	25/08/2018 18:30			Cliffs is Ararat - Horsham 220 kV Line A cred • Load	Cliffs is greater than 30 °C	Day: 4 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	26/08/2018 05:30	26/08/2018 18:30								
VIC	AusNet	27/08/2018 05:30	27/08/2018 18:30								
QLD	Powerlink	27/08/2018 08:00	14/09/2018 17:00	Broadsound - Nebo (834) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: No recall Night: No recall	Not required	Being assessed	Maintenance		
VIC	AusNet	29/08/2018 08:00	29/08/2018 15:30	Hazelwood - Cranbourne 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Invoked	Maintenance		



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
Region	INSP	Start	FIIIISII	Network asset	impact	Recall tillle	Market Hotice	Constraint	Outage reason
VIC	AusNet	30/08/2018 08:00	30/08/2018 15:30	Hazelwood - Rowville 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could:	Day: 2 hrs	Not required	Invoked	Maintenance
VIC	AusNet	31/08/2018 08:00	31/08/2018 15:30	100000000000000000000000000000000000000	Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Night: Not applicable	. Not required	mvoked	wiantellatice
QLD	Powerlink	05/09/2018 08:00	05/09/2018 15:30	Strathmore No.1 275/132 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 45 mins Night: Not applicable	Not required	Being assessed	Maintenance
TAS	TasNetworks	02/10/2018 08:00	02/10/2018 16:00	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	05/10/2018 08:00	05/10/2018 16:00	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
VIC	AusNet	08/10/2018 07:30	08/10/2018 15:30	Hazelwood Terminal Station - Loy Yang Power Station 500 kV line	A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Load shedding in Victoria	Day: 4 hrs Night: Not applicable	Not required	Being assessed	Maintenance
TAS	TasNetworks	09/10/2018 07:00	09/10/2018 15:00	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance



Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	09/10/2018 07:30	09/10/2018 15:30		A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Load shedding in Victoria	Day: 4 hrs Night: Not applicable	Not required	Being assessed	Maintenance
TAS	TasNetworks	12/10/2018 07:00	12/10/2018 15:00	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2.5 hrs Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	05/12/2018 07:00	05/12/2018 16:00	Sheffield - Farrell No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1.5 hrs Night: Not applicable	Not required	Being assessed	Maintenance
TAS	TasNetworks	06/12/2018 07:00	06/12/2018 15:00	Sheffield - Farrell No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice,

and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.