

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	05/03/2019 04:00	05/03/2019 14:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may	Day: 2.5 hrs	Not required	Being	Project work
VIC	AusNet	06/03/2019 04:00	06/03/2019 14:00		require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Night: Not applicable		assessed	,
VIC	AusNet	07/03/2019 05:30	07/03/2019 17:00	Moorabool - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Local regulation raise and lower FCAS will be sourced within South Australia.  • When power transfer is from South Australia to Victoria, contingency lower FCAS will be sourced within SA.	Day: 2 hrs Night: Not applicable	Issued on 19/02/2019	Invoked	Maintenance
VIC	AusNet	09/03/2019 04:00	09/03/2019 14:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may	Day: 2.5 hrs	Not required	Being .	Project work
<u>vic</u>	AusNet	10/03/2019 04:00	10/03/2019 14:00		require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Night: Not applicable		assessed	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
VIC	AusNet	12/03/2019 04:00	12/03/2019 14:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 2.5 hrs	Not required	Being	Project work
VIC	AusNet	13/03/2019 04:00	13/03/2019 14:00	Normali redemin 220 NV LITE	Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night: Not applicable	Notrequired	assessed	rioject work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	16/03/2019 03:00	16/03/2019 15:00	Horsham - Redcliffs 220 kV Line	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	17/03/2019 03:00	17/03/2019 15:00	Horsham - Redcliffs 220 kV Line	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	19/03/2019 04:00	19/03/2019 14:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 2 hrs	Not required	Being	Project work
VIC	AusNet	20/03/2019 04:00	20/03/2019 14:00		Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night: Not applicable		assessed	Troject nonk
VIC	AusNet	22/03/2019 04:00	22/03/2019 14:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 2 hrs	Not required	Being	Project work
VIC	AusNet	23/03/2019 04:00	23/03/2019 14:00	Notice Received 220 KV Elic	Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night: Not applicable	Wotrequired	assessed	Troject work
NSW	Transgrid	25/03/2019 06:00	25/03/2019 15:00	Armidale - Tamworth (85) 330 kV Line	A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 1 hrs Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	01/04/2019 04:00	01/04/2019 14:00	Harsham - Radeliffs 220 W Lina	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C  A cradible contingency event during this planned outage may require:	Day: 2 hrs	Not required	Being	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	02/04/2019 04:00	02/04/2019 14:00	Horshall - Nedchils 220 NV Line	Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night: Not applicable	Not required	assessed	Froject work
VIC	AusNet	04/04/2019 05:30	04/04/2019 17:30	Ballarat - Waubra - Horsham 220	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 5 hrs	Not required	Being	Project work
VIC	AusNet	05/04/2019 05:30	05/04/2019 17:30	kV Line	Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night: No recall	Notrequired	assessed	Troject work
TAS	TasNetworks	05/04/2019 06:00	05/04/2019 12:00	Sheffield - Farrell No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1.5 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	06/04/2019 05:30	06/04/2019 17:30	Ballarat - Waubra - Horsham 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 5 hrs Night: No recall	Not required	Being assessed	Project work
VIC	AusNet	07/04/2019 06:00	07/04/2019 15:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 2 hrs	Not required	Being	Project work
VIC	AusNet	08/04/2019 06:00	08/04/2019 15:00		Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night: Not applicable	, , , , , , , , , , , , , , , , , , , ,	assessed	
VIC	AusNet	09/04/2019 06:00	09/04/2019 15:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	12/04/2019 06:00	12/04/2019 15:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may	Day: 2 hrs	Not required	Being	Project work
VIC	AusNet	13/04/2019 06:00	13/04/2019 15:00	Horsianii - Nedcinis 220 KV Line	require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Night: Not applicable	NotTequired	assessed	Project work
VIC	AusNet	15/04/2019 06:00	15/04/2019 15:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 2 hrs	Not required	Being	Project work
VIC	AusNet	16/04/2019 06:00	16/04/2019 15:00	Horsianii - Redcinis 220 KV Line	Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night: Not applicable	NotTequired	assessed	Project work
VIC	AusNet	30/04/2019 06:00	30/04/2019 14:00	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN.  This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C  A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Project work
VIC	AusNet	01/05/2019 06:00	01/05/2019 14:00	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	03/05/2019 06:00	03/05/2019 14:00	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	03/05/2019 07:00	03/05/2019 17:00	Crowland - Horsham 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 4 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	04/05/2019 06:00	04/05/2019 14:00	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	04/05/2019 07:00	04/05/2019 17:00	Crowland - Horsham 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 4 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	05/05/2019 07:00	05/05/2019 17:00	Crowland - Horsham 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 4 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	06/05/2019 06:00	06/05/2019 14:00	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	06/05/2019 07:00	06/05/2019 17:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	07/05/2019 06:00	07/05/2019 14:00	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	07/05/2019 07:00	07/05/2019 17:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 4 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	08/05/2019 07:00	08/05/2019 17:00		Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night. Not applicable		assesseu	
VIC	AusNet	09/05/2019 06:00	09/05/2019 15:00	Red Cliffs-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	10/05/2019 06:00	10/05/2019 14:00	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	10/05/2019 06:00	10/05/2019 15:00	Red Cliffs-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C  A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	11/05/2019 06:00	11/05/2019 14:00	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	12/05/2019 06:00	12/05/2019 15:00	Red Cliffs-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	13/05/2019 06:00	13/05/2019 15:00		Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	<b>6</b>			
VIC	AusNet	16/05/2019 06:00	16/05/2019 15:00	Red Cliffs-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	18/05/2019 06:00	18/05/2019 15:00	Red Cliffs-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may	Day: 2 hrs	Not required	Being	Project work
VIC	AusNet	19/05/2019 06:00	19/05/2019 15:00	Neu Cilis-Weilen 220kV Line	require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Night: Not applicable	Not required	assessed	rioject work
VIC	AusNet	21/05/2019 06:00	21/05/2019 14:00	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	21/05/2019 06:00	21/05/2019 15:00	Rad Cliffs_Waman 220W/IINF	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may	Day: 2 hrs	Not required	Being	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	22/05/2019 06:00	22/05/2019 15:00	NEW CHILD WERREN ZZOKY EINE	require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Night: Not applicable	Notreganea	assessed	Troject work
VIC	AusNet	24/05/2019 06:00	24/05/2019 15:00	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	24/05/2019 06:00	24/05/2019 15:00	Red Cliffs-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	25/05/2019 06:00	25/05/2019 14:00	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	25/05/2019 06:00	25/05/2019 15:00	Red Cliffs-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	27/05/2019 06:00	27/05/2019 15:00	Red Cliffs-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	28/05/2019 06:00	28/05/2019 14:00	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	30/05/2019 06:00	30/05/2019 15:00	Red Cliffs-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
<u>VIC</u>	AusNet	31/05/2019 06:00	31/05/2019 14:00	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	31/05/2019 07:00	31/05/2019 17:00		This is a high-impact outage only if the forecast temperature at Red				
VIC	AusNet	01/06/2019 07:00	01/06/2019 17:00	Horsham - Redcliffs 220 kV Line	Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid	Day: 4 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	02/06/2019 07:00	02/06/2019 17:00		Market intervention through issuing of directions.				
VIC	AusNet	03/06/2019 06:00	03/06/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	03/06/2019 07:00	03/06/2019 17:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 4 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	04/06/2019 06:00	04/06/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	04/06/2019 07:00	04/06/2019 17:00	Horsham - Redcliffs 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 4 hrs	Not required	Being	Project work
<u>VIC</u>	AusNet	05/06/2019 07:00	05/06/2019 17:00	TO SHAFT RECEIRS 220 KV EITE	Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night: Not applicable	Notreguired	assessed	Troject work
VIC	AusNet	06/06/2019 06:00	06/06/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	06/06/2019 06:00	06/06/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	07/06/2019 06:00	07/06/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	07/06/2019 06:00	07/06/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C  A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	09/06/2019 06:00	09/06/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 2 hrs	Not required	Being	Project work
VIC	AusNet	10/06/2019 06:00	10/06/2019 15:00		Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night: Not applicable	Notrequired	assessed	rrojest nork
VIC	AusNet	12/06/2019 06:00	12/06/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 2 hrs	Not required	Being	Project work
VIC	AusNet	13/06/2019 06:00	13/06/2019 15:00	Actually wellen 220AV Live	Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night: Not applicable	Notrequired	assessed	Troject work
VIC	AusNet	15/06/2019 06:00	15/06/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	16/06/2019 06:00	16/06/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	16/06/2019 06:00	16/06/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C  A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	17/06/2019 06:00	17/06/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	18/06/2019 06:00	18/06/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C  A credible contingency event during this planned outage may require:	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	19/06/2019 06:00	19/06/2019 15:00		Load shedding in the Victorian outer grid     Market intervention through issuing of directions.				
VIC	AusNet	20/06/2019 06:00	20/06/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
Kegion	Nor	Start	FIIIIŞII	Network asset	ппрасс	Necali tillie	Warket Hotice	Constraint	Outage reason
VIC	AusNet	21/06/2019 06:00	21/06/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	21/06/2019 06:00	21/06/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 2 hrs	Not required	Being	Project work
VIC	AusNet	22/06/2019 06:00	22/06/2019 15:00	_	Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night: Not applicable	Notrequired	assessed	rioject work
VIC	AusNet	23/06/2019 06:00	23/06/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	24/06/2019 06:00	24/06/2019 15:00	Korang Waman 220kk/ LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C  A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 2 hrs	Not required	Being	Project work
VIC	AusNet	25/06/2019 06:00	25/06/2019 15:00	•		Night: Not applicable	Not required	assessed	
VIC	AusNet	27/06/2019 06:00	27/06/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	27/06/2019 06:00	27/06/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C  A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	28/06/2019 06:00	28/06/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	28/06/2019 06:00	28/06/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C  A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	30/06/2019 06:00	30/06/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	30/06/2019 06:00	30/06/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	01/07/2019 06:00	01/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	01/07/2019 06:00	01/07/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	03/07/2019 06:00	03/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	04/07/2019 06:00	04/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	10/07/2019 06:00	10/07/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C	Day: 2 hrs Night: Not applicable	Not required	Being	Project work
VIC	AusNet	11/07/2019 06:00	11/07/2019 15:00	KCI GIIG WEITEH ZZUKV LINE	A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.			assessed	
VIC	AusNet	13/07/2019 06:00	13/07/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	14/07/2019 06:00	14/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	14/07/2019 06:00	14/07/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	15/07/2019 06:00	15/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	16/07/2019 06:00	16/07/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	17/07/2019 06:00	17/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	17/07/2019 06:00	17/07/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	18/07/2019 06:00	18/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	19/07/2019 06:00	19/07/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	20/07/2019 06:00	20/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	20/07/2019 06:00	20/07/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	21/07/2019 06:00	21/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	22/07/2019 06:00	22/07/2019 15:00	Karang-Waman 220W/ LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C  A credible contingency event during this planned outage may require:	Day: 2 hrs	Not required	Being	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	23/07/2019 06:00	23/07/2019 15:00	Kerang wemen 220kv Livi	Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night: Not applicable	Not required	assessed	Project work
VIC	AusNet	24/07/2019 06:00	24/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	25/07/2019 06:00	25/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	25/07/2019 06:00	25/07/2019 15:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 2 hrs	Not required	Being	Draiget work
VIC	AusNet	26/07/2019 06:00	26/07/2019 15:00	Kelang-Wellien 220kV Live	Load shedding in the Victorian outer grid     Market intervention through issuing of directions.	Night: Not applicable	Not required	assessed	Project work
VIC	AusNet	27/07/2019 06:00	27/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN.  This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C  A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	28/07/2019 06:00	28/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN.  This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C  A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	31/07/2019 06:00	31/07/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	01/08/2019 06:00	01/08/2019 14:00	Kerang-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	03/08/2019 06:00	03/08/2019 14:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C  A credible contingency event during this planned outage may require:  Load shedding in the Victorian outer grid  Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	04/08/2019 06:00	04/08/2019 14:00	Kerang-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work

#### Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice,

and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.