

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	11/11/2019 05:30 Monday	11/11/2019 17:00 Monday	Moorabool - Mortlake 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.	Day: 2 hrs Night: No recall	To be issued	Being assessed	Project work
VIC	AusNet	12/11/2019 05:30 Tuesday	12/11/2019 17:00 Tuesday	Widolabool - Widitiake 300 kV Lille	Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event.				
VIC	AusNet	13/11/2019 05:30 Wednesday	13/11/2019 17:00 Wednesday	Moorabool - Mortlake 500 kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2 hrs Night: No recall	To be issued	Being assessed	Project work
NSW / VIC	AusNet	17/11/2019 05:30 Sunday	17/11/2019 18:30 Sunday	Jindera - Wodonga (060) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
NSW / VIC	AusNet	18/11/2019 05:30 Monday	18/11/2019 18:30 Monday	Jindera - Wodonga (060) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink • Credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW / VIC	AusNet	19/11/2019 05:30 Tuesday	19/11/2019 18:30 Tuesday	Jindera - Wodonga (060) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink • Contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
TAS	TasNetworks	22/11/2019 09:00 Friday	22/11/2019 16:00 Friday	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	23/11/2019 07:00 Saturday	23/11/2019 17:00 Saturday	MuraWara-Red Cliffs 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C OkV LINE A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Invoked	Project work
VIC	AusNet	24/11/2019 07:00 Sunday	24/11/2019 17:00 Sunday						
VIC	AusNet	28/11/2019 08:00 Thursday	28/11/2019 14:00 Thursday	Ballarat - Waubra 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: Not applicable Night: Not applicable	Not required	Invoked	Maintenance
VIC	AusNet	14/12/2019 07:00 Saturday	14/12/2019 17:00 Saturday	MuraWara.Bad Cliffe 220NV LINF	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A cradible contingency event during this planned outage may require:	Day: 2 hrs	Not required	Invoked	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	15/12/2019 07:00 Sunday	15/12/2019 17:00 Sunday	Williams and Ciliis 220KV Line	Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Night: Not applicable	Notrequired	iiivoked	Trojece work
NSW / VIC	AusNet	25/12/2019 06:00 Wednesday	25/12/2019 16:00 Wednesday	Buronga - Redcliffs (OX1) 220 kV Line.	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: No recall Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	25/12/2019 06:00 Wednesday	25/12/2019 16:00 Wednesday	Red Cliffs-Wemen 220kV LINE	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.	Day: No recall Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	01/04/2020 07:00 Wednesday	01/04/2020 17:00 Wednesday	Bendigo – Kerang 220 kV line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	06/04/2020 07:00 Monday	10/04/2020 17:00 Friday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work
VIC	AusNet	13/04/2020 07:00 Monday	17/04/2020 17:00 Friday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
QLD	Powerlink	27/04/2020 07:00 Monday	30/10/2020 17:00 Friday	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	12/05/2020 06:30 Tuesday	12/05/2020 17:00 Tuesday	Hazelwood - Rowville 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	19/05/2020 06:30 Tuesday	20/05/2020 17:00 Wednesday	Hazelwood - South Morang No.1 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could cause a large reduction in generation in Victoria.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	21/05/2020 06:30 Thursday	22/05/2020 17:00 Friday	Hazelwood - South Morang No.2 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could cause a large reduction in generation in Victoria.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	12/06/2020 07:00 Friday	12/06/2020 17:00 Friday	Moorabool - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event.	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	14/07/2020 07:00 Tuesday	15/07/2020 17:00 Wednesday	Rowville - South Morang 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
QLD	Powerlink	14/07/2020 08:00 Tuesday	14/07/2020 11:25 Tuesday	Ross No.2 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	16/07/2020 07:00 Thursday	17/07/2020 17:00 Friday	Keilor - South Morang 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	23/07/2020 07:00 Thursday	24/07/2020 17:00 Friday	South Morang - Sydenham No.2 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	28/07/2020 07:00 Tuesday	28/07/2020 17:00 Tuesday	Moorabool–Sydenham No.1 500 kV Line	This is a high-impact outage only if the Emergency Moorabool Transformer Trip (EMTT) scheme remains activated. A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance



Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	29/07/2020 07:00 Wednesday	30/07/2020 17:00 Thursday	Moorabool–Sydenham No.2 500 kV Line	This is a high-impact outage only if the Emergency Moorabool Transformer Trip (EMTT) scheme remains activated. A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice,

and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.