

Degion	NCD	Chart	Finish	Network asset	lunnat	Decell time	Market notice	Constraint	Outons read
Region	NSP	Start	Finish	Network asset	Impact	Recall time	warket notice	constraint	Outage reason
QLD	Powerlink	21/04/2020 07:30 Tuesday	21/04/2020 17:00 Tuesday	Ross No.3 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 30 mins Night: Not applicable	Not required	Not required	Maintenance
QLD	Powerlink	22/04/2020 08:30 Wednesday	22/04/2020 15:00 Wednesday	Ross No.3 288/138/19 kV Transformer	This outage has been WITHDRAWN. This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 30 mins Night: Not applicable	Not required	Being assessed	Maintenance
NSW / VIC	AusNet	05/05/2020 06:00 Tuesday	05/05/2020 19:00 Tuesday	Jindera - Wodonga (060) 330 kV Line	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
NSW / VIC	AusNet	06/05/2020 06:00 Wednesday	06/05/2020 19:00 Wednesday	Jindera - Wodonga (060) 330 kV Line	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: No recall Night: No recall	Not required	Being assessed	Maintenance



Pagion	NSP	Start	Finish	Network asset	Impact	Recall time	Market netice	Constraint	Outage reason
Region	NSP	Start	FINISN	Network asset	impact	Kecali time	warket notice	constraint	Outage reason
NSW / VIC	AusNet	07/05/2020 06:00 Thursday	07/05/2020 19:00 Thursday	Jindera - Wodonga (060) 330 kV Line	 This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
NSW / VIC	AusNet	08/05/2020 06:00 Friday	08/05/2020 19:00 Friday	Jindera - Wodonga (060) 330 kV Line	 This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
NSW / VIC	AusNet	09/05/2020 06:00 Saturday	09/05/2020 19:00 Saturday	Jindera - Wodonga (060) 330 kV Line	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: No recall Night: No recall	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW / VIC	AusNet	10/05/2020 06:00 Sunday	10/05/2020 19:00 Sunday	Jindera - Wodonga (060) 330 kV Line	 This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
NSW / VIC	AusNet	11/05/2020 06:00 Monday	11/05/2020 19:00 Monday	Jindera - Wodonga (060) 330 kV Line	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
NSW / VIC	AusNet	12/05/2020 06:00 Tuesday	12/05/2020 19:00 Tuesday	Jindera - Wodonga (060) 330 kV Line	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	12/05/2020 06:30 Tuesday	12/05/2020 17:00 Tuesday	Hazelwood - Rowville 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Invoked	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	13/05/2020 06:00 Wednesday	13/05/2020 18:00 Wednesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW / VIC	AusNet	13/05/2020 06:00 Wednesday	13/05/2020 19:00 Wednesday	Jindera - Wodonga (060) 330 kV Line	 This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	14/05/2020 06:00 Thursday	14/05/2020 18:00 Thursday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW / VIC	AusNet	14/05/2020 06:00 Thursday	14/05/2020 19:00 Thursday	Jindera - Wodonga (060) 330 kV Line	This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	15/05/2020 06:00 Friday	15/05/2020 18:00 Friday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
Negion	NJF	Jan	FIIIIƏII	NCLWUIN ASSEL	impact	Necali time	market notice	Constraille	Sulage reason
NSW / VIC	AusNet	15/05/2020 06:00 Friday	15/05/2020 19:00 Friday	Jindera - Wodonga (060) 330 kV Line	 This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
NSW / VIC	AusNet	16/05/2020 06:00 Saturday	16/05/2020 19:00 Saturday	Jindera - Wodonga (060) 330 kV Line	 This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
NSW / VIC	AusNet	17/05/2020 06:00 Sunday	17/05/2020 19:00 Sunday	Jindera - Wodonga (060) 330 kV Line	 This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: No recall Night: No recall	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW / VIC	AusNet	18/05/2020 06:00 Monday	18/05/2020 19:00 Monday	Jindera - Wodonga (060) 330 kV Line	 This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	19/05/2020 06:30 Tuesday	19/05/2020 17:00 Tuesday	Hazelwood - South Morang No.1 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could cause a large reduction in generation in Victoria.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	20/05/2020 06:30 Wednesday	20/05/2020 17:00 Wednesday	Hazelwood - South Morang No.1 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could cause a large reduction in generation in Victoria.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	21/05/2020 06:30 Thursday	21/05/2020 17:00 Thursday	Hazelwood - South Morang No.2 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could cause a large reduction in generation in Victoria.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	22/05/2020 06:30 Friday	22/05/2020 17:00 Friday	Hazelwood - South Morang No.2 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could cause a large reduction in generation in Victoria.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
SA	ElectraNet	25/05/2020 09:30 Monday	25/05/2020 16:30 Monday		A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 8 hrs Night: Not applicable	To be issued	Invoked	Maintenance
QLD	Powerlink	01/06/2020 08:30 Monday	01/06/2020 16:00 Monday	Strathmore - Ross (8858) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 30 mins Night: Not applicable	Not required	Being assessed	Maintenance
SA	ElectraNet	18/06/2020 08:45 Thursday	18/06/2020 15:30 Thursday	Cherry Gardens - Tailem Bend 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Maintenance
SA	ElectraNet	19/06/2020 08:45 Friday	19/06/2020 15:30 Friday	Cherry Gardens - Tailem Bend 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: Initiate the orderly separation of SA from the rest of the NEM. Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
QLD	Powerlink	06/07/2020 07:00 Monday	14/07/2020 17:00 Tuesday	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	14/07/2020 07:00 Tuesday	14/07/2020 17:00 Tuesday	Rowville - South Morang 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
QLD	Powerlink	14/07/2020 08:00 Tuesday	14/07/2020 11:25 Tuesday	Ross No.2 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	15/07/2020 07:00 Wednesday	15/07/2020 17:00 Wednesday	Rowville - South Morang 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	16/07/2020 07:00 Thursday	16/07/2020 17:00 Thursday	Keilor - South Morang 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	17/07/2020 07:00 Friday	17/07/2020 17:00 Friday	Keilor - South Morang 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
SA	ElectraNet	17/07/2020 09:00 Friday	19/07/2020 17:30 Sunday	Tailem Bend - South East No.1 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 3 hrs Night: 6 hrs	To be issued	Being assessed	Maintenance
VIC	AusNet	23/07/2020 07:00 Thursday	23/07/2020 17:00 Thursday	South Morang - Sydenham No.2 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	24/07/2020 07:00 Friday	24/07/2020 17:00 Friday	South Morang - Sydenham No.2 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	28/07/2020 07:00 Tuesday	28/07/2020 17:00 Tuesday	Moorabool–Sydenham No.1 500 kV Line	This is a high-impact outage only if the Emergency Moorabool Transformer Trip (EMTT) scheme remains activated. A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	29/07/2020 07:00 Wednesday	29/07/2020 17:00 Wednesday	Moorabool–Sydenham No.2 500 kV Line	This is a high-impact outage only if the Emergency Moorabool Transformer Trip (EMTT) scheme remains activated. A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance



Desire	NCD	Chant	Finish	Not work a sect	lucco et	De sell times	Maulasturat	Countries: 1	0
Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	30/07/2020 07:00 Thursday	30/07/2020 17:00 Thursday	Moorabool–Sydenham No.2 500 kV Line	This is a high-impact outage only if the Emergency Moorabool Transformer Trip (EMTT) scheme remains activated. A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
NSW / VIC	AusNet	03/08/2020 09:00 Monday	03/08/2020 19:00 Monday						
NSW / VIC	AusNet	04/08/2020 09:00 Tuesday	04/08/2020 19:00 Tuesday	Jindera - Wodonga (060) 330 kV	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales.	Day: No recall	Not required	Invoked	Project work
NSW / VIC	AusNet	05/08/2020 09:00 Wednesday	05/08/2020 19:00 Wednesday	Line	 Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Night: No recall		mokeu	. TOJECE WORK
NSW / VIC	AusNet	06/08/2020 09:00 Thursday	06/08/2020 19:00 Thursday						
NSW / VIC	Transgrid	06/08/2020 09:00 Thursday	06/08/2020 19:00 Thursday	Jindera - Wodonga (060) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 10 hrs Night: No recall	Not required	Being assessed	Maintenance



Newly added outage Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
SA	ElectraNet	14/08/2020 09:00 Friday	16/08/2020 17:30 Sunday	Tailem Bend - South East No.2 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 3 hrs Night: 6 hrs	To be issued	Being assessed	Maintenance
QLD	Powerlink	05/10/2020 07:00 Monday	16/10/2020 17:00 Friday	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 72 hrs Night: 96 hrs	Not required	Being assessed	Maintenance
QLD	Powerlink	01/07/2021 07:00 Thursday	18/08/2021 17:00 Wednesday	Stanwell - Broadsound (856) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may result in shedding Far North QLD load and Lilyvale local load. Following a credible contingency market intervention through issuing of directions may be required. If market intervention is unsuccessful all of North QLD load would be in a credible risk	Day: 8 hrs Night: 12 hrs	Not required	Being assessed	Maintenance

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice,

and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and

- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.