

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	18/05/2020 07:00 Monday	18/05/2020 18:00 Monday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	19/05/2020 06:00 Tuesday	19/05/2020 18:00 Tuesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
VIC	AusNet	19/05/2020 07:00 Tuesday	19/05/2020 16:00 Tuesday	Hazelwood - South Morang No.1 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could cause a large reduction in generation in Victoria.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
<u>NSW</u>	Transgrid	20/05/2020 06:00 Wednesday	20/05/2020 18:00 Wednesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
VIC	AusNet	20/05/2020 07:00 Wednesday	20/05/2020 16:00 Wednesday	Hazelwood - South Morang No.1 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW  A credible contingency event during this planned outage could cause a large reduction in generation in Victoria.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
NSW	Transgrid	21/05/2020 06:00 Thursday	21/05/2020 18:00 Thursday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
VIC	AusNet	21/05/2020 06:30 Thursday	21/05/2020 17:00 Thursday	Hazelwood - South Morang No.2 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW  A credible contingency event during this planned outage could cause a large reduction in generation in Victoria.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
NSW	Transgrid	22/05/2020 06:00 Friday	22/05/2020 18:00 Friday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
VIC	AusNet	22/05/2020 06:30 Friday	22/05/2020 17:00 Friday	Hazelwood - South Morang No.2 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW  A credible contingency event during this planned outage could cause a large reduction in generation in Victoria.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
NSW	Transgrid	23/05/2020 06:00 Saturday	23/05/2020 18:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	25/05/2020 06:00 Monday	25/05/2020 18:00 Monday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
SA	ElectraNet	25/05/2020 09:30 Monday	25/05/2020 16:30 Monday		A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  Initiate the orderly separation of SA from the rest of the NEM.  Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 8 hrs Night: Not applicable	To be issued	Invoked	Maintenance
NSW	Transgrid	25/05/2020 10:00 Monday	25/05/2020 16:00 Monday	Balranald Buronga X3 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C During this planned outage power transfer will be restricted  • Between Victoria and New South Wales.  • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	25/05/2020 10:00 Monday	25/05/2020 16:00 Monday	Balranald-Darlington Point (X5) 220 kV line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C During this planned outage power transfer will be restricted  • Between Victoria and New South Wales.  • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 1.5 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	26/05/2020 06:00 Tuesday	26/05/2020 18:00 Tuesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	27/05/2020 06:00 Wednesday	27/05/2020 18:00 Wednesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	28/05/2020 06:00 Thursday	28/05/2020 18:00 Thursday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	29/05/2020 06:00 Friday	29/05/2020 18:00 Friday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	30/05/2020 06:00 Saturday	30/05/2020 18:00 Saturday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	01/06/2020 06:00 Monday	01/06/2020 18:00 Monday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
QLD	Powerlink	01/06/2020 08:30 Monday	01/06/2020 16:00 Monday	Strathmore - Ross (8858) 275 kV Line	This outage has been WITHDRAWN. This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 30 mins Night: Not applicable	Not required	Being assessed	Maintenance
NSW	Transgrid	02/06/2020 06:00 Tuesday	02/06/2020 18:00 Tuesday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	03/06/2020 06:00 Wednesday	03/06/2020 18:00 Wednesday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	04/06/2020 06:00 Thursday	04/06/2020 18:00 Thursday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	05/06/2020 06:00 Friday	05/06/2020 18:00 Friday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	06/06/2020 06:00 Saturday	06/06/2020 18:00 Saturday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	09/06/2020 06:00 Tuesday	09/06/2020 18:00 Tuesday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	09/06/2020 07:00 Tuesday	13/06/2020 16:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	This outage has been WITHDRAWN.  A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: 4 hrs	Not required	Invoked	Maintenance
NSW	Transgrid	10/06/2020 06:00 Wednesday	10/06/2020 18:00 Wednesday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Project work
NSW	Transgrid	11/06/2020 06:00 Thursday	11/06/2020 18:00 Thursday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Project work
VIC	AusNet	11/06/2020 07:30 Thursday	11/06/2020 16:00 Thursday	Keilor – Sydenham 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW  A credible contingency event during this planned outage could:  Cause a large reduction in generation in Victoria  Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: Not applicable Night: Not applicable	Not required	Invoked	Maintenance
NSW	Transgrid	12/06/2020 06:00 Friday	12/06/2020 18:00 Friday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	13/06/2020 06:00 Saturday	13/06/2020 18:00 Saturday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	15/06/2020 06:00 Monday	15/06/2020 18:00 Monday	Tamworth Liddell PS (84) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Project work
NSW	Transgrid	15/06/2020 07:00 Monday	20/06/2020 16:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	This outage has been WITHDRAWN.  A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: 4 hrs	Not required	Invoked	Maintenance
NSW	Transgrid	16/06/2020 06:00 Tuesday	16/06/2020 18:00 Tuesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Project work
NSW	Transgrid	17/06/2020 06:00 Wednesday	17/06/2020 18:00 Wednesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Project work
NSW	Transgrid	18/06/2020 06:00 Thursday	18/06/2020 18:00 Thursday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Project work
<u>NSW</u>	Transgrid	19/06/2020 06:00 Friday	19/06/2020 18:00 Friday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Project work
NSW	Transgrid	20/06/2020 06:00 Saturday	20/06/2020 18:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Project work
NSW	Transgrid	22/06/2020 06:00 Monday	22/06/2020 18:00 Monday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Project work
NSW	Transgrid	23/06/2020 06:00 Tuesday	23/06/2020 18:00 Tuesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	24/06/2020 06:00 Wednesday	24/06/2020 18:00 Wednesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Project work
QLD	Powerlink	06/07/2020 07:00 Monday	14/07/2020 17:00 Tuesday		This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: No recall Night: No recall	Not required	Being assessed	Maintenance
SA	ElectraNet	06/07/2020 08:45 Monday	06/07/2020 15:30 Monday	Cherry Gardens - Tailem Bend 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  Initiate the orderly separation of SA from the rest of the NEM.  Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 4 hrs Night: Not applicable	To be issued	Being assessed	Maintenance
SA	ElectraNet	07/07/2020 08:45 Tuesday	07/07/2020 15:30 Tuesday	Cherry Gardens - Tailem Bend 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  Initiate the orderly separation of SA from the rest of the NEM.  Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Maintenance
VIC	AusNet	14/07/2020 07:00 Tuesday	14/07/2020 17:00 Tuesday	Rowville - South Morang 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW  A credible contingency event during this planned outage could:  Cause a large reduction in generation in Victoria  Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
QLD	Powerlink	14/07/2020 08:00 Tuesday	14/07/2020 11:25 Tuesday	Ross No.2 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	15/07/2020 07:00 Wednesday	15/07/2020 17:00 Wednesday	Rowville - South Morang 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW  A credible contingency event during this planned outage could:  Cause a large reduction in generation in Victoria  Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	16/07/2020 07:00 Thursday	16/07/2020 17:00 Thursday	Keilor - South Morang 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW  A credible contingency event during this planned outage could:  Cause a large reduction in generation in Victoria  Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	17/07/2020 07:00 Friday	17/07/2020 17:00 Friday	Keilor - South Morang 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW  A credible contingency event during this planned outage could:  Cause a large reduction in generation in Victoria  Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
SA	ElectraNet	17/07/2020 09:00 Friday	19/07/2020 17:30 Sunday	Tailem Bend - South East No.1 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  Initiate the orderly separation of SA from the rest of the NEM.  Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 3 hrs Night: 6 hrs	To be issued	Being assessed	Maintenance
QLD	Powerlink	22/07/2020 08:30 Wednesday	22/07/2020 14:00 Wednesday	Ross No.3 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	23/07/2020 07:00 Thursday	23/07/2020 17:00 Thursday	South Morang - Sydenham No.2 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	24/07/2020 07:00 Friday	24/07/2020 17:00 Friday	South Morang - Sydenham No.2 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW  A credible contingency event during this planned outage could:  Cause a large reduction in generation in Victoria  Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	28/07/2020 07:00 Tuesday	28/07/2020 17:00 Tuesday	Moorabool–Sydenham No.1 500 kV Line	This is a high-impact outage only if the Emergency Moorabool Transformer Trip (EMTT) scheme remains activated. A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	29/07/2020 07:00 Wednesday	29/07/2020 17:00 Wednesday	Moorabool–Sydenham No.2 500 kV Line	This is a high-impact outage only if the Emergency Moorabool Transformer Trip (EMTT) scheme remains activated. A credible contingency event during this planned outage could cause:  • A large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	30/07/2020 07:00 Thursday	30/07/2020 17:00 Thursday	Moorabool–Sydenham No.2 500 kV Line	This is a high-impact outage only if the Emergency Moorabool Transformer Trip (EMTT) scheme remains activated. A credible contingency event during this planned outage could cause:  • A large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
NSW / VIC	AusNet AusNet	03/08/2020 09:00 Monday 04/08/2020 09:00 Tuesday	03/08/2020 19:00 Monday 04/08/2020 19:00 Tuesday	Jindera - Wodonga (060) 330 kV	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer	Day: No recall	Not required	Invoked	Project work



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW / VIC	AusNet	05/08/2020 09:00 Wednesday	05/08/2020 19:00 Wednesday	Line	Between South Australia and Victoria on Murraylink     A credible contingency event during this planned outage may require:	Night: No recall	Not required	mvoked	r roject work
NSW / VIC	AusNet	06/08/2020 09:00 Thursday	06/08/2020 19:00 Thursday		<ul> <li>Load shedding in the Victorian outer grid</li> <li>Market intervention through issuing of directions.</li> </ul>				
NSW / VIC	Transgrid	06/08/2020 09:00 Thursday	06/08/2020 19:00 Thursday	Jindera - Wodonga (060) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer  • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 10 hrs Night: No recall	Not required	Being assessed	Maintenance
SA	ElectraNet	14/08/2020 09:00 Friday	16/08/2020 17:30 Sunday	Tailem Bend - South East No.2 275 kV Line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  Initiate the orderly separation of SA from the rest of the NEM.  Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 3 hrs Night: 6 hrs	To be issued	Being assessed	Maintenance
VIC	AusNet	05/10/2020 07:00 Monday	05/10/2020 17:00 Monday	Moorabool-HGTS 500kV no 1 LINE	N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 4 hrs Night: No recall	Not required	Being assessed	Project work
QLD	Powerlink	05/10/2020 07:00 Monday	16/10/2020 17:00 Friday	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 72 hrs Night: 96 hrs	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	06/10/2020 07:00	06/10/2020 17:00						
VIC	Addite	Tuesday	Tuesday						
VIC	AusNet	07/10/2020 07:00	07/10/2020 17:00		N/A				
		Wednesday	Wednesday		N/A A credible contingency event during this planned outage could cause				
VIC	AusNet	08/10/2020 07:00 Thursday	08/10/2020 17:00 Thursday		synchronous separation of the South Australia region from the rest of				
		09/10/2020 07:00	09/10/2020 17:00		the NEM.	Day: 4 hrs		Being	
VIC	AusNet	Friday	Friday	Moorabool-HGTS 500kV no 1 LINE	During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia	Night: No recall	Not required	assessed	Project work
VIC	AusNet	10/10/2020 07:00	10/10/2020 17:00		interconnector (Heywood interconnector).				
VIC	Ausnet	Saturday	Saturday		Post contingent FCAS will be sourced within SA following Separation				
VIC	AusNet	11/10/2020 07:00	11/10/2020 17:00		event.				
VIC	Addite	Sunday	Sunday						
VIC	AusNet	12/10/2020 07:00	12/10/2020 17:00						
		Monday	Monday						
VIC	AusNet	19/10/2020 07:00 Monday	19/10/2020 17:00 Monday						
		20/10/2020 07:00	20/10/2020 17:00						
VIC	AusNet	Tuesday	Tuesday						
		21/10/2020 07:00	21/10/2020 17:00		A credible contingency event during this planned outage could cause				
VIC	AusNet	Wednesday	Wednesday		synchronous separation of the South Australia region from the rest of				
VIC	AusNet	22/10/2020 07:00	22/10/2020 17:00		the NEM.				
VIC	Ausivet	Thursday	Thursday	Moorabool - Mortlake 500 kV line	During this planned outage:	Day: 4 hrs	Not required	Being	Project work
VIC	AusNet	23/10/2020 07:00	23/10/2020 17:00	moorabee moralane see kv iiile	Power transfer will be restricted across the Victoria - South Australia	Night: No recall	. rocrequired	assessed	. rojece work
_		Friday	Friday		interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation				
VIC	AusNet	24/10/2020 07:00	24/10/2020 17:00		event.				
		Saturday 25/10/2020 07:00	Saturday						
VIC	AusNet	Sunday	25/10/2020 17:00 Sunday						
		26/10/2020 07:00	26/10/2020 17:00						
VIC	AusNet	Monday	Monday						
VIC	AusNet	12/04/2021 07:00	12/04/2021 17:00						
VIC	Ausnet	Monday	Monday						
VIC	AusNet	13/04/2021 07:00	13/04/2021 17:00						
*10	71031100	Tuesday	Tuesday						
VIC	AusNet	14/04/2021 07:00	14/04/2021 17:00		This is a high-impact outage only if the forecast temperature at Red				
		Wednesday	Wednesday		Cliffs is greater than 30 °C	David 2 has		Daine	
VIC	AusNet	15/04/2021 07:00 Thursday	15/04/2021 17:00 Thursday	Red Cliffs-Wemen 220kV LINE	A credible contingency event during this planned outage may require:	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
		16/04/2021 07:00	16/04/2021 17:00		Load shedding in the Victorian outer grid	Mante Not applicable		ussesseu	
VIC	AusNet	Friday	16/04/2021 17:00 Friday		Market intervention through issuing of directions.				
		,	,						



Newly added outage
Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	17/04/2021 07:00 Saturday	17/04/2021 17:00 Saturday						
VIC	AusNet	18/04/2021 07:00 Sunday	18/04/2021 17:00 Sunday						
VIC	AusNet	24/05/2021 07:00 Monday	24/05/2021 17:00 Monday						
VIC	AusNet	25/05/2021 07:00 Tuesday	25/05/2021 17:00 Tuesday						
VIC	AusNet	26/05/2021 07:00 Wednesday	26/05/2021 17:00 Wednesday		This is a high-impact outage only if the forecast temperature at Red				
VIC	AusNet	27/05/2021 07:00 Thursday	27/05/2021 17:00 Thursday	Kerang-Wemen 220kV LINE	Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	28/05/2021 07:00 Friday	28/05/2021 17:00 Friday						
VIC	AusNet	29/05/2021 07:00 Saturday	29/05/2021 17:00 Saturday						
VIC	AusNet	30/05/2021 07:00 Sunday	30/05/2021 17:00 Sunday						
QLD	Powerlink	01/07/2021 07:00 Thursday	18/08/2021 17:00 Wednesday	Stanwell – Broadsound 856 or 8831	This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may result in shedding Far North QLD load and Lilyvale local load.  Following a credible contingency market intervention through issuing of directions may be required. If market intervention is unsuccessful all of North QLD load would be in a credible risk	Day: 8 hrs Night: 12 hrs	Not required	Being assessed	Maintenance

#### Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice,

and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.