

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	10/08/2020 07:00 Monday	10/08/2020 18:00 Monday	Muswellbrook - Tamworth (88) 330 kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	11/08/2020 07:00 Tuesday	11/08/2020 18:00 Tuesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
VIC	AusNet	11/08/2020 08:30 Tuesday	11/08/2020 16:00 Tuesday	Dederang - Wodonga 330 kV Line	This is a high-impact outage if the forecast temperature at Red Cliffs is greater than 30 deg. C. This line outage offloads X5 220 kV line. Possible load shedding and risk of large reduction in generation in NSW and interconnector capacity between NSW - Victoria following a credible contingency	Day: 2 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	12/08/2020 07:00 Wednesday	12/08/2020 18:00 Wednesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW / VIC	Transgrid	12/08/2020 10:00 Wednesday	12/08/2020 17:30 Wednesday	Jindera - Wodonga (060) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: No recall	Not required	Invoked	0
NSW	Transgrid	13/08/2020 07:00 Thursday	13/08/2020 18:00 Thursday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	14/08/2020 07:00 Friday	14/08/2020 18:00 Friday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	14/08/2020 08:00 Friday	14/08/2020 13:00 Friday	Keilor - South Morang 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 2 hrs Night: No recall	Not required	Invoked	Maintenance
SA	ElectraNet	14/08/2020 09:00 Friday	16/08/2020 17:30 Sunday		A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 3 hrs Night: 6 hrs	lssued on 16/07/2020	Invoked	Maintenance
NSW	Transgrid	15/08/2020 07:00 Saturday	15/08/2020 18:00 Saturday	kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	16/08/2020 11:00 Sunday	16/08/2020 16:00 Sunday	Armidale - Tamworth (86) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 2 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	17/08/2020 06:30 Monday	17/08/2020 18:00 Monday	KV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 5 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	17/08/2020 07:00 Monday	22/08/2020 18:00 Saturday	kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	18/08/2020 06:30 Tuesday	18/08/2020 18:00 Tuesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 5 hrs Night: No recall	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	19/08/2020 06:30 Wednesday	19/08/2020 18:00 Wednesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 5 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	19/08/2020 10:00 Wednesday	19/08/2020 16:00 Wednesday	Balranald-Darlington Point (X5) 220 kV line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C During this planned outage power transfer will be restricted • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 1.5 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	19/08/2020 10:00 Wednesday	19/08/2020 16:00 Wednesday	Balranald Buronga X3 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C During this planned outage power transfer will be restricted • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	20/08/2020 06:30 Thursday	20/08/2020 18:00 Thursday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 5 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	21/08/2020 06:30 Friday	21/08/2020 18:00 Friday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 5 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	22/08/2020 06:30 Saturday	22/08/2020 18:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 5 hrs Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	23/08/2020 07:00 Sunday	23/08/2020 18:00 Sunday	Red Cliffs-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	24/08/2020 06:30 Monday	24/08/2020 18:00 Monday		A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	24/08/2020 06:30 Monday	29/08/2020 18:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	This outage has been WITHDRAWN. A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	24/08/2020 07:00 Monday	24/08/2020 18:00 Monday	Red Cliffs-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
NSW	Transgrid	25/08/2020 06:30 Tuesday	25/08/2020 18:00 Tuesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	25/08/2020 07:00 Tuesday	25/08/2020 17:00 Tuesday	Red Cliffs-Wemen 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
NSW	Transgrid	26/08/2020 06:30 Wednesday	26/08/2020 18:00 Wednesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	27/08/2020 06:30 Thursday	27/08/2020 18:00 Thursday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	27/08/2020 07:00 Thursday	27/08/2020 17:00 Thursday	Ballarat - Waubra 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Invoked	Maintenance



Destan	NCD	Chart	r ia ia h	Notice and a sector	lucca at	De cell time e	Manhat wat:	Countral :	0
Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	constraint	Outage reason
NSW	Transgrid	28/08/2020 06:30 Friday	28/08/2020 18:00 Friday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	29/08/2020 06:30 Saturday	29/08/2020 18:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	31/08/2020 06:30 Monday	05/09/2020 18:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
TAS	TasNetworks	31/08/2020 09:00 Monday	31/08/2020 15:00 Monday	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 30 mins Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	31/08/2020 15:00 Monday	31/08/2020 16:00 Monday	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 30 mins Night: Not applicable	Not required	Being assessed	Maintenance
TAS	TasNetworks	01/09/2020 13:00 Tuesday	01/09/2020 13:30 Tuesday	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 30 mins Night: Not applicable	Not required	Being assessed	Maintenance
TAS	TasNetworks	02/09/2020 09:00 Wednesday	02/09/2020 11:00 Wednesday	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 30 mins Night: Not applicable	Not required	Invoked	Maintenance
TAS	TasNetworks	02/09/2020 13:00 Wednesday	02/09/2020 14:00 Wednesday	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 30 mins Night: Not applicable	Not required	Being assessed	Maintenance
NSW	Transgrid	07/09/2020 06:30 Monday	12/09/2020 18:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
QLD	Powerlink	07/09/2020 08:30 Monday	07/09/2020 15:00 Monday	Strathmore - Ross (8858) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance
QLD	Powerlink	07/09/2020 11:30 Monday	07/09/2020 15:00 Monday	Ross No.4 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
Region	1451	Start	1 111311	Network asset	This is a high-impact outage if the forecast temperature at Red Cliffs is	Necan time	market notice	constrailt	Catage reason
VIC	AusNet	16/09/2020 07:00 Wednesday	17/09/2020 17:00 Thursday	Dederang - Wodonga 330 kV Line	rins is a high-hipact outage in the forecast temperature at red clinis is greater than 30 deg. C. This line outage offloads X5 220 kV line. Possible load shedding and risk of large reduction in generation in NSW and interconnector capacity between NSW - Victoria following a credible contingency	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	22/09/2020 07:00 Tuesday	22/09/2020 17:00 Tuesday	Hazelwood - Loy Yang Power Station No.1 500 kV Line	A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Load shedding in Victoria	Day: 8 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	22/09/2020 07:00 Tuesday	22/09/2020 17:00 Tuesday	Ballarat - Waubra 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	23/09/2020 07:00 Wednesday	23/09/2020 17:00 Wednesday						
VIC	AusNet	24/09/2020 07:00 Thursday	24/09/2020 17:00 Thursday	Hazelwood - Loy Yang Power Station No.1 500 kV Line	 A credible contingency event during this planned outage could cause: A large reduction in generation in Victoria Load shedding in Victoria 	Day: 8 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	25/09/2020 07:00 Friday	25/09/2020 17:00 Friday						
VIC	AusNet	03/10/2020 06:00 Saturday	03/10/2020 18:00 Saturday						
VIC	AusNet	04/10/2020 05:00 Sunday	04/10/2020 17:00 Sunday	Hazelwood Terminal Station - Loy Yang Power Station 500 kV line	 A credible contingency event during this planned outage could cause: A large reduction in generation in Victoria Load shedding in Victoria 	Day: 4 hrs Night: Not applicable	To be issued	Being assessed	Maintenance
VIC	AusNet	05/10/2020 05:00 Monday	05/10/2020 15:00 Monday						
QLD	Powerlink	05/10/2020 07:00 Monday	16/10/2020 17:00 Friday	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 72 hrs Night: 96 hrs	Not required	Being assessed	Maintenance
VIC	AusNet	06/10/2020 07:15 Tuesday	06/10/2020 14:00 Tuesday	Hazelwood Terminal Station - Loy Yang Power Station 500 kV line	A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Load shedding in Victoria	Day: 2 hrs Night: No recall	Not required	Invoked	Maintenance
VIC	AusNet	06/10/2020 08:15 Tuesday	06/10/2020 15:00 Tuesday	Hazelwood Terminal Station - Loy Yang Power Station 500 kV line	A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Load shedding in Victoria	Day: 2 hrs Night: No recall	Not required	Invoked	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	21/10/2020 05:00 Wednesday	21/10/2020 17:00 Wednesday						
VIC	AusNet	22/10/2020 05:00 Thursday	22/10/2020 17:00 Thursday						
VIC	AusNet	23/10/2020 05:00 Friday	23/10/2020 17:00 Friday						
VIC	AusNet	24/10/2020 05:00 Saturday	24/10/2020 17:00 Saturday		N/A A credible contingency event during this planned outage could cause				
VIC	AusNet	25/10/2020 05:00 Sunday	25/10/2020 17:00 Sunday	Maarahaal UCTS 500W/ no 1 UNE	synchronous separation of the South Australia region from the rest of the NEM.	Day: 2.5 hrs	To be issued	Being	Drojost work
VIC	AusNet	26/10/2020 05:00 Monday	26/10/2020 17:00 Monday	Moorabool-HGTS 500kV no 1 LINE	 Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). 	Night: No recall	To be issued	assessed	Project work
VIC	AusNet	27/10/2020 05:00 Tuesday	27/10/2020 17:00 Tuesday		 Post continent FCAS will be sourced within SA following Separation event. 				
VIC	AusNet	28/10/2020 05:00 Wednesday	28/10/2020 17:00 Wednesday						
VIC	AusNet	29/10/2020 05:00 Thursday	29/10/2020 17:00 Thursday						
VIC	AusNet	30/10/2020 05:00 Friday	30/10/2020 17:00 Friday						
VIC	AusNet	04/11/2020 05:00 Wednesday	04/11/2020 17:00 Wednesday						
VIC	AusNet	05/11/2020 05:00 Thursday	05/11/2020 17:00 Thursday						
VIC	AusNet	06/11/2020 05:00 Friday	06/11/2020 17:00 Friday						
VIC	AusNet	07/11/2020 05:00 Saturday	07/11/2020 17:00 Saturday		A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of				
VIC	AusNet	08/11/2020 05:00 Sunday	08/11/2020 17:00 Sunday		the NEM. During this planned outage:	Day: 2.5 hrs	Ta ba ianu d	Being	Designations
VIC	AusNet	09/11/2020 05:00 Monday	09/11/2020 17:00 Monday	Moorabool - Mortlake 500 kV Line	Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Night: No recall	To be issued	assessed	Project work
VIC	AusNet	10/11/2020 05:00 Tuesday	10/11/2020 17:00 Tuesday		 Post contingent FCAS will be sourced within SA following Separation event. 				
VIC	AusNet	11/11/2020 05:00 Wednesday	11/11/2020 17:00 Wednesday						
VIC	AusNet	12/11/2020 05:00 Thursday	12/11/2020 17:00 Thursday						
VIC	AusNet	13/11/2020 05:00 Friday	13/11/2020 17:00 Friday						



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
Region	NJF	Start	Fillişli	Network asset	impact	Recail time	Warkernotice	constraint	Outage reason
VIC	AusNet	14/11/2020 05:00 Saturday	14/11/2020 17:00 Saturday	Moorabool - Mortlake 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2.5 hrs Night: No recall	To be issued	Being assessed	Project work
VIC	AusNet	15/11/2020 05:00 Sunday	15/11/2020 17:00 Sunday	Moorabool - Mortlake 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2.5 hrs Night: No recall	To be issued	Being assessed	Project work
VIC	AusNet	16/11/2020 07:30 Monday	16/11/2020 18:30 Monday						
VIC	AusNet	17/11/2020 07:30 Tuesday	17/11/2020 18:30 Tuesday						
VIC	AusNet	18/11/2020 07:30 Wednesday	18/11/2020 18:30 Wednesday]	This is a high-impact outage only if the forecast temperature at Red				
VIC	AusNet	19/11/2020 07:30 Thursday	19/11/2020 18:30 Thursday	Bendigo - Kerang 220 kV Line	Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid	Day: 2 hrs Night: No recall	Not required	Invoked	Maintenance
VIC	AusNet	20/11/2020 07:30 Friday	20/11/2020 18:30 Friday		Market intervention through issuing of directions.				
VIC	AusNet	21/11/2020 07:30 Saturday	21/11/2020 18:30 Saturday						
VIC	AusNet	22/11/2020 07:30 Sunday	22/11/2020 18:30 Sunday						
VIC	AusNet	24/11/2020 07:30 Tuesday	24/11/2020 16:30 Tuesday						
VIC	AusNet	25/11/2020 07:30 Wednesday	25/11/2020 16:30 Wednesday	Ararat Waubra 220 Willing	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C	Day: 2 hrs	Not required	Invokod	Maintonance
VIC	AusNet	26/11/2020 07:30 Thursday	26/11/2020 16:30 Thursday	Ararat - Waubra 220 kV Line	 A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Night: No recall	Not required	Invoked	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
146	A	27/11/2020 07:30	27/11/2020 16:30						
VIC	AusNet	Friday	Friday						
VIC	AusNet	12/04/2021 07:00	12/04/2021 17:00						
VIC	Auswei	Monday	Monday						
VIC	AusNet	13/04/2021 07:00	13/04/2021 17:00						
VIC	Auswei	Tuesday	Tuesday						
VIC	AusNet	14/04/2021 07:00	14/04/2021 17:00						
VIC	Auswei	Wednesday	Wednesday		This is a high-impact outage only if the forecast temperature at Red				
VIC	AusNet	15/04/2021 07:00	15/04/2021 17:00	Red Cliffs-Wemen 220kV LINE	Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 2 hrs	Not required	Being	Maintenance
VIC	Auswei	Thursday	Thursday	Red Cliffs-Wernen 220KV LINE	Load shedding in the Victorian outer grid	Night: Not applicable	Not required	assessed	Wantenance
VIC	AusNet	16/04/2021 07:00	16/04/2021 17:00		Market intervention through issuing of directions.				
VIC	Auswei	Friday	Friday						
VIC	AusNet	17/04/2021 07:00	17/04/2021 17:00						
VIC	Auswei	Saturday	Saturday						
VIC	AusNet	18/04/2021 07:00	18/04/2021 17:00						
VIC	Auswei	Sunday	Sunday						
VIC	AusNet	24/05/2021 07:00	24/05/2021 17:00						
vic	Auswei	Monday	Monday						
VIC	AusNet	25/05/2021 07:00	25/05/2021 17:00						
vic	Ausiver	Tuesday	Tuesday						
VIC	AusNet	26/05/2021 07:00	26/05/2021 17:00						
vic	Ausiver	Wednesday	Wednesday		This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C				
VIC	AusNet	27/05/2021 07:00	27/05/2021 17:00	Kerang-Wemen 220kV LINE	A credible contingency event during this planned outage may require:	Day: 2 hrs	Not required	Being	Maintenance
vic	Auswei	Thursday	Thursday		Load shedding in the Victorian outer grid	Night: Not applicable	Notrequired	assessed	Wantenance
VIC	AusNet	28/05/2021 07:00	28/05/2021 17:00		 Market intervention through issuing of directions. 				
vic	Auswei	Friday	Friday						
VIC	AusNet	29/05/2021 07:00	29/05/2021 17:00						
vic	Ausiver	Saturday	Saturday						
VIC	AusNet	30/05/2021 07:00	30/05/2021 17:00						
vie	Austree	Sunday	Sunday						
QLD	Powerlink	01/07/2021 07:00 Thursday	18/08/2021 17:00 Wednesday	Stanwell – Broadsound 856 or 8831	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may result in shedding Far North QLD load and Lilyvale local load. Following a credible contingency market intervention through issuing of directions may be required. If market intervention is unsuccessful all of North QLD load would be in a credible risk	Day: 8 hrs Night: 12 hrs	Not required	Being assessed	Maintenance



Upcoming high-impact		Newly added outage						
- F	Upcoming high-impact outages in the NEM (information as of 10/08/2020 1227 hrs):							
Region NSP	Start	Finish	Network asset	Impact	Recall time	Market notice Constraint Outage reason		

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice,

and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and

- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.