

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	31/08/2020 06:30 Monday	31/08/2020 18:00 Monday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
TAS	TasNetworks	31/08/2020 09:00 Monday	31/08/2020 15:00 Monday	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 30 mins Night: Not applicable	Not required	Invoked	Maintenance
NSW	Transgrid	01/09/2020 06:30 Tuesday	01/09/2020 18:00 Tuesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
QLD	Powerlink	01/09/2020 07:00 Tuesday	01/09/2020 18:00 Tuesday	Ross - Haughton River 8911 275 kV line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 4 hrs Night: 8 hrs	Not required	Invoked	Maintenance
NSW	Transgrid	02/09/2020 06:30 Wednesday	02/09/2020 18:00 Wednesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
TAS	TasNetworks	02/09/2020 09:00 Wednesday	02/09/2020 11:00 Wednesday	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 30 mins Night: Not applicable	Not required	Invoked	Maintenance
NSW	Transgrid	03/09/2020 06:30 Thursday	03/09/2020 18:00 Thursday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	04/09/2020 06:30 Friday	04/09/2020 18:00 Friday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	05/09/2020 06:30 Saturday	05/09/2020 18:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
VIC	AusNet	06/09/2020 05:30 Sunday	06/09/2020 17:00 Sunday	Kiamal SF-MuraWara 220kV LINE	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
NSW	Transgrid	06/09/2020 07:00 Sunday	06/09/2020 17:00 Sunday	Liddell to Muswellbrook (83) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 6 hrs Night: 6 hrs	Not required	Invoked	Maintenance
NSW	Transgrid	07/09/2020 06:30 Monday	07/09/2020 18:00 Monday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
QLD	Powerlink	07/09/2020 08:30 Monday	07/09/2020 15:00 Monday	Strathmore - Ross (8858) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance
QLD	Powerlink	07/09/2020 11:30 Monday	07/09/2020 15:00 Monday	Ross No.4 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance
QLD	Powerlink	07/09/2020 11:30 Monday	07/09/2020 15:00 Monday	Ross No.4 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 1 hrs Night: Not applicable	Not required	Being assessed	Maintenance
NSW	Transgrid	08/09/2020 06:30 Tuesday	12/09/2020 18:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: 4 hrs	Not required	Invoked	Maintenance
NSW	Transgrid	14/09/2020 06:30 Monday	19/09/2020 18:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: 4 hrs	Not required	Invoked	Maintenance
VIC	AusNet	16/09/2020 07:00 Wednesday	17/09/2020 17:00 Thursday	Dederang - Wodonga 330 kV Line	This is a high-impact outage if the forecast temperature at Red Cliffs is greater than 30 deg. C. This line outage offloads X5 220 kV line. Possible load shedding and risk of large reduction in generation in NSW and interconnector capacity between NSW - Victoria following a credible contingency	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
NSW	Transgrid	21/09/2020 06:30 Monday	26/09/2020 18:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: 4 hrs	Not required	Invoked	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	22/09/2020 07:00 Tuesday	22/09/2020 17:00 Tuesday	Hazelwood - Loy Yang Power Station No.1 500 kV Line	A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Load shedding in Victoria	Day: 8 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	22/09/2020 07:00 Tuesday	22/09/2020 17:00 Tuesday	Ballarat - Waubra 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	23/09/2020 07:00 Wednesday	23/09/2020 17:00 Wednesday	Hazelwood - Loy Yang Power Station No.1 500 kV Line	A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Load shedding in Victoria	Day: 8 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	24/09/2020 07:00 Thursday	24/09/2020 17:00 Thursday	Hazelwood - Loy Yang Power	A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria	Day: 8 hrs	Not required	Being	Maintenance
VIC	AusNet	25/09/2020 07:00 Friday	25/09/2020 17:00 Friday	Station No.1 500 kV Line	Load shedding in Victoria	Night: Not applicable	Not required	assessed	Maintenance
NSW	Transgrid	28/09/2020 06:30 Monday	28/09/2020 18:00 Monday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	29/09/2020 06:30 Tuesday	29/09/2020 18:00 Tuesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	30/09/2020 06:30 Wednesday	30/09/2020 18:00 Wednesday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
NSW	Transgrid	01/10/2020 06:30 Thursday	01/10/2020 18:00 Thursday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
NSW	Transgrid	02/10/2020 06:30 Friday	02/10/2020 18:00 Friday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance



Newly added outage Update(s) since the last notification

Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	03/10/2020 06:00 Saturday	03/10/2020 18:00 Saturday	Hazelwood Terminal Station - Loy Yang Power Station 500 kV line	A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Load shedding in Victoria	Day: 4 hrs Night: Not applicable	To be issued	Being assessed	Maintenance
NSW	Transgrid	03/10/2020 06:30 Saturday	03/10/2020 18:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Invoked	Maintenance
VIC	AusNet	04/10/2020 05:00 Sunday	04/10/2020 17:00 Sunday	Hazelwood Terminal Station - Loy	A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria	Day: 4 hrs	To be issued	Being	Maintenance
VIC	AusNet	05/10/2020 05:00 Monday	05/10/2020 15:00 Monday	Yang Power Station 500 kV line	Load shedding in Victoria	Night: Not applicable		assessed	
QLD	Powerlink	05/10/2020 07:00 Monday	16/10/2020 17:00 Friday	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 72 hrs Night: 96 hrs	Not required	Being assessed	Maintenance
NSW	Transgrid	06/10/2020 06:00 Tuesday	10/10/2020 15:00 Saturday	Muswellbrook - Tamworth (88) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: No recall	Not required	Being assessed	Maintenance
VIC	AusNet	06/10/2020 07:15 Tuesday	06/10/2020 14:00 Tuesday	Hazelwood Terminal Station - Loy Yang Power Station 500 kV line	A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Load shedding in Victoria	Day: 2 hrs Night: No recall	Not required	Invoked	Maintenance
VIC	AusNet	06/10/2020 08:15 Tuesday	06/10/2020 15:00 Tuesday	Hazelwood Terminal Station - Loy Yang Power Station 500 kV line	A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Load shedding in Victoria	Day: 2 hrs Night: No recall	Not required	Invoked	Maintenance
QLD	Powerlink	09/10/2020 08:30 Friday	09/10/2020 14:30 Friday	Ross No.3 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 2 hrs Night: Not applicable	To be issued	Being assessed	Maintenance
VIC	AusNet	21/10/2020 05:00 Wednesday	21/10/2020 17:00 Wednesday						
VIC	AusNet	22/10/2020 05:00 Thursday	22/10/2020 17:00 Thursday						
VIC	AusNet	23/10/2020 05:00 Friday	23/10/2020 17:00 Friday						
VIC	AusNet	24/10/2020 05:00 Saturday	24/10/2020 17:00 Saturday		N/A A credible contingency event during this planned outage could cause				



Pagion	NSP	Start	Finish	Network asset	Import	Recall time	Market netice	Constraint	Outage reason
Region	INSP			Network asset	Impact synchronous separation of the South Australia region from the rest of	Kecall time	warket notice	constraint	Outage reason
VIC	AusNet	25/10/2020 05:00	25/10/2020 17:00		the NEM.				
		Sunday	Sunday	Moorabool-HGTS 500kV no 1 LINE	During this planned outage:	Day: 2.5 hrs	To be issued	Being	Project work
VIC	AusNet	26/10/2020 05:00	26/10/2020 17:00		Power transfer will be restricted across the Victoria - South Australia	Night: No recall		assessed	-
		Monday	Monday	-	interconnector (Heywood interconnector).				
VIC	AusNet	27/10/2020 05:00	27/10/2020 17:00		 Post contingent FCAS will be sourced within SA following Separation 				
_		Tuesday	Tuesday	_	event.				
VIC	AusNet	28/10/2020 05:00	28/10/2020 17:00						
	Addition	Wednesday	Wednesday						
VIC	AusNet	29/10/2020 05:00	29/10/2020 17:00						
vic	Aushet	Thursday	Thursday						
VIC	AusNet	30/10/2020 05:00	30/10/2020 17:00						
VIC	Aushet	Friday	Friday						
146	Aughlat	04/11/2020 05:00	04/11/2020 17:00						
VIC	AusNet	Wednesday	Wednesday						
		05/11/2020 05:00	05/11/2020 17:00	-					
VIC	AusNet	Thursday	Thursday						
		06/11/2020 05:00	06/11/2020 17:00						
VIC	AusNet	Friday	Friday						
		07/11/2020 05:00	07/11/2020 17:00						
VIC	AusNet	Saturday	Saturday		A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of				
		08/11/2020 05:00	08/11/2020 17:00		the NEM.				
VIC	AusNet	Sunday	Sunday		During this planned outage:	Day: 2.5 hrs		Being	
		09/11/2020 05:00	09/11/2020 17:00	Moorabool - Mortlake 500 kV Line	 Power transfer will be restricted across the Victoria - South Australia 	Night: No recall	To be issued	assessed	Project work
VIC	AusNet	Monday	Monday		interconnector (Heywood interconnector).	0			
	-	10/11/2020 05:00	10/11/2020 17:00	-	 Post contingent FCAS will be sourced within SA following Separation 				
VIC	AusNet	Tuesday	Tuesday		event.				
		11/11/2020 05:00	11/11/2020 17:00	4					
VIC	AusNet	Wednesday	Wednesday						
		12/11/2020 05:00	12/11/2020 17:00	-					
VIC	AusNet	12/11/2020 05:00 Thursday	12/11/2020 17:00 Thursday						
		,		4					
VIC	AusNet	13/11/2020 05:00	13/11/2020 17:00						
		Friday	Friday						



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	14/11/2020 05:00 Saturday	14/11/2020 17:00 Saturday	Moorabool - Mortlake 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2.5 hrs Night: No recall	To be issued	Being assessed	Project work
VIC	AusNet	15/11/2020 05:00 Sunday	15/11/2020 17:00 Sunday	Moorabool - Mortlake 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2.5 hrs Night: No recall	To be issued	Being assessed	Project work
VIC	AusNet	16/11/2020 07:30	16/11/2020 18:30						
VIC	AusNet	Monday 17/11/2020 07:30 Tuesday	Monday 17/11/2020 18:30 Tuesday						
VIC	AusNet	18/11/2020 07:30 Wednesday	18/11/2020 18:30 Wednesday		This is a high-impact outage only if the forecast temperature at Red				
VIC	AusNet	19/11/2020 07:30 Thursday	19/11/2020 18:30 Thursday	Bendigo - Kerang 220 kV Line	Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:	Day: 2 hrs Night: No recall	Not required	Invoked	Maintenance
VIC	AusNet	20/11/2020 07:30 Friday	20/11/2020 18:30 Friday		 Load shedding in the Victorian outer grid Market intervention through issuing of directions. 				
VIC	AusNet	21/11/2020 07:30 Saturday	21/11/2020 18:30 Saturday						
VIC	AusNet	22/11/2020 07:30 Sunday	22/11/2020 18:30 Sunday						
VIC	AusNet	24/11/2020 07:30 Tuesday	24/11/2020 16:30 Tuesday						
VIC	AusNet	25/11/2020 07:30 Wednesday	25/11/2020 16:30 Wednesday		This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C	Day: 2 hrs			
VIC	AusNet	26/11/2020 07:30 Thursday	26/11/2020 16:30 Thursday		 A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Night: No recall	Not required	Invoked	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC	AusNet	27/11/2020 07:30 Friday	27/11/2020 16:30 Friday						
VIC	AusNet	12/04/2021 07:00 Monday	12/04/2021 17:00 Monday						
VIC	AusNet	13/04/2021 07:00 Tuesday	13/04/2021 17:00 Tuesday						
VIC	AusNet	14/04/2021 07:00 Wednesday	14/04/2021 17:00 Wednesday		This is a high-impact outage only if the forecast temperature at Red				
VIC	AusNet	15/04/2021 07:00 Thursday	15/04/2021 17:00 Thursday	Red Cliffs-Wemen 220kV LINE	Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	16/04/2021 07:00 Friday	16/04/2021 17:00 Friday		Market intervention through issuing of directions.				
VIC	AusNet	17/04/2021 07:00 Saturday	17/04/2021 17:00 Saturday						
VIC	AusNet	18/04/2021 07:00 Sunday	18/04/2021 17:00 Sunday						
VIC	AusNet	24/05/2021 07:00 Monday	24/05/2021 17:00 Monday						
VIC	AusNet	25/05/2021 07:00 Tuesday	25/05/2021 17:00 Tuesday						
VIC	AusNet	26/05/2021 07:00 Wednesday	26/05/2021 17:00 Wednesday		This is a high-impact outage only if the forecast temperature at Red				
VIC	AusNet	27/05/2021 07:00 Thursday	27/05/2021 17:00 Thursday		Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid	Day: 2 hrs Night: Not applicable	Not required	Being assessed	Maintenance
VIC	AusNet	28/05/2021 07:00 Friday	28/05/2021 17:00 Friday		Market intervention through issuing of directions.				
VIC	AusNet	29/05/2021 07:00 Saturday	29/05/2021 17:00 Saturday						
VIC	AusNet	30/05/2021 07:00 Sunday	30/05/2021 17:00 Sunday						
QLD	Powerlink	01/07/2021 07:00 Thursday	18/08/2021 17:00 Wednesday	Stanwell – Broadsound 856 or 8831	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may result in shedding Far North QLD load and Lilyvale local load. Following a credible contingency market intervention through issuing of directions may be required. If market intervention is unsuccessful all of North QLD load would be in a credible risk	Day: 8 hrs Night: 12 hrs	Not required	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
SA	ElectraNet	06/07/2021 08:15 Tuesday	11/07/2021 08:15 Sunday	Tailem Bend - South East No 1 275 kV line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 159 hrs Night: 159 hrs	To be issued	Being assessed	Maintenance
SA	ElectraNet	11/07/2021 08:15 Sunday	13/07/2021 12:30 Tuesday	Tailem Bend - South East No 1 275 kV line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 159 hrs Night: 159 hrs	To be issued	Being assessed	Maintenance
SA	ElectraNet	13/07/2021 12:30 Tuesday	15/07/2021 17:30 Thursday	Tailem Bend - South East No 1 275 kV line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 159 hrs Night: 159 hrs	To be issued	Being assessed	Maintenance
SA	ElectraNet	27/07/2021 12:30 Tuesday	29/07/2021 17:30 Thursday	Tailem Bend - South East No 2 275 kV line	A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to: • Initiate the orderly separation of SA from the rest of the NEM. • Source increased local regulation FCAS within SA. During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 159 hrs Night: 159 hrs	To be issued	Being assessed	Maintenance



Region	NSP	Start	Finish	Network asset	Impact	Recall time	Market notice	Constraint	Outage reason
VIC / SA	ElectraNet	03/08/2021 08:15 Tuesday	10/08/2021 08:15 Tuesday	South East - Heywood	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 159 hrs Night: 159 hrs	To be issued	Being assessed	Maintenance
VIC / SA	ElectraNet	10/08/2021 08:15 Tuesday	12/08/2021 17:30 Thursday	South East - Heywood	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 159 hrs Night: 159 hrs	To be issued	Being assessed	Maintenance
VIC / SA	ElectraNet	17/08/2021 08:15 Tuesday	24/08/2021 08:15 Tuesday	South East - Heywood	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 159 hrs Night: 159 hrs	To be issued	Being assessed	Maintenance
VIC / SA	ElectraNet	24/08/2021 08:15 Tuesday	26/08/2021 17:30 Thursday	South East - Heywood	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 159 hrs Night: 159 hrs	To be issued	Being assessed	Maintenance



Upcoming	high-impact	outages in the NEI	M (information as o	of 31/08/2020 1134 hrs):			Newly added outage
- 0							Update(s) since the last notification
Region NSP Start Finish Network asset Impact Recall tir							Market notice Constraint Outage reason

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice,

and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and

- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.