

| Region | NSP       | Start                         | Finish                        | Network asset                                                      | Impact                                                                                                                                           | Recall time                         | Market notice | Constraint        | Outage reason |
|--------|-----------|-------------------------------|-------------------------------|--------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|---------------|-------------------|---------------|
| NSW    | Transgrid | 28/09/2020 06:30<br>Monday    | 28/09/2020 18:00<br>Monday    | Muswellbrook - Tamworth (88) 330                                   | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs<br>Night: No recall      | Not required  | Invoked           | Maintenance   |
| NSW    | Transgrid | 29/09/2020 06:30<br>Tuesday   | 29/09/2020 18:00<br>Tuesday   | Muswellbrook - Tamworth (88) 330<br>kV Line                        | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs<br>Night: No recall      | Not required  | Being<br>assessed | Maintenance   |
| NSW    | Transgrid | 30/09/2020 06:30<br>Wednesday | 30/09/2020 18:00<br>Wednesday | Muswellbrook - Tamworth (88) 330<br>kV Line                        | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs<br>Night: No recall      | Not required  | Being<br>assessed | Maintenance   |
| NSW    | Transgrid | 01/10/2020 06:30<br>Thursday  | 01/10/2020 18:00<br>Thursday  | Muswellbrook - Tamworth (88) 330<br>kV Line                        | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs<br>Night: No recall      | Not required  | Invoked           | Maintenance   |
| NSW    | Transgrid | 02/10/2020 06:30<br>Friday    | 02/10/2020 18:00<br>Friday    | Muswellbrook - Tamworth (88) 330<br>kV Line                        | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs<br>Night: No recall      | Not required  | Invoked           | Maintenance   |
| VIC    | AusNet    | 03/10/2020 06:00<br>Saturday  | 03/10/2020 18:00<br>Saturday  | Hazelwood Terminal Station - Loy<br>Yang Power Station 500 kV line | A credible contingency event during this planned outage could cause:  • A large reduction in generation in Victoria  • Load shedding in Victoria | Day: 4 hrs<br>Night: Not applicable | To be issued  | Being<br>assessed | Maintenance   |
| NSW    | Transgrid | 03/10/2020 06:30<br>Saturday  | 03/10/2020 18:00<br>Saturday  | Muswellbrook - Tamworth (88) 330                                   | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs<br>Night: No recall      | Not required  | Invoked           | Maintenance   |
| VIC    | AusNet    | 04/10/2020 05:00<br>Sunday    | 04/10/2020 17:00<br>Sunday    | Hazelwood Terminal Station - Loy                                   | A credible contingency event during this planned outage could cause:                                                                             | Day: 4 hrs                          |               | Being             |               |
| VIC    | AusNet    | 05/10/2020 05:00<br>Monday    | 05/10/2020 15:00<br>Monday    | Yang Power Station 500 kV line                                     | <ul> <li>A large reduction in generation in Victoria</li> <li>Load shedding in Victoria</li> </ul>                                               | Night: Not applicable               | To be issued  | assessed          | Maintenance   |
| NSW    | Transgrid | 06/10/2020 06:00<br>Tuesday   | 06/10/2020 17:00<br>Tuesday   | Muswellbrook - Tamworth (88) 330<br>kV Line                        | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs<br>Night: 4 hrs          | Not required  | Invoked           | Maintenance   |



| Region | NSP       | Start                         | Finish                        | Network asset                                                      | Impact                                                                                                                                                                                                                                  | Recall time                         | Market notice | Constraint        | Outage reason |
|--------|-----------|-------------------------------|-------------------------------|--------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|---------------|-------------------|---------------|
| NSW    | Transgrid | 06/10/2020 06:00<br>Tuesday   | 10/10/2020 15:00<br>Saturday  | Muswellbrook - Tamworth (88) 330<br>kV Line                        | This outage has been WITHDRAWN. A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM                                                         | Day: 4 hrs<br>Night: 4 hrs          | Not required  | Being<br>assessed | Maintenance   |
| QLD    | Powerlink | 06/10/2020 07:00<br>Tuesday   | 16/10/2020 17:00<br>Friday    | Bouldercombe - Nebo (821) 275 kV<br>Line                           | This outage has been WITHDRAWN. This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions. | Day: 72 hrs<br>Night: 96 hrs        | Not required  | Being<br>assessed | Maintenance   |
| QLD    | Powerlink | 06/10/2020 07:00<br>Tuesday   | 16/10/2020 17:00<br>Friday    | Bouldercombe - Nebo (821) 275 kV<br>Line                           | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.                                | Day: 72 hrs<br>Night: 96 hrs        | Not required  | Being<br>assessed | Maintenance   |
| VIC    | AusNet    | 06/10/2020 07:15<br>Tuesday   | 06/10/2020 14:00<br>Tuesday   | Hazelwood Terminal Station - Loy<br>Yang Power Station 500 kV line | A credible contingency event during this planned outage could cause:  • A large reduction in generation in Victoria  • Load shedding in Victoria                                                                                        | Day: 2 hrs<br>Night: No recall      | Not required  | Invoked           | Maintenance   |
| VIC    | AusNet    | 06/10/2020 08:15<br>Tuesday   | 06/10/2020 15:00<br>Tuesday   | Hazelwood Terminal Station - Loy<br>Yang Power Station 500 kV line | This outage has been WITHDRAWN. A credible contingency event during this planned outage could cause: A large reduction in generation in Victoria Load shedding in Victoria                                                              | Day: 2 hrs<br>Night: No recall      | Not required  | Invoked           | Maintenance   |
| NSW    | Transgrid | 07/10/2020 06:00<br>Wednesday | 07/10/2020 17:00<br>Wednesday | Muswellbrook - Tamworth (88) 330<br>kV Line                        | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM                                                                                        | Day: 4 hrs<br>Night: 4 hrs          | Not required  | Invoked           | Maintenance   |
| NSW    | Transgrid | 08/10/2020 06:00<br>Thursday  | 08/10/2020 17:00<br>Thursday  | Muswellbrook - Tamworth (88) 330<br>kV Line                        | A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM                                                                                          | Day: 4 hrs<br>Night: 4 hrs          | Not required  | Invoked           | Maintenance   |
| NSW    | Transgrid | 09/10/2020 06:00<br>Friday    | 09/10/2020 17:00<br>Friday    | Muswellbrook - Tamworth (88) 330<br>kV Line                        | A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM                                                                                          | Day: 4 hrs<br>Night: 4 hrs          | Not required  | Invoked           | Maintenance   |
| QLD    | Powerlink | 09/10/2020 08:30<br>Friday    | 09/10/2020 14:30<br>Friday    |                                                                    | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.                                | Day: 2 hrs<br>Night: Not applicable | To be issued  | Being<br>assessed | Maintenance   |



| Region | NSP         | Start                         | Finish                        | Network asset                                              | Impact                                                                                                                                           | Recall time                           | Market notice | Constraint        | Outage reason |
|--------|-------------|-------------------------------|-------------------------------|------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|---------------|-------------------|---------------|
| NSW    | Transgrid   | 10/10/2020 06:00<br>Saturday  | 10/10/2020 17:00<br>Saturday  | Muswellbrook - Tamworth (88) 330                           | A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM   | Day: 4 hrs<br>Night: 4 hrs            | Not required  | Invoked           | Maintenance   |
| NSW    | Transgrid   | 12/10/2020 06:00<br>Monday    | 12/10/2020 17:00<br>Monday    | Muswellbrook - Tamworth (88) 330<br>kV Line                | A credible contingency event during this planned outage could cause:  Synchronous separation of the Queensland region from the rest of the NEM   | Day: 4 hrs<br>Night: No recall        | Not required  | Invoked           | Maintenance   |
| TAS    | TasNetworks | 12/10/2020 11:00<br>Monday    | 12/10/2020 14:00<br>Monday    | Sheffield - Farrell No.2 220 kV Line                       | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.                                 | Day: 10 mins<br>Night: Not applicable | Not required  | Being<br>assessed | Maintenance   |
| NSW    | Transgrid   | 13/10/2020 06:00<br>Tuesday   | 13/10/2020 17:00<br>Tuesday   | Muswellbrook - Tamworth (88) 330<br>kV Line                | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs<br>Night: No recall        | Not required  | Invoked           | Maintenance   |
| TAS    | TasNetworks | 13/10/2020 07:00<br>Tuesday   | 13/10/2020 10:00<br>Tuesday   | Sheffield - Farrell No.1 220 kV Line                       | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.                                 | Day: 10 mins<br>Night: Not applicable | Not required  | Being<br>assessed | Maintenance   |
| NSW    | Transgrid   | 14/10/2020 06:00<br>Wednesday | 14/10/2020 17:00<br>Wednesday | Muswellbrook - Tamworth (88) 330<br>kV Line                | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs<br>Night: No recall        | Not required  | Invoked           | Maintenance   |
| TAS    | TasNetworks | 14/10/2020 08:00<br>Wednesday | 16/10/2020 16:00<br>Friday    | George Town - George Town<br>Converter Station 220 kV Line | Review in 2017.<br>Tasmania will be separated from the NEM                                                                                       | Day: 1 hrs<br>Night: 3 hrs            | Not required  | Invoked           | Maintenance   |
| NSW    | Transgrid   | 15/10/2020 06:00<br>Thursday  | 15/10/2020 17:00<br>Thursday  | Muswellbrook - Tamworth (88) 330<br>kV Line                | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs<br>Night: No recall        | Not required  | Invoked           | Maintenance   |
| TAS    | TasNetworks | 15/10/2020 06:30<br>Thursday  | 15/10/2020 11:00<br>Thursday  | <u> </u>                                                   | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.                                 | Day: 5 mins<br>Night: Not applicable  | Not required  | Being<br>assessed | Maintenance   |
| TAS    | TasNetworks | 15/10/2020 11:30<br>Thursday  | 15/10/2020 15:30<br>Thursday  | <u> </u>                                                   | A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.                                 | Day: 5 mins<br>Night: Not applicable  | Not required  | Being<br>assessed | Maintenance   |
| NSW    | Transgrid   | 16/10/2020 06:00<br>Friday    | 16/10/2020 17:00<br>Friday    | Muswellbrook - Tamworth (88) 330<br>kV Line                | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM | Day: 4 hrs<br>Night: No recall        | Not required  | Being<br>assessed | Maintenance   |



| Region | NSP        | Start                        | Finish                       | Network asset                               | Impact                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | Recall time                         | Market notice    | Constraint        | Outage reason |
|--------|------------|------------------------------|------------------------------|---------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|------------------|-------------------|---------------|
| Region | Nor        | Start                        | FIIIISII                     | Network asset                               | Impact                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | Recall tille                        | ivial ket notice | Constraint        | Outage reason |
| NSW    | Transgrid  | 17/10/2020 06:00<br>Saturday | 17/10/2020 17:00<br>Saturday | Muswellbrook - Tamworth (88) 330<br>kV Line | A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM                                                                                                                                                                                                                                                                                                                                                   | Day: 4 hrs<br>Night: No recall      | Not required     | Being<br>assessed | Maintenance   |
| SA     | ElectraNet | 17/10/2020 07:30<br>Saturday | 17/10/2020 17:30<br>Saturday | Cherry Gardens - Tailem Bend 275<br>kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  Initiate the orderly separation of SA from the rest of the NEM.  Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs<br>Night: Not applicable | To be issued     | Being<br>assessed | Maintenance   |
| NSW    | Transgrid  | 18/10/2020 06:30<br>Sunday   | 18/10/2020 15:00<br>Sunday   | Dumaresq-Sapphire (8J) 330kV                | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM                                                                                                                                                                                                                                                                                                                                                  | Day: 2 hrs<br>Night: No recall      | Not required     | Invoked           | Maintenance   |
| SA     | ElectraNet | 18/10/2020 07:30<br>Sunday   | 18/10/2020 17:30<br>Sunday   | Cherry Gardens - Tailem Bend 275<br>kV Line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  Initiate the orderly separation of SA from the rest of the NEM.  Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 2 hrs<br>Night: Not applicable | To be issued     | Being<br>assessed | Maintenance   |
| NSW    | Transgrid  | 19/10/2020 06:00<br>Monday   | 19/10/2020 17:00<br>Monday   | Muswellbrook - Tamworth (88) 330            | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM                                                                                                                                                                                                                                                                                                                                                  | Day: 4 hrs<br>Night: No recall      | Not required     | Being<br>assessed | Maintenance   |



| Region | NSP    | Start                         | Finish                        | Network asset                  | Impact                                                                                                                                                                                                                                                                                                                                                                                                              | Recall time                      | Market notice | Constraint        | Outage reason |
|--------|--------|-------------------------------|-------------------------------|--------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|---------------|-------------------|---------------|
| VIC    | AusNet | 20/10/2020 05:00<br>Tuesday   | 20/10/2020 17:00<br>Tuesday   | Tarrone - HGTS 500kV no 1 LINE | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.                                  | Day: 30 mins<br>Night: No recall | To be issued  | Being<br>assessed | Maintenance   |
| VIC    | AusNet | 21/10/2020 05:00<br>Wednesday | 21/10/2020 17:00<br>Wednesday | Moorabool-HGTS 500kV no 1 LINE | This outage has been WITHDRAWN.  N/A  A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall | To be issued  | Being<br>assessed | Project work  |
| VIC    | AusNet | 21/10/2020 05:00<br>Wednesday | 21/10/2020 17:00<br>Wednesday | Tarrone - HGTS 500kV no 1 LINE | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event.                                    | Day: 30 mins<br>Night: No recall | To be issued  | Being<br>assessed | Maintenance   |



| Region | NSP    | Start                         | Finish                        | Network asset                          | Impact                                                                                                                                                                                                                                                                                                                                                                                                              | Recall time                      | Market notice | Constraint        | Outage reason |
|--------|--------|-------------------------------|-------------------------------|----------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|---------------|-------------------|---------------|
| VIC    | AusNet | 21/10/2020 05:00<br>Wednesday | 21/10/2020 17:00<br>Wednesday | Moorabool–Sydenham No.1 500<br>kV Line | This is a high-impact outage only if the Emergency Moorabool Transformer Trip (EMTT) scheme remains activated. A credible contingency event during this planned outage could cause: A large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).                                                                              | Day: 2 hrs<br>Night: No recall   | Not required  | Being<br>assessed | Maintenance   |
| VIC    | AusNet | 22/10/2020 05:00<br>Thursday  | 22/10/2020 17:00<br>Thursday  | Moorabool-HGTS 500kV no 1 LINE         | This outage has been WITHDRAWN.  N/A  A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall | To be issued  | Being<br>assessed | Project work  |
| VIC    | AusNet | 22/10/2020 05:00<br>Thursday  | 22/10/2020 17:00<br>Thursday  | Tarrone - HGTS 500kV no 1 LINE         | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event.                                | Day: 30 mins<br>Night: No recall | To be issued  | Being<br>assessed | Maintenance   |
| VIC    | AusNet | 22/10/2020 05:00<br>Thursday  | 22/10/2020 17:00<br>Thursday  |                                        | This is a high-impact outage only if the Emergency Moorabool Transformer Trip (EMTT) scheme remains activated. A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).                                                                          | Day: 2 hrs<br>Night: No recall   | Not required  | Being<br>assessed | Maintenance   |



| Γ | Region | NSP    | Start                        | Finish                       | Network asset                  | Impact                                                                                                                                                                                                                                                                                                                                                                                                                  | Recall time                      | Market notice | Constraint        | Outage reason |
|---|--------|--------|------------------------------|------------------------------|--------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|---------------|-------------------|---------------|
|   | VIC    | AusNet | 23/10/2020 05:00<br>Friday   | 23/10/2020 17:00<br>Friday   | Moorabool-HGTS 500kV no 1 LINE | This outage has been WITHDRAWN. N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.      | Day: 2.5 hrs<br>Night: No recall | To be issued  | Being<br>assessed | Project work  |
|   | VIC    | AusNet | 23/10/2020 05:00<br>Friday   | 23/10/2020 17:00<br>Friday   | Tarrone - HGTS 500kV no 1 LINE | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.                                      | Day: 30 mins<br>Night: No recall | To be issued  | Being<br>assessed | Maintenance   |
|   | VIC    | AusNet | 24/10/2020 05:00<br>Saturday | 24/10/2020 17:00<br>Saturday | Moorabool-HGTS 500kV no 1 LINE | This outage has been WITHDRAWN.  N/A  A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall | To be issued  | Being<br>assessed | Project work  |



| Region | NSP    | Start                       | Finish                      | Network asset                  | Impact                                                                                                                                                                                                                                                                                                                                                                                                                  | Recall time                      | Market notice | Constraint        | Outage reason |
|--------|--------|-----------------------------|-----------------------------|--------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|---------------|-------------------|---------------|
| VIC    | AusNet | 25/10/2020 05:00<br>Sunday  | 25/10/2020 17:00<br>Sunday  | Moorabool-HGTS 500kV no 1 LINE | This outage has been WITHDRAWN.  N/A  A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event.     | Day: 2.5 hrs<br>Night: No recall | To be issued  | Being<br>assessed | Project work  |
| VIC    | AusNet | 26/10/2020 05:00<br>Monday  | 26/10/2020 17:00<br>Monday  | Moorabool-HGTS 500kV no 1 LINE | This outage has been WITHDRAWN.  N/A  A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event.     | Day: 2.5 hrs<br>Night: No recall | To be issued  | Being<br>assessed | Project work  |
| VIC    | AusNet | 27/10/2020 05:00<br>Tuesday | 27/10/2020 17:00<br>Tuesday | Moorabool-HGTS 500kV no 1 LINE | This outage has been WITHDRAWN.  N/A  A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall | To be issued  | Being<br>assessed | Project work  |



| Region | NSP    | Start                         | Finish                        | Network asset                  | Impact                                                                                                                                                                                                                                                                                                                                                                                                              | Recall time                           | Market notice | Constraint        | Outage reason |
|--------|--------|-------------------------------|-------------------------------|--------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|---------------|-------------------|---------------|
| VIC    | AusNet | 28/10/2020 05:00<br>Wednesday | 28/10/2020 17:00<br>Wednesday | Moorabool-HGTS 500kV no 1 LINE | This outage has been WITHDRAWN.  N/A  A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall      | To be issued  | Being<br>assessed | Project work  |
| VIC    | AusNet | 28/10/2020 05:00<br>Wednesday | 28/10/2020 17:00<br>Wednesday | Tarrone - HGTS 500kV no 1 LINE | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.                                  | Day: 30 mins<br>Night: Not applicable | To be issued  | Being<br>assessed | Maintenance   |
| VIC    | AusNet | 29/10/2020 05:00<br>Thursday  | 29/10/2020 17:00<br>Thursday  | Moorabool-HGTS 500kV no 1 LINE | This outage has been WITHDRAWN.  N/A  A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall      | To be issued  | Being<br>assessed | Project work  |



| Region | NSP       | Start                        | Finish                       | Network asset                               | Impact                                                                                                                                                                                                                                                                                                                                                                                                              | Recall time                           | Market notice | Constraint        | Outage reason |
|--------|-----------|------------------------------|------------------------------|---------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|---------------|-------------------|---------------|
| VIC    | AusNet    | 29/10/2020 05:00<br>Thursday | 29/10/2020 17:00<br>Thursday |                                             | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.                                  | Day: 30 mins<br>Night: Not applicable | To be issued  | Being<br>assessed | Maintenance   |
| VIC    | AusNet    | 30/10/2020 05:00<br>Friday   | 30/10/2020 17:00<br>Friday   | Moorabool-HGTS 500kV no 1 LINE              | This outage has been WITHDRAWN.  N/A  A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall      | To be issued  | Being<br>assessed | Project work  |
| QLD    | Powerlink | 31/10/2020 07:00<br>Saturday | 31/10/2020 18:53<br>Saturday | Ross - Haughton River 8911 275 kV<br>line   | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may require market intervention through issuing of directions.                                                                                                                                                                                                            | Day: 4 hrs<br>Night: No recall        | Not required  | Being<br>assessed | Maintenance   |
| NSW    | Transgrid | 02/11/2020 06:00<br>Monday   | 07/11/2020 15:00<br>Saturday | Muswellbrook - Tamworth (88) 330<br>kV Line | A credible contingency event during this planned outage could cause:  • Synchronous separation of the Queensland region from the rest of the NEM                                                                                                                                                                                                                                                                    | Day: 4 hrs<br>Night: No recall        | Not required  | Being<br>assessed | Maintenance   |



| Region | NSP       | Start                         | Finish                        | Network asset                    | Impact                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | Recall time                      | Market notice | Constraint        | Outage reason |
|--------|-----------|-------------------------------|-------------------------------|----------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|---------------|-------------------|---------------|
| NSW    | Transgrid | 03/11/2020 06:00<br>Tuesday   | 03/11/2020 16:00<br>Tuesday   | Jindera - Wagga (62) 330 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer  • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink • Contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.          | Day: 2 hrs<br>Night: No recall   | Not required  | Being<br>assessed | Maintenance   |
| NSW    | Transgrid | 04/11/2020 06:00<br>Wednesday | 04/11/2020 16:00<br>Wednesday | Jindera - Wagga (62) 330 kV Line | This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer  • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. | Day: 2 hrs<br>Night: No recall   | Not required  | Being<br>assessed | Maintenance   |
| VIC    | AusNet    | 09/11/2020 05:00<br>Monday    | 09/11/2020 17:00<br>Monday    |                                  | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of                                                                                                                                                                                                                                                                                                                              |                                  |               |                   |               |
| VIC    | AusNet    | 10/11/2020 05:00<br>Tuesday   | 10/11/2020 17:00<br>Tuesday   |                                  | the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia                                                                                                                                                                                                                                                                                                                                                         | Day: 2 hrs<br>Night: No recall   | To be issued  | Being<br>assessed | Maintenance   |
| VIC    | AusNet    | 11/11/2020 05:00<br>Wednesday | 11/11/2020 17:00<br>Wednesday |                                  | interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation                                                                                                                                                                                                                                                                                                                                                        |                                  |               |                   |               |
| VIC    | AusNet    | 12/11/2020 05:00<br>Thursday  | 12/11/2020 17:00<br>Thursday  | Moorabool-HGTS 500kV no 1 LINE   | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.                                                                                     | Day: 2.5 hrs<br>Night: No recall | To be issued  | Invoked           | Maintenance   |



| Region | NSP    | Start                        | Finish                       | Network asset                          | Impact                                                                                                                                                                                                                                                                                                                                                                             | Recall time                      | Market notice | Constraint        | Outage reason |
|--------|--------|------------------------------|------------------------------|----------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|---------------|-------------------|---------------|
| VIC    | AusNet | 12/11/2020 05:00<br>Thursday | 12/11/2020 17:00<br>Thursday | Heywood - Mortlake 500 kV Line         | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event.  | Day: 2 hrs<br>Night: No recall   | To be issued  | Being<br>assessed | Maintenance   |
| VIC    | AusNet | 13/11/2020 05:00<br>Friday   | 13/11/2020 17:00<br>Friday   | Moorabool-HGTS 500kV no 1 LINE         | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall | To be issued  | Invoked           | Maintenance   |
| VIC    | AusNet | 13/11/2020 05:00<br>Friday   | 13/11/2020 17:00<br>Friday   | Heywood - Mortlake 500 kV Line         | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event.      | Day: 2 hrs<br>Night: No recall   | To be issued  | Being<br>assessed | Maintenance   |
| VIC    | AusNet | 13/11/2020 05:00<br>Friday   | 13/11/2020 17:00<br>Friday   | Moorabool–Sydenham No.2 500<br>kV Line | This is a high-impact outage only if the Emergency Moorabool Transformer Trip (EMTT) scheme remains activated. A credible contingency event during this planned outage could cause:  • A large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).                                        | Day: 2 hrs<br>Night: No recall   | To be issued  | Being<br>assessed | Maintenance   |



| Region | NSP    | Start                        | Finish                       | Network asset                          | Impact                                                                                                                                                                                                                                                                                                                                                                                                     | Recall time                      | Market notice | Constraint        | Outage reason |
|--------|--------|------------------------------|------------------------------|----------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|---------------|-------------------|---------------|
| VIC    | AusNet | 14/11/2020 05:00<br>Saturday | 14/11/2020 17:00<br>Saturday |                                        | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.                         | Day: 2.5 hrs<br>Night: No recall | To be issued  | Invoked           | Maintenance   |
| VIC    | AusNet | 14/11/2020 05:00<br>Saturday | 14/11/2020 17:00<br>Saturday | Moorabool–Sydenham No.2 500<br>kV Line | This is a high-impact outage only if the Emergency Moorabool Transformer Trip (EMTT) scheme remains activated. A credible contingency event during this planned outage could cause: • A large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).                                                                 | Day: 2 hrs<br>Night: No recall   | To be issued  | Being<br>assessed | Maintenance   |
| VIC    | AusNet | 15/11/2020 05:00<br>Sunday   | 15/11/2020 17:00<br>Sunday   | Moorabool - Mortlake 500 kV Line       | This outage has been WITHDRAWN. A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall | To be issued  | Being<br>assessed | Project work  |
| VIC    | AusNet | 15/11/2020 05:00<br>Sunday   | 15/11/2020 17:00<br>Sunday   | Moorabool-HGTS 500kV no 1 LINE         | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of                                                                                                                                                                                                                                                              | Day: 2.5 hrs                     | To be issued  | Invoked           | Maintenance   |
| VIC    | AusNet | 16/11/2020 05:00<br>Monday   | 16/11/2020 17:00<br>Monday   |                                        | the NEM. During this planned outage:                                                                                                                                                                                                                                                                                                                                                                       | Night: No recall                 |               |                   |               |
| VIC    | AusNet | 16/11/2020 07:30<br>Monday   | 16/11/2020 18:30<br>Monday   | Bendigo - Kerang 220 kV Line           | This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.                                                                                                        | Day: 2 hrs<br>Night: No recall   | Not required  | Invoked           | Maintenance   |



| Region | NSP    | Start                         | Finish                        | Network asset                  | Impact                                                                                                                                                                                                                                                                                                                                                                             | Recall time                      | Market notice | Constraint | Outage reason |
|--------|--------|-------------------------------|-------------------------------|--------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|---------------|------------|---------------|
| VIC    | AusNet | 17/11/2020 05:00<br>Tuesday   | 17/11/2020 17:00<br>Tuesday   | Moorabool-HGTS 500kV no 1 LINE | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall | To be issued  | Invoked    | Maintenance   |
| VIC    | AusNet | 17/11/2020 07:30<br>Tuesday   | 17/11/2020 18:30<br>Tuesday   | Bendigo - Kerang 220 kV Line   | This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.                                                                                | Day: 2 hrs<br>Night: No recall   | Not required  | Invoked    | Maintenance   |
| VIC    | AusNet | 18/11/2020 05:00<br>Wednesday | 18/11/2020 17:00<br>Wednesday | Moorabool-HGTS 500kV no 1 LINE | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall | To be issued  | Invoked    | Maintenance   |
| VIC    | AusNet | 18/11/2020 07:30<br>Wednesday | 18/11/2020 18:30<br>Wednesday | Bendigo - Kerang 220 kV Line   | This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.                                                                                | Day: 2 hrs<br>Night: No recall   | Not required  | Invoked    | Maintenance   |



| Region | NSP    | Start                        | Finish                       | Network asset                | Impact                                                                                                                                                                                                                                                                                                                                                                             | Recall time                      | Market notice | Constraint | Outage reason |
|--------|--------|------------------------------|------------------------------|------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|---------------|------------|---------------|
| VIC    | AusNet | 19/11/2020 05:00<br>Thursday | 19/11/2020 17:00<br>Thursday |                              | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall | To be issued  | Invoked    | Maintenance   |
| VIC    | AusNet | 19/11/2020 07:30<br>Thursday | 19/11/2020 18:30<br>Thursday | Bendigo - Kerang 220 kV Line | This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.                                                                                | Day: 2 hrs<br>Night: No recall   | Not required  | Invoked    | Maintenance   |
| VIC    | AusNet | 20/11/2020 05:00<br>Friday   | 20/11/2020 17:00<br>Friday   |                              | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall | To be issued  | Invoked    | Maintenance   |
| VIC    | AusNet | 20/11/2020 07:30<br>Friday   | 20/11/2020 18:30<br>Friday   | Bendigo - Kerang 220 kV Line | This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.                                                                                | Day: 2 hrs<br>Night: No recall   | Not required  | Invoked    | Maintenance   |



| Region | NSP    | Start                        | Finish                       | Network asset                  | Impact                                                                                                                                                                                                                                                                                                                                                                             | Recall time                      | Market notice | Constraint | Outage reason |
|--------|--------|------------------------------|------------------------------|--------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|---------------|------------|---------------|
| VIC    | AusNet | 21/11/2020 05:00<br>Saturday | 21/11/2020 17:00<br>Saturday | Moorabool-HGTS 500kV no 1 LINE | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall | To be issued  | Invoked    | Maintenance   |
| VIC    | AusNet | 21/11/2020 07:30<br>Saturday | 21/11/2020 18:30<br>Saturday | Bendigo - Kerang 220 kV Line   | This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.                                                                                | Day: 2 hrs<br>Night: No recall   | Not required  | Invoked    | Maintenance   |
| VIC    | AusNet | 22/11/2020 05:00<br>Sunday   | 22/11/2020 17:00<br>Sunday   | Moorabool-HGTS 500kV no 1 LINE | N/A A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall | To be issued  | Invoked    | Maintenance   |
| VIC    | AusNet | 22/11/2020 07:30<br>Sunday   | 22/11/2020 18:30<br>Sunday   | Bendigo - Kerang 220 kV Line   | This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: Load shedding in the Victorian outer grid Market intervention through issuing of directions.                                                                                | Day: 2 hrs<br>Night: No recall   | Not required  | Invoked    | Maintenance   |



| Region | NSP    | Start                         | Finish                        | Network asset                    | Impact                                                                                                                                                                                                                                                                                                                                                                            | Recall time                      | Market notice | Constraint        | Outage reason |
|--------|--------|-------------------------------|-------------------------------|----------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|---------------|-------------------|---------------|
| VIC    | AusNet | 24/11/2020 07:30<br>Tuesday   | 24/11/2020 16:30<br>Tuesday   | Ararat - Waubra 220 kV Line      | This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.                                                                           | Day: 2 hrs<br>Night: No recall   | Not required  | Invoked           | Maintenance   |
| VIC    | AusNet | 25/11/2020 07:30<br>Wednesday | 25/11/2020 16:30<br>Wednesday | Ararat - Waubra 220 kV Line      | This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.                                                                         | Day: 2 hrs<br>Night: No recall   | Not required  | Invoked           | Maintenance   |
| VIC    | AusNet | 26/11/2020 07:30<br>Thursday  | 26/11/2020 16:30<br>Thursday  | Ararat - Waubra 220 kV Line      | This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require:  • Load shedding in the Victorian outer grid  • Market intervention through issuing of directions.                                                                         | Day: 2 hrs<br>Night: No recall   | Not required  | Invoked           | Maintenance   |
| VIC    | AusNet | 27/11/2020 05:00<br>Friday    | 27/11/2020 17:00<br>Friday    | Moorabool - Mortlake 500 kV Line | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 2.5 hrs<br>Night: No recall | To be issued  | Being<br>assessed | Project work  |
| VIC    | AusNet | 27/11/2020 07:30<br>Friday    | 27/11/2020 16:30<br>Friday    | Ararat - Waubra 220 kV Line      | This outage has been WITHDRAWN. This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.                                                                           | Day: 2 hrs<br>Night: No recall   | Not required  | Invoked           | Maintenance   |
| VIC    | AusNet | 28/11/2020 05:00<br>Saturday  | 28/11/2020 17:00<br>Saturday  |                                  |                                                                                                                                                                                                                                                                                                                                                                                   |                                  |               |                   |               |



| Region | NSP      | Start                         | Finish                        | Network asset                        | Impact                                                                                                                    | Recall time           | Market notice | Constraint        | Outage reason |
|--------|----------|-------------------------------|-------------------------------|--------------------------------------|---------------------------------------------------------------------------------------------------------------------------|-----------------------|---------------|-------------------|---------------|
| VIC    | AusNet   | 29/11/2020 05:00              | 29/11/2020 17:00              |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | Ausivet  | Sunday                        | Sunday                        |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | AusNet   | 30/11/2020 05:00              | 30/11/2020 17:00              |                                      |                                                                                                                           |                       |               |                   |               |
|        |          | Monday                        | Monday                        |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | AusNet   | 01/12/2020 05:00              | 01/12/2020 17:00              |                                      | A credible contingency event during this planned outage could cause                                                       |                       |               |                   |               |
|        |          | Tuesday                       | Tuesday                       |                                      | synchronous separation of the South Australia region from the rest of                                                     | Day: 2.5 hrs          |               |                   | Project work  |
| VIC    | AusNet   | 02/12/2020 05:00<br>Wednesday | 02/12/2020 17:00<br>Wednesday |                                      | the NEM.                                                                                                                  |                       |               | Doing             |               |
|        |          | 03/12/2020 05:00              | 03/12/2020 17:00              | Moorabool - Mortlake 500 kV line     | During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia                    | Night: No recall      | To be issued  | Being<br>assessed |               |
| VIC    | AusNet   | Thursday                      | Thursday                      |                                      | interconnector (Heywood interconnector).                                                                                  | Tight: 110 readin     |               | assessea          |               |
|        |          | 04/12/2020 05:00              | 04/12/2020 17:00              |                                      | Post contingent FCAS will be sourced within SA following Separation                                                       |                       |               |                   |               |
| VIC    | AusNet   | Friday                        | Friday                        |                                      | event.                                                                                                                    |                       |               |                   |               |
|        |          | 05/12/2020 05:00              | 05/12/2020 17:00              |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | AusNet   | Saturday                      | Saturday                      |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | AusNet   | 06/12/2020 05:00              | 06/12/2020 17:00              |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | Ausivet  | Sunday                        | Sunday                        |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | AusNet   | 07/12/2020 05:00              | 07/12/2020 17:00              |                                      |                                                                                                                           |                       |               |                   |               |
| ****   | 71051101 | Monday                        | Monday                        |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | AusNet   | 12/04/2021 07:00              | 12/04/2021 17:00              |                                      |                                                                                                                           |                       |               |                   |               |
|        |          | Monday                        | Monday                        |                                      |                                                                                                                           |                       | Not required  |                   |               |
| VIC    | AusNet   | 13/04/2021 07:00<br>Tuesday   | 13/04/2021 17:00<br>Tuesday   |                                      |                                                                                                                           |                       |               |                   |               |
|        |          | 14/04/2021 07:00              | 14/04/2021 17:00              |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | AusNet   | Wednesday                     | Wednesday                     |                                      | This is a high-impact outage only if the forecast temperature at Red                                                      | Day: 2 hrs            |               |                   |               |
|        |          | 15/04/2021 07:00              | 15/04/2021 17:00              |                                      | Cliffs is greater than 30 °C                                                                                              |                       |               | Being             |               |
| VIC    | AusNet   | Thursday                      | Thursday                      | Red Cliffs-Wemen 220kV LINE          | A credible contingency event during this planned outage may require:                                                      | Night: Not applicable |               | assessed          | Maintenance   |
| 1.00   |          | 16/04/2021 07:00              | 16/04/2021 17:00              |                                      | <ul> <li>Load shedding in the Victorian outer grid</li> <li>Market intervention through issuing of directions.</li> </ul> |                       |               |                   |               |
| VIC    | AusNet   | Friday                        | Friday                        |                                      | - Warket intervention through issuing of directions.                                                                      |                       |               |                   |               |
| VIC    | AusNet   | 17/04/2021 07:00              | 17/04/2021 17:00              |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | Ausivet  | Saturday                      | Saturday                      |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | AusNet   | 18/04/2021 07:00              | 18/04/2021 17:00              |                                      |                                                                                                                           |                       |               |                   |               |
| ****   | 71051101 | Sunday                        | Sunday                        |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | AusNet   | 24/05/2021 07:00              | 24/05/2021 17:00              |                                      |                                                                                                                           |                       |               |                   |               |
|        |          | Monday                        | Monday                        |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | AusNet   | 25/05/2021 07:00              | 25/05/2021 17:00              |                                      |                                                                                                                           |                       |               |                   |               |
|        |          | Tuesday                       | Tuesday                       |                                      |                                                                                                                           |                       |               |                   |               |
| VIC    | AusNet   | 26/05/2021 07:00<br>Wednesday | 26/05/2021 17:00<br>Wednesday |                                      | is is a high-impact outage only if the forecast temperature at Red                                                        |                       |               |                   |               |
|        |          | 27/05/2021 07:00              | 27/05/2021 17:00              | Cliffs Kerang-Wemen 220kV LINE A cre | Cliffs is greater than 30 °C                                                                                              | Day: 2 hrs            |               | Being             |               |
| VIC    | AusNet 2 | Thursday                      | Thursday                      |                                      |                                                                                                                           | Night: Not applicable | Not required  | assessed          | Maintenance   |
|        |          |                               |                               | Ī                                    |                                                                                                                           | 1 5                   | I             |                   | ı l           |



| Region | NSP        | Start                        | Finish                        | Network asset                                | Impact                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | Recall time                    | Market notice | Constraint        | Outage reason |
|--------|------------|------------------------------|-------------------------------|----------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------|---------------|-------------------|---------------|
| VIC    | AusNet     | 28/05/2021 07:00             | 28/05/2021 17:00              |                                              | Market intervention through issuing of directions.                                                                                                                                                                                                                                                                                                                                                                                                                                                |                                |               |                   |               |
|        | 71051101   | Friday                       | Friday                        |                                              |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |                                |               |                   |               |
| VIC    | AusNet     | 29/05/2021 07:00             | 29/05/2021 17:00              |                                              |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |                                |               |                   |               |
|        |            | Saturday                     | Saturday                      |                                              |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |                                |               |                   |               |
| VIC    | AusNet     | 30/05/2021 07:00<br>Sunday   | 30/05/2021 17:00<br>Sunday    |                                              |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |                                |               |                   |               |
| QLD    | Powerlink  | 01/07/2021 07:00<br>Thursday | 18/08/2021 17:00<br>Wednesday | Stanwell – Broadsound 856 or<br>8831         | This is a high impact outage because the recall time is greater than 30 minutes.  A credible contingency event during this planned outage may result in shedding Far North QLD load and Lilyvale local load.  Following a credible contingency market intervention through issuing of directions may be required. If market intervention is unsuccessful all of North QLD load would be in a credible risk                                                                                        | Day: 8 hrs<br>Night: 12 hrs    | Not required  | Being<br>assessed | Maintenance   |
| SA     | ElectraNet | 06/07/2021 08:15<br>Tuesday  | 11/07/2021 08:15<br>Sunday    | Tailem Bend - South East No 1 275<br>kV line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  Initiate the orderly separation of SA from the rest of the NEM.  Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 159 hrs<br>Night: 159 hrs | To be issued  | Being<br>assessed | Maintenance   |
| SA     | ElectraNet | 11/07/2021 08:15<br>Sunday   | 13/07/2021 12:30<br>Tuesday   | Tailem Bend - South East No 1 275<br>kV line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  Initiate the orderly separation of SA from the rest of the NEM.  Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 159 hrs<br>Night: 159 hrs | To be issued  | Being<br>assessed | Maintenance   |



| Region   | NSP        | Start                       | Finish                       | Network asset                             | Impact                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | Recall time                    | Market notice | Constraint        | Outage reason |
|----------|------------|-----------------------------|------------------------------|-------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------|---------------|-------------------|---------------|
| SA       | ElectraNet | 13/07/2021 12:30<br>Tuesday | 15/07/2021 17:30<br>Thursday | Tailem Bend - South East No 1 275 kV line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  Initiate the orderly separation of SA from the rest of the NEM.  Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 159 hrs<br>Night: 159 hrs | To be issued  | Being<br>assessed | Maintenance   |
| SA       | ElectraNet | 27/07/2021 12:30<br>Tuesday | 29/07/2021 17:30<br>Thursday | Tailem Bend - South East No 2 275 kV line | A credible contingency event during this planned outage could leave South Australia connected to the NEM only via the South Australian 132 kV network. To maintain system security following this contingency AEMO will need to:  Initiate the orderly separation of SA from the rest of the NEM.  Source increased local regulation FCAS within SA.  During this planned outage power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). | Day: 159 hrs<br>Night: 159 hrs | To be issued  | Being<br>assessed | Maintenance   |
| VIC / SA | ElectraNet | 03/08/2021 08:15<br>Tuesday | 10/08/2021 08:15<br>Tuesday  |                                           | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  Post contingent FCAS will be sourced within SA following Separation event.                                                                                                                     | Day: 159 hrs<br>Night: 159 hrs | To be issued  | Being<br>assessed | Maintenance   |



Newly added outage

Update(s) since the last notification

| Region   | NSP        | Start                       | Finish                       | Network asset        | Impact                                                                                                                                                                                                                                                                                                                                                                            | Recall time                    | Market notice | Constraint        | Outage reason |
|----------|------------|-----------------------------|------------------------------|----------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------|---------------|-------------------|---------------|
| VIC / SA | ElectraNet | 10/08/2021 08:15<br>Tuesday | 12/08/2021 17:30<br>Thursday | South East - Heywood | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 159 hrs<br>Night: 159 hrs | To be issued  | Being<br>assessed | Maintenance   |
| VIC / SA | ElectraNet | 17/08/2021 08:15<br>Tuesday | 24/08/2021 08:15<br>Tuesday  | South East - Heywood | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 159 hrs<br>Night: 159 hrs | To be issued  | Being<br>assessed | Maintenance   |
| VIC / SA | ElectraNet | 24/08/2021 08:15<br>Tuesday | 26/08/2021 17:30<br>Thursday | South East - Heywood | A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.  During this planned outage:  • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector).  • Post contingent FCAS will be sourced within SA following Separation event. | Day: 159 hrs<br>Night: 159 hrs | To be issued  | Being<br>assessed | Maintenance   |

#### Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice,

and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies.

AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.