

Upcoming High-Impact Outages (HIOs) in the NEM
- Information Current as of: 12 July 2021 - 0708 hrs -

Legend

	Newly Added Outage
	Update(s) since the last notification
	Withdrawn since the last notification

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNSP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	12/07/2021 06:30 Monday	12/07/2021 08:00 Monday	Heywood 500 kV CB 213	<<NEW since the last notification>> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2 hrs Night: NA	In Progress - PTP MN: 87969 - Issued on: Fri 09/07/2021				✓	Maintenance 1.5 Hours
VIC	AusNet	12/07/2021 08:00 Monday	12/07/2021 19:00 Monday	Heywood - Mortlake 500 kV Line	<<NEW since the last notification>> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2 hrs Night: NA	Planned - PDLTP MN: 87715 - Issued on: Mon 28/06/2021	✓	✓	✓		Maintenance 11 Hours
NSW	Transgrid	12/07/2021 08:00 Monday	12/07/2021 16:00 Monday	Wagga - Darlington Point (63) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer •Between Victoria and New South Wales. •Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: NA	Planned - PDLTP	✓	✓	✓		Maintenance 8 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNISP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
SA	ElectraNet	12/07/2021 13:30 Monday	20/07/2021 08:15 Tuesday	Heywood - South East No.1 275 kV Line	<<This outage has been WITHDRAWN!>> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 159 hrs Night: 159 hrs	Withdrawn MN: 86982 - Issued on: Tue 15/06/2021				✓	Commissioning 7.8 Days
VIC	AusNet	13/07/2021 07:00 Tuesday	13/07/2021 19:00 Tuesday	Heywood - Mortlake 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2 hrs Night: NA	Planned - MTLTP MN: 87715 - Issued on: Mon 28/06/2021	✓	✓	✓		Maintenance 12 Hours
NSW	Transgrid	13/07/2021 07:30 Tuesday	13/07/2021 17:00 Tuesday	Armidale - Tamworth (86) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 2 hrs Night: NA	Planned - MTLTP	✓	✓	✓		Maintenance 9.5 Hours
VIC	AusNet	14/07/2021 07:00 Wednesday	14/07/2021 19:00 Wednesday	Heywood - Mortlake 500 kV Line	<<This outage has been WITHDRAWN!>> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2 hrs Night: NA	Withdrawn MN: 87715 - Issued on: Mon 28/06/2021					Maintenance 12 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNISP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	14/07/2021 07:00 Wednesday	14/07/2021 17:00 Wednesday	Heywood No.2 500 kV Bus	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - MTLTP		✓		✓	Maintenance 10 Hours
NSW	Transgrid	14/07/2021 07:30 Wednesday	14/07/2021 17:00 Wednesday	Armidale - Tamworth (86) 330 kV Line	A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> Synchronous separation of the Queensland region from the rest of the NEM 	Day: 2 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 9.5 Hours
VIC	AusNet	14/07/2021 08:00 Wednesday	14/07/2021 16:00 Wednesday	Rowville - South Morang 500 kV Line	This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: <ul style="list-style-type: none"> Cause a large reduction in generation in Victoria Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). 	Day: 1 hr Night: NA	Planned - MTLTP					Maintenance 8 Hours
VIC	AusNet	15/07/2021 07:00 Thursday	15/07/2021 18:00 Thursday	Kerang-Wemen 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 3 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 11 Hours
NSW	Transgrid	15/07/2021 07:30 Thursday	15/07/2021 17:00 Thursday	Armidale - Tamworth (86) 330 kV Line	A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> Synchronous separation of the Queensland region from the rest of the NEM 	Day: 2 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 9.5 Hours
VIC	AusNet	16/07/2021 07:00 Friday	16/07/2021 18:00 Friday	Kerang-Wemen 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 3 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 11 Hours
NSW	Transgrid	16/07/2021 07:30 Friday	16/07/2021 17:00 Friday	Armidale - Tamworth (86) 330 kV Line	A credible contingency event during this planned outage could cause: <ul style="list-style-type: none"> Synchronous separation of the Queensland region from the rest of the NEM 	Day: 2 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 9.5 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNISP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	17/07/2021 07:00 Saturday	17/07/2021 18:00 Saturday	Kerang-Wemen 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 3 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 11 Hours
NSW	Transgrid	17/07/2021 07:30 Saturday	17/07/2021 17:00 Saturday	Armidale - Tamworth (86) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 2 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 9.5 Hours
VIC	AusNet	18/07/2021 07:00 Sunday	18/07/2021 18:00 Sunday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 3 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 11 Hours
NSW	Transgrid	18/07/2021 07:30 Sunday	18/07/2021 17:00 Sunday	Armidale - Tamworth (86) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 2 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 9.5 Hours
NSW	Transgrid	19/07/2021 06:30 Monday	21/07/2021 17:00 Wednesday	Liddell to Muswellbrook (83) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: 4 hrs	Planned - RESUBMIT		✓		✓	Commissioning 2.4 Days
VIC	AusNet	19/07/2021 07:00 Monday	19/07/2021 18:00 Monday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 3 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 11 Hours
VIC	AusNet	20/07/2021 07:00 Tuesday	20/07/2021 18:00 Tuesday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 3 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 11 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNISP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
SA	ElectraNet	20/07/2021 08:15 Tuesday	22/07/2021 13:30 Thursday	Heywood - South East No.1 275 kV Line	<<This outage has been WITHDRAWN!>> A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 159 hrs Night: 159 hrs	Withdrawn MN: 87531 - Issued on: Mon 21/06/2021				✓	Commissioning 2.2 Days
VIC	AusNet	21/07/2021 07:00 Wednesday	21/07/2021 17:00 Wednesday	Heywood No.2 500 kV Bus	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2 hrs Night: NA	Planned - MTLTP MN: 87973 - Issued on: Fri 09/07/2021	✓			✓	Maintenance 10 Hours
VIC	AusNet	22/07/2021 07:00 Thursday	22/07/2021 17:00 Thursday	Heywood No.2 500 kV Bus	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2 hrs Night: NA	Planned - MTLTP MN: 87973 - Issued on: Fri 09/07/2021	✓			✓	Maintenance 10 Hours
VIC	AusNet	23/07/2021 07:00 Friday	23/07/2021 17:00 Friday	Heywood No.2 500 kV Bus	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event.	Day: 2 hrs Night: NA	Planned - MTLTP MN: 87973 - Issued on: Fri 09/07/2021	✓			✓	Maintenance 10 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNISP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
NSW	Transgrid	24/07/2021 06:00 Saturday	25/07/2021 17:00 Sunday	Liddell to Muswellbrook (83) 330 kV Line	A credible contingency event during this planned outage could cause: • Synchronous separation of the Queensland region from the rest of the NEM	Day: 4 hrs Night: 4 hrs	Planned - RESUBMIT		✓		✓	Commissioning 1.5 Days
VIC	AusNet	24/07/2021 07:00 Saturday	24/07/2021 18:00 Saturday	Kerang-Wemen 220 kV Line	<<NEW since the last notification>> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 3 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 11 Hours
VIC	AusNet	25/07/2021 07:00 Sunday	25/07/2021 18:00 Sunday	Kerang-Wemen 220 kV Line	<<NEW since the last notification>> This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 3 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 11 Hours
VIC	AusNet	26/07/2021 07:00 Monday	26/07/2021 17:00 Monday	Red Cliffs-Wemen 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 10 Hours
VIC	AusNet	26/07/2021 07:45 Monday	26/07/2021 16:00 Monday	Keilor - South Morang 500 kV Line	<<NEW since the last notification>> This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector).	Day: 0 mins Night: NA	Planned - MTLTP					Maintenance 8.3 Hours
VIC	AusNet	27/07/2021 07:00 Tuesday	27/07/2021 17:00 Tuesday	Red Cliffs-Wemen 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 10 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNISP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	27/07/2021 07:30 Tuesday	27/07/2021 16:00 Tuesday	South Morang - Sydenham No.2 500 kV Line	<<NEW since the last notification>> This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW A credible contingency event during this planned outage could: <ul style="list-style-type: none"> • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). 	Day: 1 hr Night: NA	Planned - SUBMIT					Maintenance 8.5 Hours
VIC	AusNet	28/07/2021 07:00 Wednesday	28/07/2021 19:00 Wednesday	Heywood - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 12 Hours
VIC	AusNet	29/07/2021 07:00 Thursday	29/07/2021 19:00 Thursday	Heywood - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 12 Hours
VIC	AusNet	30/07/2021 07:00 Friday	30/07/2021 19:00 Friday	Heywood - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 12 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNISP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	31/07/2021 07:00 Saturday	31/07/2021 19:00 Saturday	Heywood - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 12 Hours
VIC	AusNet	02/08/2021 07:00 Monday	03/08/2021 17:00 Tuesday	Heywood No.1 500 kV Bus	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. 	Day: 24 hrs Night: 24 hrs	Planned - SUBMIT					Maintenance 1.4 Days
VIC	AusNet	04/08/2021 07:00 Wednesday	04/08/2021 17:00 Wednesday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 10 Hours
VIC	AusNet	05/08/2021 07:00 Thursday	05/08/2021 17:00 Thursday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 10 Hours
VIC	AusNet	06/08/2021 07:00 Friday	06/08/2021 17:00 Friday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 10 Hours
VIC	AusNet	07/08/2021 07:00 Saturday	07/08/2021 17:00 Saturday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 10 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNISP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	08/08/2021 07:00 Sunday	08/08/2021 17:00 Sunday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 10 Hours
VIC	AusNet	09/08/2021 07:00 Monday	09/08/2021 17:00 Monday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 10 Hours
VIC	AusNet	10/08/2021 07:00 Tuesday	10/08/2021 17:00 Tuesday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 10 Hours
VIC	AusNet	11/08/2021 07:00 Wednesday	11/08/2021 17:00 Wednesday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 10 Hours
VIC	AusNet	12/08/2021 07:00 Thursday	12/08/2021 17:00 Thursday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 10 Hours
NSW	Transgrid	13/08/2021 07:00 Friday	13/08/2021 17:00 Friday	Buronga-Balranald (X3) 220kV line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C During this planned outage power transfer will be restricted <ul style="list-style-type: none"> • Between Victoria and New South Wales. • Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 4 hrs Night: NA	Planned - MTLTP		✓	✓	✓	Maintenance 10 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNISP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
NSW	Transgrid	13/08/2021 07:00 Friday	22/08/2021 17:00 Sunday	Lower Tumut - Wagga (051) 330 kV Line	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer</p> <ul style="list-style-type: none"> Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 48 hrs Night: 48 hrs	Planned - SUBMIT		✓		✓	Commissioning 9.4 Days
VIC	AusNet	16/08/2021 07:00 Monday	17/08/2021 17:00 Tuesday	Heywood No.2 500 kV Bus	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. 	Day: 24 hrs Night: 24 hrs	Planned - SUBMIT					Maintenance 1.4 Days
QLD	Powerlink	16/08/2021 08:30 Monday	17/08/2021 17:00 Tuesday	Broadsound - Nebo (834) 275 kV Line	<p><<NEW since the last notification>></p> <p>This is a high impact outage because the recall time is greater than 30 minutes.</p> <p>A credible contingency event during this planned outage may require market intervention through issuing of directions.</p>	Day: 3 hrs Night: 6 hrs	Planned - SUBMIT					Maintenance 1.4 Days
VIC	AusNet	20/08/2021 07:00 Friday	20/08/2021 19:00 Friday	Heywood - Mortlake 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 12 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNSP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	21/08/2021 07:00 Saturday	21/08/2021 19:00 Saturday	Heywood - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. 	Day: 1 hr Night: NA	Planned - SUBMIT					Maintenance 12 Hours
VIC	AusNet	23/08/2021 07:00 Monday	23/08/2021 17:00 Monday	Kerang-Wemen 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: NA Night: NA	Planned - SUBMIT					Maintenance 10 Hours
VIC	AusNet	24/08/2021 07:00 Tuesday	24/08/2021 17:00 Tuesday	Bendigo - Kerang 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: NA Night: NA	Planned - SUBMIT					Maintenance 10 Hours
QLD	Powerlink	24/08/2021 08:30 Tuesday	24/08/2021 17:00 Tuesday	Ross No.2 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 3 hrs Night: NA	Planned - SUBMIT					Maintenance 8.5 Hours
QLD	Powerlink	26/08/2021 09:00 Thursday	26/08/2021 12:00 Thursday	Nebo - Strathmore (8845) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 3 Hours
QLD	Powerlink	26/08/2021 13:00 Thursday	26/08/2021 17:00 Thursday	Nebo - Strathmore (8845) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 4 Hours
QLD	Powerlink	28/08/2021 07:00 Saturday	28/08/2021 18:00 Saturday	Haughton River - Strathmore (879) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 4 hrs Night: 8 hrs	Planned - SUBMIT					Maintenance 11 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNSP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
QLD	Powerlink	01/09/2021 08:30 Wednesday	01/09/2021 12:00 Wednesday	Ross No.4 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 1 hr Night: NA	Planned - SUBMIT					Maintenance 3.5 Hours
VIC	AusNet	04/09/2021 07:00 Saturday	04/09/2021 19:00 Saturday	Heywood - Mortlake 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 12 Hours
QLD	Powerlink	06/09/2021 08:30 Monday	10/09/2021 16:00 Friday	Ross No.3 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 4 hrs Night: 6 hrs	Planned - SUBMIT					Maintenance 4.3 Days
VIC	AusNet	18/09/2021 07:00 Saturday	20/09/2021 17:00 Monday	Jindera - Wodonga (060) 330 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer <ul style="list-style-type: none"> Between Victoria and New South Wales. Between South Australia and Victoria on Murraylink A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> Load shedding in the Victorian outer grid Market intervention through issuing of directions. 	Day: 4 hrs Night: 4 hrs	Planned - SUBMIT	✓	✓	✓		Maintenance 2.4 Days
VIC	AusNet	21/09/2021 07:00 Tuesday	21/09/2021 19:00 Tuesday	Heywood - Mortlake 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 12 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNISP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	22/09/2021 07:00 Wednesday	22/09/2021 19:00 Wednesday	Heywood - Mortlake 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 12 Hours
VIC	AusNet	23/09/2021 07:00 Thursday	23/09/2021 19:00 Thursday	Heywood - Mortlake 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 12 Hours
VIC	AusNet	29/09/2021 07:00 Wednesday	29/09/2021 19:00 Wednesday	Heywood - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 12 Hours
QLD	Powerlink	18/10/2021 07:00 Monday	30/10/2021 17:00 Saturday	Nebo - Broadsound (8847) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: NA Night: NA	Planned - SUBMIT					Commissioning 12.4 Days

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNSP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
NSW	Transgrid	19/10/2021 05:30 Tuesday	19/10/2021 13:00 Tuesday	Wagga - Darlington Point (63) 330 kV Line	<p>This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C</p> <p>This outage offloads the Buronga to Darlington Point X5 220 kV line and restricts power transfer</p> <ul style="list-style-type: none"> •Between Victoria and New South Wales. •Between South Australia and Victoria on Murraylink <p>A credible contingency event during this planned outage may require:</p> <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 2 hrs Night: NA	Planned - SUBMIT		✓	✓	✓	Maintenance 7.5 Hours
VIC	AusNet	19/10/2021 06:00 Tuesday	19/10/2021 16:00 Tuesday	Keilor – Sydenham 500 kV Line	<p>This is a high impact outage only if the Forecast Operational Demand in Victoria region is greater than 7,000 MW</p> <p>A credible contingency event during this planned outage could:</p> <ul style="list-style-type: none"> • Cause a large reduction in generation in Victoria • Restrict power transfer across the Victoria - South Australia interconnector (Heywood interconnector). 	Day: 3 hrs Night: NA	Planned - SUBMIT					Maintenance 10 Hours
VIC	AusNet	04/11/2021 06:00 Thursday	04/11/2021 18:00 Thursday	Heywood - Tarrone 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 12 Hours
VIC	AusNet	05/11/2021 06:00 Friday	05/11/2021 18:00 Friday	Heywood - Tarrone 500 kV Line	<p>A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM.</p> <p>During this planned outage:</p> <ul style="list-style-type: none"> • Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). • Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 12 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNISP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	06/11/2021 06:00 Saturday	06/11/2021 18:00 Saturday	Heywood - Tarrone 500 kV Line	A credible contingency event during this planned outage could cause synchronous separation of the South Australia region from the rest of the NEM. During this planned outage: <ul style="list-style-type: none"> Power transfer will be restricted across the Victoria - South Australia interconnector (Heywood interconnector). Post contingent FCAS will be sourced within SA following Separation event. 	Day: 2 hrs Night: NA	Planned - SUBMIT					Maintenance 12 Hours
QLD	Powerlink	08/11/2021 14:00 Monday	08/11/2021 15:00 Monday	Ross No.2 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 5 mins Night: NA	Planned - SUBMIT					Maintenance 60 Minutes
QLD	Powerlink	09/11/2021 08:00 Tuesday	09/11/2021 08:30 Tuesday	Ross No.3 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 5 mins Night: NA	Planned - SUBMIT					Maintenance 30 Minutes
QLD	Powerlink	10/11/2021 10:00 Wednesday	10/11/2021 10:30 Wednesday	Ross No.4 288/138/19 kV Transformer	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 5 mins Night: NA	Planned - SUBMIT					Maintenance 30 Minutes
TAS	TasNetworks	06/12/2021 07:00 Monday	06/12/2021 15:00 Monday	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: NA	Planned - SUBMIT			✓		Maintenance 8 Hours
QLD	Powerlink	06/12/2021 07:00 Monday	06/12/2021 16:00 Monday	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Commissioning 9 Hours
TAS	TasNetworks	07/12/2021 07:00 Tuesday	07/12/2021 15:00 Tuesday	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: NA	Planned - SUBMIT			✓		Maintenance 8 Hours
QLD	Powerlink	07/12/2021 07:00 Tuesday	07/12/2021 16:00 Tuesday	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Commissioning 9 Hours
TAS	TasNetworks	20/12/2021 07:00 Monday	20/12/2021 15:00 Monday	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: NA	Planned - SUBMIT			✓		Maintenance 8 Hours
TAS	TasNetworks	21/12/2021 07:00 Tuesday	21/12/2021 15:00 Tuesday	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: NA	Planned - SUBMIT			✓		Maintenance 8 Hours
TAS	TasNetworks	11/01/2022 07:00 Tuesday	11/01/2022 15:00 Tuesday	Gordon - Chapel St No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: NA	Planned - SUBMIT			✓		Commissioning 8 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNSP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
TAS	TasNetworks	15/02/2022 08:00 Tuesday	15/02/2022 14:00 Tuesday	Sheffield - Farrell No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1.5 hrs Night: NA	Planned - SUBMIT			✓		Maintenance 6 Hours
TAS	TasNetworks	16/02/2022 08:00 Wednesday	16/02/2022 14:30 Wednesday	Sheffield - Farrell No.2 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 2 hrs Night: NA	Planned - SUBMIT			✓		Maintenance 6.5 Hours
TAS	TasNetworks	24/02/2022 07:00 Thursday	24/02/2022 15:00 Thursday	Gordon - Chapel St No.1 220 kV Line	A credible contingency event during this planned outage could cause a large reduction in generation in Tasmania.	Day: 1 hr Night: NA	Planned - SUBMIT			✓		Commissioning 8 Hours
VIC	AusNet	01/03/2022 06:00 Tuesday	01/03/2022 15:00 Tuesday	Red Cliffs-Wemen 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 9 Hours
VIC	AusNet	01/03/2022 06:00 Tuesday	01/03/2022 15:00 Tuesday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 9 Hours
VIC	AusNet	02/03/2022 06:00 Wednesday	02/03/2022 15:00 Wednesday	Red Cliffs-Wemen 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 9 Hours
VIC	AusNet	03/03/2022 06:00 Thursday	03/03/2022 15:00 Thursday	Red Cliffs-Wemen 220 kV Line	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 9 Hours
VIC	AusNet	09/03/2022 06:00 Wednesday	09/03/2022 15:00 Wednesday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 9 Hours
VIC	AusNet	10/03/2022 06:00 Thursday	10/03/2022 15:00 Thursday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 9 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNSP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
VIC	AusNet	16/03/2022 06:00 Wednesday	16/03/2022 13:00 Wednesday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 7 Hours
VIC	AusNet	20/04/2022 07:00 Wednesday	20/04/2022 16:00 Wednesday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 9 Hours
VIC	AusNet	10/05/2022 07:00 Tuesday	10/05/2022 16:00 Tuesday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 9 Hours
QLD	Powerlink	10/05/2022 07:00 Tuesday	12/05/2022 17:00 Thursday	Bouldercombe - Nebo (821) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 6 hrs Night: 8 hrs	Planned - SUBMIT					Commissioning 2.4 Days
VIC	AusNet	11/05/2022 07:00 Wednesday	11/05/2022 16:00 Wednesday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 9 Hours
VIC	AusNet	12/05/2022 07:00 Thursday	12/05/2022 16:00 Thursday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 9 Hours
VIC	AusNet	13/05/2022 07:00 Friday	13/05/2022 16:00 Friday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 9 Hours
VIC	AusNet	17/05/2022 07:00 Tuesday	17/05/2022 16:00 Tuesday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: • Load shedding in the Victorian outer grid • Market intervention through issuing of directions.	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 9 Hours

Region	NSP	Start	Finish	Network Asset	Impact	Recall	Status and Market Notice	Unplanned?	DNISP Aware?	Generator Aware?	Inter-Regional	Reason and Duration
QLD	Powerlink	24/05/2022 07:00 Tuesday	03/06/2022 17:00 Friday	Bouldercombe - Broadsound (820) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 120 hrs Night: 120 hrs	Planned - SUBMIT					Commissioning 10.4 Days
VIC	AusNet	31/05/2022 07:00 Tuesday	31/05/2022 16:00 Tuesday	Buronga - Redcliffs (OX1) 220 kV Line.	This is a high-impact outage only if the forecast temperature at Red Cliffs is greater than 30 °C A credible contingency event during this planned outage may require: <ul style="list-style-type: none"> • Load shedding in the Victorian outer grid • Market intervention through issuing of directions. 	Day: 4 hrs Night: NA	Planned - SUBMIT					Maintenance 9 Hours
QLD	Powerlink	02/08/2022 07:00 Tuesday	22/08/2022 17:00 Monday	Nebo - Strathmore (8845) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: NA Night: NA	Planned - SUBMIT					Commissioning 20.4 Days
QLD	Powerlink	29/08/2022 07:00 Monday	16/09/2022 17:00 Friday	Nebo - Strathmore (878) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: NA Night: NA	Planned - SUBMIT					Commissioning 18.4 Days
QLD	Powerlink	13/09/2022 07:00 Tuesday	23/09/2022 17:00 Friday	Bouldercombe - Broadsound (820) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 120 hrs Night: 120 hrs	Planned - SUBMIT					Commissioning 10.4 Days
QLD	Powerlink	17/10/2022 07:00 Monday	03/11/2022 17:00 Thursday	Nebo - Strathmore (8845) 275 kV Line	This is a high impact outage because the recall time is greater than 30 minutes. A credible contingency event during this planned outage may require market intervention through issuing of directions.	Day: 24 hrs Night: 48 hrs	Planned - SUBMIT					Commissioning 17.4 Days

The following fields of data are submitted by NSPs to AEMO.

- ✓ **Unplanned** - Outage is forced outage, trip or submitted with short notice.
- ✓ **DNISP(s) Aware** - The TNSP that submitted the outage confirms they have notified DNISP(s) that are impacted by this outage and made aware of the risks of next contingency.
- ✓ **Generator(s) Aware** - The TNSP that submitted the outage confirms they have notified generator(s) that are directly impacted by this outage and made aware of potential risks of next credible contingency.
- ✓ **Inter-Regional** - The TNSP that submitted the outage confirms they have notified other TNSP(s) that may be impacted by this outage, often in the neighbouring region.

Disclaimer

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies. AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- * make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- * are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.